



BEFORE THE UNITED STATES.
ATOMIC ENERGY COMMISSION

In the Matter of) 7-6-71.
Consolidated Edison Company) Docket No. 50-247
of New York, Inc.)
(Indian Point Station, Unit No. 2))

ADDITIONAL TESTIMONY OF APPLICANT



PART I



Date: July 6, 1971

8110230216 710706
PDR ADOCK 05000247
T PDR

The testimony in this document is being supplied in response to the evidence proposed to be introduced by the Citizens Committee for the Protection of the Environment by its letter to the Atomic Safety and Licensing Board dated June 4, 1971. For each item of testimony the particular proposed finding by the Citizens Committee to which the testimony responds and the witness who will sponsor the testimony at the hearing on July 13 are identified.

1 Response to Item 3.a.3.g (p. 6) (Mr. John D. McAdoo)

2 The possibility of explosions in the reactor
3 vessel resulting from the accumulation of small releases
4 of hydrogen was considered. There are two potential
5 sources of hydrogen in the reactor, namely metal-water
6 reaction and radiolysis. They occur at different times.

7 Metal water reactions occur during the period of
8 high fuel cladding temperature before the ECCS has re-
9 flooded the core. Hydrogen produced is rapidly swept to
10 the containment with the steam produced by reflooding the
11 hot fuel. Until it reaches the containment, there is no
12 oxygen present, hence no possibility of combustion.

13 Radiolysis occurs during the long term cooling
14 period following reflooding, and is accompanied with
15 stoichiometric amounts of oxygen. The concentration of
16 these gases does not reach the explosive range, even
17 before dilution in the containment atmosphere, although a
18 flammable mixture may be present inside the reactor pipe or
19 reactor vessel dome. The energy release associated with
20 combustion of this mixture is insufficient to damage the
21 pressure retaining components of the system; hence it is
22 not conceivable that safety related functions of the
23 reactor coolant system would be affected by ignition of
24 the mixture.

25 Release and mixing of hydrogen in the containment
26 from the point of efflux was studied to show that mixing
27 occurs within a very small space. Ignition here is a remote

- 1 possibility -- but in case it would occur, the heat
- 2 energy of combustion can be accommodated within the
- 3 capacity of the emergency containment cooling systems.

1 Response to Item 3.a.3(i) (p. 7) (Mr. John D. McAdoo)

2 A stainless steel water reaction does not occur
3 below a temperature of about 2500°F. Since temperatures
4 do not reach this value in the design basis accident, such
5 reactions will not occur.

1 Response to Item 3.b.3 (p. 8) (Mr. John D. McAdoo)

2 Spray nozzles randomly selected from those to be
3 installed in Unit 2 were tested by the manufacturer and
4 found to exhibit drop size characteristics much more
5 favorable than that assumed in the FSAR. The analysis
6 was made assuming a number mean drop size larger than that
7 representing two standard deviations from the norm of the
8 measured data. The analysis is therefore quite conservative
9 in this regard.

1 Response to Item 6.b. (p. 15) (Mr. Joseph A. Prestele)

2 The plant will be adequately protected against
3 unauthorized entry by the measures outlined in the answer
4 to Citizens Committee's question No. H-30. In addition to
5 the roving guard patrol of the site, the normal point of
6 entry to the fenced plant proper is through a continuously
7 guarded gateway. Unauthorized attempts at entry by breach-
8 ing or climbing the fence will be deterred by intensive
9 perimeter lighting. Such lighting will also facilitate
10 detection of any attempts to gain unauthorized access to
11 the plant. In addition, Con Edison has under study a method
12 of direct surveillance of the lighted fence perimeter by
13 a modern electronic detection system to further enhance
14 security precautions.

15 If, in spite of these precautions, an unauthorized
16 person were to attain access to the fenced area, entry to
17 the plant controlled area buildings would be prevented
18 by locked doors. Further, entry points to the controlled
19 area from the conventional area will be equipped with
20 alarms and indicators to alert the Staff to any unauthorized
21 entry.

1 Response to Item 6.C. (p. 16) (Mr. John J. Grob)

2 An analysis of the probability of an aircraft
3 hitting Indian Point Unit No. 2 has been completed. It
4 is based upon (1) a survey of the current number of over-
5 flights by aircraft in the general vicinity of the Indian
6 Point site; (2) a probabilistic approximation of the
7 distance from the airway centerline to the point where
8 an aircraft hits the terrain being overflown if there is
9 an inflight accident; (3) the incidence rate of in-flight
10 aircraft accidents resulting in a serious crash; and
11 (4) the area of the Indian Point Unit No. 2 that is
12 considered to represent a target for such an aircraft
13 crash.

14 The in-flight accident data upon which the study
15 was based was obtained from the accident investigation
16 files of the National Transportation Safety Board. Airway
17 and overflight data was obtained from the New York Air
18 Route Traffic Control Center. The result of the study
19 yields an estimated probability of a hit by an aircraft
20 into the reactor containment, the spent fuel or the control
21 room buildings, of $p = 9 \times 10^{-8}$ /year.

22 Stated in other ways:

- 23 1. One hit would be expected in 11 million years.
- 24 2. The probability of having a hit in a year is
25 0.00000009 or a chance of 1 in 11 million
26 per year.

1 The Applicant concludes from this study that the
2 likelihood of an aircraft hitting Unit No. 2 is so remote
3 that this contingency need not be considered in the design.

4 With respect to the specific assertions in section
5 6.C. 1), 2), and 3) of intervenor's proposed findings, the
6 nearest holding pattern is the Brewster holding pattern
7 serving the Westchester County Airport. Only a small number
8 of aircraft use this holding pattern, and the closest point
9 of the pattern is 8 miles northeast of the Indian Point site.
10 The nearest approach route to Kennedy Airport does not go
11 directly over the plant site but rather passes two miles
12 east of the site. There are many aircraft movements within
13 ten horizontal miles of the site, but the Indian Point site
14 is not unique in this respect. These movements are taken
15 into account in the analysis described above.