

Consolidated Edison Company of New York, Inc.
4 Irving Place, New York, N.Y. 10003
Telephone (212) 480-5181

November 24, 1971

Re: Indian Point Station
Unit No. 2
Docket No. 50-247

Dr. Peter A. Morris, Director
Division of Reactor Licensing
U. S. Atomic Energy Commission
Washington, D. C. 20545


Dear Dr. Morris:

Our letter of November 14, 1971 submitted a report describing the fire incident which occurred on November 14 and indicated that we would be in contact with your office as soon as further discussions were appropriate.

With regard to restoration of fire damage please be advised that we plan to restore the building and its equipment to the conditions which preceded the fire and to meet in all respects the Unit 2 Final Facility Description and Safety Analysis Report. This restoration will be accomplished by thoroughly cleaning the building, testing its components and replacing or repairing those which are damaged. In particular the motor control centers and lighting switch gear which were damaged will be replaced with new equipment and will be connected to existing undamaged cables with splices, installed and tested in a manner to preserve the reliability of the approved design.

On Wednesday, November 24, 1971 we met with representatives of Region 1 of the Division of Compliance. Our plans for the restoration were discussed at that time and we expect to be in further contact with Region 1 as the work progresses. Should you have any questions regarding this work we are available to meet with your staff and to provide such information as you may require.

Very truly yours,



8111040635 711203
PDR ADDCK 05000247
S PDR

