

January 22, 2010

LICENSEE: Arizona Public Service Company
FACILITY: Palo Verde Nuclear Generating Station, Units 1, 2, and 3
SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALL HELD ON
JANUARY 14, 2010, BETWEEN THE U.S. NUCLEAR REGULATORY
COMMISSION AND ARIZONA PUBLIC SERVICE COMPANY,
CONCERNING DRAFT REQUEST FOR ADDITIONAL INFORMATION
PERTAINING TO THE PALO VERDE NUCLEAR GENERATING
STATION, UNITS 1, 2, AND 3, LICENSE RENEWAL APPLICATION

The U.S. Nuclear Regulatory Commission (the staff) and representatives of Arizona Public Service Company (the applicant) held a telephone conference call on January 14, 2010, to discuss and clarify the staff's draft request for additional information (RAI) concerning the Palo Verde Nuclear Generating Station, Units 1, 2, and 3, license renewal application. The telephone conference call was useful in clarifying the intent of the staff's draft RAI.

Enclosure 1 provides a listing of the participants and Enclosure 2 contains a listing of the draft questions discussed with the applicant, including a brief description on the status of the items.

The applicant had an opportunity to comment on this summary.

/RA/

Lisa M. Regner, Sr. Project Manager
Projects Branch 2
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket Nos. 50-528, 50-529, and 50-530

Enclosures:
As stated

cc w/encls: See next page

January 22, 2010

LICENSEE: Arizona Public Service Company
FACILITY: Palo Verde Nuclear Generating Station, Units 1, 2, and 3
SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALL HELD ON
JANUARY 14, 2010, BETWEEN THE U.S. NUCLEAR REGULATORY
COMMISSION AND ARIZONA PUBLIC SERVICE COMPANY,
CONCERNING DRAFT REQUEST FOR ADDITIONAL INFORMATION
PERTAINING TO THE PALO VERDE NUCLEAR GENERATING
STATION, UNITS 1, 2, AND 3, LICENSE RENEWAL APPLICATION

The U.S. Nuclear Regulatory Commission (the staff) and representatives of Arizona Public Service Company (the applicant) held a telephone conference call on January 14, 2010, to discuss and clarify the staff's draft request for additional information (RAI) concerning the Palo Verde Nuclear Generating Station, Units 1, 2, and 3, license renewal application. The telephone conference call was useful in clarifying the intent of the staff's draft RAI.

Enclosure 1 provides a listing of the participants and Enclosure 2 contains a listing of the draft questions discussed with the applicant, including a brief description on the status of the items.

The applicant had an opportunity to comment on this summary.

/RA/

Lisa M. Regner, Sr. Project Manager
Projects Branch 2
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket Nos. 50-528, 50-529, and 50-530

Enclosures:
As stated

cc w/encls: See next page

DISTRIBUTION: See next page

ADAMS Accession No. **ML100141784**

OFFICE	LA:DLR	PM:RPB2:DLR	BC:RPB2:DLR	PM:RPB2:DLR
NAME	SFiguroa	LRegner	DWrona	LRegner
DATE	01/19/10	01/20/10	01/22/10	01/22/10

OFFICIAL RECORD COPY

Memo to Arizona Public Service Company from Lisa M. Regner dated January, 22, 2010

SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALL HELD ON
JANUARY 14, 2010, BETWEEN THE U.S. NUCLEAR REGULATORY
COMMISSION AND ARIZONA PUBLIC SERVICE COMPANY,
CONCERNING DRAFT REQUEST FOR ADDITIONAL INFORMATION
PERTAINING TO THE PALO VERDE NUCLEAR GENERATING
STATION, UNITS 1, 2, AND 3, LICENSE RENEWAL APPLICATION

DISTRIBUTION:

HARD COPY:

DLR RF

E-MAIL:

PUBLIC

RidsNrrDlr Resource
RidsNrrDlrRpb1 Resource
RidsNrrDlrRpb2 Resource
RidsNrrDlrRarb Resource
RidsNrrDlrRasb Resource
RidsNrrDlrRapb Resource
RidsNrrDlrRpob Resource
RidsNrrDciCvib Resource
RidsNrrDciCpnb Resource
RidsNrrDciCsgb Resource
RidsNrrDraAfpb Resource
RidsNrrDraApla Resource
RidsNrrDeEmcb Resource
RidsNrrDeEeeb Resource
RidsNrrDssSrxb Resource
RidsNrrDssSbpb Resource
RidsNrrDssScvb Resource
RidsOgcMailCenter Resource
RidsOpaMail Resource

L. Regner
D. Drucker
R. Hall
B. Mizuno, OGC
R. Treadway, RIV
G. Pick, RIV

**TELEPHONE CONFERENCE CALL
PALO VERDE NUCLEAR GENERATING STATION, UNITS 1, 2, AND 3
LICENSE RENEWAL APPLICATION**

**LIST OF PARTICIPANTS
JANUARY 14, 2010**

PARTICIPANTS

Lisa Regner
Albert Wong
Todd Mintz
Roman Kazban
Angela Krainik
Glenn Michael
Neal Schneider
Donald Stevens
Nicholas Gawel
Al Saunders

AFFILIATIONS

U.S. Nuclear Regulatory Commission (NRC)
NRC
Center for Nuclear Waste Regulatory Analyses (CNWRA)
CNWRA
Arizona Public Service Company (APS)
APS
Strategic Teaming and Resource Sharing (STARS) Alliance
STARS
STARS
STARS

**TELEPHONE CONFERENCE CALL CONCERNING
DRAFT REQUEST FOR ADDITIONAL INFORMATION
PALO VERDE NUCLEAR GENERATING STATION, UNITS 1, 2, AND 3
LICENSE RENEWAL APPLICATION**

JANUARY 14, 2010

The U.S. Nuclear Regulatory Commission (the staff) and representatives of Arizona Public Service Company (the applicant) held a telephone conference call on January 14, 2010, to discuss and clarify the following draft request for additional information (RAI) concerning the Palo Verde Nuclear Generating Station, Units 1, 2, and 3, license renewal application (LRA).

DRAFT RAI 3.1.2-1

Background

The Generic Aging Lessons Learned (GALL) Report, Section X.M1 recommends the Metal Fatigue of Reactor Coolant Pressure Boundary Aging Management Program (AMP) for managing the aging of selected reactor coolant system components.

Issue

In the LRA, Section 3.1.2.2.1, the applicant states that the pressurizer relief tank is not an ASME Section III Class 1 component, nor is it designated to other fatigue or cycle design rules, and therefore has no fatigue time-limited aging analysis (TLAA). However, the GALL Report, Section IV, Subsection C2, item IV.C2-23 states that a time-limited aging analysis is needed to evaluate metal fatigue of the pressurizer relief tank for the period of extended operation.

Request

Provide additional information how metal fatigue of the pressurizer relief tank will be evaluated and managed for the period of extended operation.

DRAFT RAI 3.2.2-1

Background

The GALL Report, Table V.C, item V.C-4, indicates that stainless steel containment isolation piping and component internal surfaces exposed to treated water are subject to loss of material/pitting and crevice corrosion as an aging effect/mechanism. The GALL Report states that the aging effect/mechanism can be managed by the Water Chemistry and One-time Inspection Programs. The GALL Report further states that a further evaluation should be conducted on these components.

Issue

Section 3.2.2.2.8 of the LRA indicates that the further evaluation associated with this component is not applicable because the containment isolation components were "evaluated in the systems in which the components were found to have the function of containment integrity." Staff is unclear why the applicant indicates that this further evaluation for steel containment isolation piping is not applicable.

ENCLOSURE 2

Request

Provide additional information what is meant by the containment isolation components were evaluated in the system in which the components were found to have the function of containment integrity. In addition, if a further evaluation is conducted for these components in a different system, provide the location of the further evaluation. If further evaluations were not conducted for these components, provide additional justification.

DRAFT RAI 3.3.2-1

Background

The GALL Report, Table VIII, item VIII.A-5 is for copper piping exposed to treated water in the steam turbine system. The GALL Report suggests the use of the Water Chemistry Program augmented with the One-Time Inspection Program to manage loss of material and selective leaching in this system. However, the GALL Report in Table VII, item VII.C2-7 is for copper piping (Zinc > 15 percent) exposed to treated water in the Closed-Cycle Cooling Water System. The GALL Report suggests that loss of material and selective leaching for this component and system be managed by the Selective Leaching of Materials Program. One of the main differences between these two programs as described in the GALL Report is that hardness measurements are incorporated into the Selective Leaching of Materials Program, not in the Water Chemistry Program.

Issue

Table 3.3.2-4 of the LRA indicates that a copper alloy (Zinc > 15 percent) piping exposed to demineralized water is consistent with GALL Report item VIII.A-5. However, LRA Table 3.3.2-4 is a closed-cycle cooling water system. As such it seems that the GALL Report item VII.C2-7 may be more appropriate for this material. It is not clear to the staff how the Water Chemistry Program augmented with the One-Time Inspection Program is sufficient to manage the loss of material for the LRA closed-cycle cooling water component since these programs do not require hardness testing.

Request

Provide additional explanation on how the Water Chemistry Program (B2.1.2) and the One-Time Inspection (B2.1.16) will address the aging effect for loss of material for the copper alloy piping exposed to demineralized water in a Closed-Cycle Cooling Water System.

Discussion: The applicant indicated that all questions are clear. These draft questions will be sent in a formal RAI.

Palo Verde Nuclear Generating Station,
Units 1, 2, and 3

cc:

Mr. Steve Olea
Arizona Corporation Commission
1200 W. Washington Street
Phoenix, AZ 85007

Mr. Douglas Kent Porter, Senior Counsel
Southern California Edison Company
Law Department, Generation Resources
P.O. Box 800
Rosemead, CA 91770

Senior Resident Inspector
U.S. Nuclear Regulatory Commission
P.O. Box 40
Buckeye, AZ 85326

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
612 E. Lamar Blvd., Suite 400
Arlington, TX 76011-4125

Chairman
Maricopa County Board of Supervisors
301 W. Jefferson, 10th Floor
Phoenix, AZ 85003

Mr. Aubrey V. Godwin, Director
Arizona Radiation Regulatory Agency
4814 S. 40th Street
Phoenix, AZ 85040

Mr. Scott Bauer, Director
Regulatory Affairs
Palo Verde Nuclear Generating Station
Mail Station 7636
P.O. Box 52034
Phoenix, AZ 85072-2034

Mr. Dwight C. Mims, Vice President
Regulatory Affairs and Plant Improvement
Palo Verde Nuclear Generating Station
Mail Station 7605
P.O. Box 52034
Phoenix, AZ 85072-2034

Mr. John C. Taylor, Director, Nuclear
Generation
El Paso Electric Company
340 E. Palm Lane, Suite 310
Phoenix, AZ 85004

Mr. James Ray
Public Service Company of New Mexico
2401 Aztec NE, MS Z110
Albuquerque, NM 87107-4224

Mr. Geoffrey M. Cook
Southern California Edison Company
5000 Pacific Coast Highway, Bldg. D21
San Clemente, CA 92672

Mr. Robert Henry
Salt River Project
6504 E. Thomas Road
Scottsdale, AZ 85251

Mr. Jeffrey T. Weikert
Assistant General Counsel
El Paso Electric Company
Mail Location 167
123 W. Mills
El Paso, TX 79901

Mr. Eric Tharp
Los Angeles Department of Water & Power
Southern California Public Power Authority
P.O. Box 51111, Room 1255-C
Los Angeles, CA 90051-0100

Mr. Brian Almon
Public Utility Commission
William B. Travis Building
P.O. Box 13326
1701 N. Congress Avenue
Austin, TX 78701-3326

Mr. Randall K. Edington
Executive Vice President
Nuclear/CNO
Arizona Public Service Company
P.O. Box 52034, Mail Station 7602
Phoenix, AZ 85072-2034