



January 6, 2010

L-2010-002
10 CFR 50.36

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C. 20555

Re: St. Lucie Unit 1
Docket No: 50-335
Date of Event: December 8, 2009
Technical Specification Special Report
Wide Range Containment Sump Level System

This Special Report is being submitted pursuant to the requirements of St. Lucie Unit 1 Technical Specification 3.3.3.8, Table 3.3-11 Action 5, and Technical Specification 6.9.2. In accordance with the limiting condition for operation (LCO), if the number of OPERABLE Channels are less than the Minimum Channels OPERABLE, either restore the inoperable channel(s) to OPERABLE status within 48 hours, if repairs are feasible without shutting down, or initiate an alternate method of monitoring the reactor vessel inventory and submit a Special Report pursuant to Specification 6.9.2. This report is administrative in nature in that it provides only notification that the plant Wide Range Containment Sump Level System (LIS-07-13A) was administratively removed from service for greater than 72 hours during planned maintenance activities of the 1A emergency diesel generator (EDG.) The reactor vessel level monitoring system (RVLMS) was used during this period to provide system monitoring. LIS-07-13A had no instrumentation issues and returned to service upon completion of the 1A EDG maintenance window.

Please contact us if there any questions on this information.

Sincerely,

A handwritten signature in black ink, appearing to read 'Eric S. Katzman', written over a horizontal line.

Eric S. Katzman
Licensing Manager
St. Lucie Plant

ESK/DLC

A001