

March 12, 2010

LICENSEE: Arizona Public Service Company
FACILITY: Palo Verde Nuclear Generating Station, Units 1, 2, and 3
SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALL HELD ON
JANUARY 8, 2010, BETWEEN THE U.S. NUCLEAR REGULATORY
COMMISSION AND ARIZONA PUBLIC SERVICE COMPANY, CONCERNING
CONTAINMENT COATINGS PERTAINING TO THE PALO VERDE NUCLEAR
GENERATING STATION, UNITS 1, 2, AND 3, LICENSE RENEWAL
APPLICATION (TAC NOS. ME0254, ME0255, AND ME0256)

The U.S. Nuclear Regulatory Commission (NRC) staff and representatives of Arizona Public Service Company (APS) held a telephone conference call on January 8, 2010, to discuss the applicant's September 10, 2009, response to the NRC's request for additional information (RAI) dated August 11, 2009. This response concerned proper maintenance of the protective coatings inside containment for the period of extended operation for the Palo Verde Nuclear Generating Station, Units 1, 2, and 3, license renewal application.

The telephone conference call was useful in clarifying the need for coating inspections, as described in the applicant's responses to Generic Letter 2004-02 (dated February 28 and March 13, 2009), to continue into the period of extended operation.

APS representatives stated that they would submit a letter to the NRC with a commitment to incorporate into the Updated Final Safety Analysis Report (UFSAR), in the next update required by 10 CFR 50.71(e), a requirement to assess the containment building interior coating system in accordance with the PVNGS Containment Coatings Condition Assessment procedure every operating cycle. This requirement was described in a letter to the NRC dated March 13, 2009. This has the effect of continuing the coating assessments into the period of extended operation.

Angela Krainik, of APS staff, stated that the submittal of this letter was to be on or before April 30, 2010. Enclosed is a listing of the participants. The applicant had an opportunity to comment on this summary.

/RA/

Lisa M. Regner, Sr. Project Manager
Projects Branch 2
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket Nos. 50-528, 50-529, and 50-530

Enclosure:
As stated

cc w/encl: See next page

March 12, 2010

LICENSEE: Arizona Public Service Company

FACILITY: Palo Verde Nuclear Generating Station, Units 1, 2, and 3

SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALL HELD ON JANUARY 8, 2010, BETWEEN THE U.S. NUCLEAR REGULATORY COMMISSION AND ARIZONA PUBLIC SERVICE COMPANY, CONCERNING CONTAINMENT COATINGS PERTAINING TO THE PALO VERDE NUCLEAR GENERATING STATION, UNITS 1, 2, AND 3, LICENSE RENEWAL APPLICATION (TAC NOS. ME0254, ME0255, AND ME0256)

The U.S. Nuclear Regulatory Commission (NRC) staff and representatives of Arizona Public Service Company (APS or the applicant) held a telephone conference call on January 8, 2010, to discuss the applicant's September 10, 2009, response to the NRC's request for additional information (RAI) dated August 11, 2009. This response concerned proper maintenance of the protective coatings inside containment for the period of extended operation for the Palo Verde Nuclear Generating Station, Units 1, 2, and 3, license renewal application.

The telephone conference call was useful in clarifying the need for coating inspections, as described in the applicant's responses to Generic Letter 2004-02 (dated February 28 and March 13, 2009), to continue into the period of extended operation.

APS representatives stated that they would submit a letter to the NRC with a commitment to incorporate into the Updated Final Safety Analysis Report (UFSAR), in the next update required by 10 CFR 50.71(e), a requirement to assess the containment building interior coating system in accordance with the PVNGS Containment Coatings Condition Assessment procedure every operating cycle. This requirement was described in a letter to the NRC dated March 13, 2009. This has the effect of continuing the coating assessments into the period of extended operation.

Angela Krainik, of APS staff, stated that the submittal of this letter was to be on or before April 30, 2010. Enclosed is a listing of the participants. The applicant had an opportunity to comment on this summary.

/RA/

Lisa M. Regner, Sr. Project Manager
Projects Branch 2
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket Nos. 50-528, 50-529, and 50-530

Enclosure:

As stated

cc w/encl: See next page

DISTRIBUTION:

See next page

ADAMS Accession No.: **ML10010618**

OFFICE	LA:RPOB:DLR	PM:RPB2:DLR	BC:RPB2:DLR	PM:RPB2:DLR
NAME	SFiguroa	LRegner	DWrona	LRegner (Signature)
DATE	03/8/10	03/9/10	03/9/10	03/12/10

OFFICIAL RECORD COPY

Memorandum to Arizona Public Service Company from Lisa M. Regner dated March 12, 2010

SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALL HELD ON
JANUARY 8, 2010, BETWEEN THE U.S. NUCLEAR REGULATORY
COMMISSION AND ARIZONA PUBLIC SERVICE COMPANY, CONCERNING
CONTAINMENT COATINGS PERTAINING TO THE PALO VERDE NUCLEAR
GENERATING STATION, UNITS 1, 2, AND 3, LICENSE RENEWAL
APPLICATION (TAC NOS. ME0254, ME0255, AND ME0256)

DISTRIBUTION:

HARD COPY:

DLR RF

E-MAIL:

PUBLIC

RidsNrrDlr Resource

RidsNrrDlrRpb1 Resource

RidsNrrDlrRpb2 Resource

RidsNrrDlrRer1 Resource

RidsNrrDlrRer2 Resource

RidsNrrDlrRerb Resource

RidsNrrDlrRpob Resource

RidsNrrDciCvib Resource

RidsNrrDciCpnb Resource

RidsNrrDciCsgb Resource

RidsNrrDraAfpb Resource

RidsNrrDraApla Resource

RidsNrrDeEmcb Resource

RidsNrrDeEeeb Resource

RidsNrrDssSrxb Resource

RidsNrrDssSbpb Resource

RidsNrrDssScvb Resource

RidsOgcMailCenter Resource

RidsOpaMail

L. Regner

B. Mizuno

R. Treadway, RIV

G. Pick, RIV

**TELEPHONE CONFERENCE CALL
PALO VERDE NUCLEAR GENERATING STATION, UNITS 1, 2, AND 3
LICENSE RENEWAL APPLICATION**

**LIST OF PARTICIPANTS
January 8, 2009**

PARTICIPANTS

Lisa Regner
Andrew Johnson
Angela Krainik
Glenn Michael
Eric Blocher

AFFILIATIONS

U.S. Nuclear Regulatory Commission (NRC)
NRC
Arizona Public Service Company (APS)
APS
Strategic Teaming and Resource Sharing (STARS) Alliance

ENCLOSURE

Palo Verde Nuclear Generating Station,
Units 1, 2, and 3

cc:

Mr. Steve Olea
Arizona Corporation Commission
1200 W. Washington Street
Phoenix, AZ 85007

Mr. Douglas Kent Porter, Senior Counsel
Southern California Edison Company
Law Department, Generation Resources
P.O. Box 800
Rosemead, CA 91770

Senior Resident Inspector
U.S. Nuclear Regulatory Commission
P.O. Box 40
Buckeye, AZ 85326

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
612 E. Lamar Blvd., Suite 400
Arlington, TX 76011-4125

Chairman
Maricopa County Board of Supervisors
301 W. Jefferson, 10th Floor
Phoenix, AZ 85003

Mr. Aubrey V. Godwin, Director
Arizona Radiation Regulatory Agency
4814 S. 40th Street
Phoenix, AZ 85040

Mr. Ron Barnes, Director
Regulatory Affairs
Palo Verde Nuclear Generating Station
Mail Station 7636
P.O. Box 52034
Phoenix, AZ 85072-2034

Mr. Dwight C. Mims, Vice President
Regulatory Affairs and Plant Improvement
Palo Verde Nuclear Generating Station
Mail Station 7605
P.O. Box 52034
Phoenix, AZ 85072-2034

Mr. John C. Taylor, Director, Nuclear
Generation
El Paso Electric Company
340 E. Palm Lane, Suite 310
Phoenix, AZ 85004

Mr. James Ray
Public Service Company of New Mexico
2401 Aztec NE, MS Z110
Albuquerque, NM 87107-4224

Mr. Geoffrey M. Cook
Southern California Edison Company
5000 Pacific Coast Highway, Bldg. D21
San Clemente, CA 92672

Mr. Robert Henry
Salt River Project
6504 E. Thomas Road
Scottsdale, AZ 85251

Mr. Jeffrey T. Weikert
Assistant General Counsel
El Paso Electric Company
Mail Location 167
123 W. Mills
El Paso, TX 79901

Mr. Eric Tharp
Los Angeles Department of Water & Power
Southern California Public Power Authority
P.O. Box 51111, Room 1255-C
Los Angeles, CA 90051-0100

Mr. Brian Almon
Public Utility Commission
William B. Travis Building
P.O. Box 13326
1701 N. Congress Avenue
Austin, TX 78701-3326

Mr. Randall K. Edington
Executive Vice President
Nuclear/CNO
Arizona Public Service Company
P.O. Box 52034, Mail Station 7602
Phoenix, AZ 85072-2034