

STATE OF NEW YORK  
PUBLIC SERVICE COMMISSION

Case #27869:

Consolidated Edison Co.  
Indian Point #2 Outage

Testimony of  
WALTER L. FLEISHER

WESTCHESTER PEOPLES ACTION COALITION  
255 Grove Street  
White Plains, N.Y.

April 17, 1980

8105210526

WALTER L. FLEISHER

1 Q. Please give your name and address.

2 A. Walter L. Fleisher, I reside at 443 Buena Vista  
3 Road, New City, N.Y. 10956.

4 Q. For whom are you appearing?

5 A. I am appearing as a witness for Westchester Peoples  
6 Action Coalition.

7 Q. What is the scope of your testimony?

8 A. My testimony will cover the type of containment  
9 building cooling system installed; the materials  
10 selected for the fan cooling units (FCU); the design  
11 and workmanship of the FCU's and the associated ex-  
12 ternal piping, the revised cooling coils and piping  
13 and the design and installation of the containment  
14 bulding sump pumps.

15 Q. First will you list your work experience related to  
16 your testimony.

17 A. I present a two page document entitled "Appendix A  
18 Walter L. Fleisher Resumé, dated March, 1980."

19 Q. Is there anything you wish to add to the resumé?

20 A. Yes, the resumé is general. I would like to stress  
21 my extensive involvement with piping and cooling  
22 systems and particularly with systems handling  
23 brackish water.

24 My earliest recollection is from 1934 about a  
25 project for Beechnut Packing Co. in the Bush Ter-

1        minal building in Brooklyn. The project included  
2        the installation of three centrifugal water vapor  
3        refrigeration machines. The condensers were pro-  
4        vided with Brooklyn well water, which, due to over-  
5        pumping, was brackish. The condenser tubes lasted  
6        six months.

7        Q. Any other projects?

8        A. Yes, a job for Schaeffer Brewing Company at Kent  
9        Avenue, Brooklyn, replacing a stainless steel river  
10       water line that perforated in less than a year; work  
11       at Indian Point's former neighbor Standard Brands'  
12       river water cooling system; and finally, six years  
13       experience at Columbia University's Nevis Laboratory  
14       at Irvington, N.Y., with their primary Hudson River  
15       water cooling system, and the secondary high purity  
16       system used to cool the cyclotron components and  
17       the primary and secondary beam line magnets.

18       Q. What is your opinion of introducing river water  
19       inside the containment building?

20       A. From my experience with the extremely corrosive pro-  
21       perties of brackish water, and the ensuing impossi-  
22       bility of maintaining the integrity of the piping  
23       system for an extended period of time; and the dan-  
24       gerous and destructive results of the brackish water  
25       coming in contact with the reactor vessel, compo-

utter  
1 nents and electrical systems, it was/folly to intro-  
2 duce the river water into the containment building.  
3 Without question there should have been a primary/  
4 secondary system with complete isolation of the water  
5 inside the containment building.

6 Q. Is there another reason why brackish water should  
7 not be used in the FCU's?

8 A. Yes. Water that is exposed to ionizing radiation,  
9 which is the case inside the containment building,  
10 decomposes into hydrogen gas and a hydrogen peroxide  
11 radical. The hydrogen peroxide radical is extremely  
12 active and will cause extensive corrosion in a short  
13 period of time.

14 The only effective measure against the hydrogen  
15 peroxide problem is to use deaerated and deionized  
16 water with a specific resistance of better than 1.2  
17 megohm centimeters. Even with this precaution copper  
18 and copper based alloys are not recommended. Thus  
19 the cupro-nickel tubing used as a protection against  
20 the brackish water is the least desirable material  
21 in the presence of ionizing radiation.

22 Q. Accepting the fact that the river water was introduced  
23 into the containment building, what are your observa-  
24 tions on the design and construction of the circula-  
25 ting piping and the FCU's?

WALTER L. FLEISHER

1 A. The piping is fabricated from cement lined steel  
2 pipe with arc welded joints. While cement lined  
3 pipe is a good material for the river water, the  
4 welded joints are not. For the cement lining to be  
5 effective it must be continuous without any breaks  
6 or imperfections. This is impossible with a butt  
7 weld joint. There is no way to get a perfect fit-up  
8 and the welding process will cause some damage to  
9 the lining.

10 The weld metal also is susceptible to corrosion  
11 due to the difference in composition, chemical inclu-  
12 sions and imperfections in the weld. The proof of  
13 the faults of the welded joints is in the leaks  
14 that developed, and an inspection of some sectioned  
15 joints which showed gaps in the lining of up to  $\frac{1}{4}$   
16 of an inch, and severe pitting of the welds.

17 To provide reasonable corrosion resistance,  
18 joints must be made by mechanical means, such as  
19 flanged joints with carefully finished cement lin-  
20 ing and gaskets that will prevent any contact be-  
21 tween the water and the base metal.

22 Q. What about the FCU's?

23 A. The cooling coils were fabricated from a cupro-  
24 nickel alloy with what appeared to be silver-con-  
25 taining brazing alloy. As explained above, the

1 cupro-nickel is not a good material in the pre-  
2 sence of ionizing radiation. I have not been pro-  
3 vided with the radiation type or level at the tubes,  
4 but was not permitted to inspect the center section  
5 of the removed coils because of the radiation danger.

6 The design of the coils is what I would charac-  
7 terize as low grade commercial. Except for the ma-  
8 terial the construction and workmanship is what I  
9 might expect on a competitive air-conditioning job.  
10 The tube stubs were inserted into a drilled hole in  
11 the headers, not always perpendicular, and extended  
12 into the the header random amounts. This makes for  
13 a poor fit-up and a source of erosion corrosion.

14 The stubs were swaged to receive the coil tubes.  
15 The fit of the swages was not good and the brazing  
16 was horrible with globs of brazing alloy instead of  
17 a neat fillet. The use of the stubs is unnecessary  
18 and doubles the number of joints and potential leaks.

19 There was no galvanic isolation between the  
20 coils and the steel pipe, and there was no type  
21 of cathodic protection.

22 Even the coil casings were made from galvanized  
23 steel, which was severely corroded, and in direct  
24 contact with the tubes where the tubes pressed  
25 through the casings, providing another likely source

WALTER L. FLEISHER

1 for corrosion and perforation of the tubes.

2 Q. How do the replacement coils differ from the  
3 original coils?

4 A. The new coils are provided with a water box with a  
5 flanged head and the tubes are rolled into the tube  
6 sheet, eliminating the stubs and all brazed joints  
7 and provide a smooth transition from the water box  
8 to the tubes. The coil casings appear to be of  
9 austenitic stainless steel.

10 The changes are a tacit admission of the short-  
11 comings of the original design. While the new con-  
12 struction is an improvement, it will not cure the  
13 problem of the radiation induced corrosion.

14 Q. Have there been any changes in the piping?

15 A. No. The fabrication and materials appear to be  
16 the same although the workmanship appears appreci-  
17 ably improved. However, the corrosion at the  
18 welded joints is bound to recur.

19 Q. Is any of the information used in your testimony  
20 on corrosion novel or proprietary?

21 A. No. The problem is in handling sea water or  
22 brackish water for which engineering solutions  
23 have a long history, certainly dating back to  
24 World War II days, the early 1940's.

25 As for radiation induced problems, the answer

WALTER L. FLEISHER

1 was certainly recognized in the treatment of the  
2 reactor feed water in this and other nuclear ge-  
3 ner ating plants.

4 Q. What is your opinion of the containment building  
5 sump pump installation?

6 A. The installation ignored the fundamentals for an  
7 essential piece of equipment located in an inac-  
8 cessible location. First, there was no way of  
9 determining if it was functioning. Second, there  
10 was no way of operating it remotely. Third, there  
11 was no way of checking the performance remotely.  
12 Fourth, the pump float control is primitive. Fifth,  
13 the add on of another motor, after the branch fuses,  
14 is inexcusable.

15 Q. What would be the minimum requirements for an in-  
16 stallation of this type?

17 A. There should be a power-available indicator, a pump  
18 running indicator, flow indicators both electrical  
19 and mechanically visual, and a displacer type level  
20 control designed to fail-safe, and two independent  
21 level indicators using different methods of detec-  
22 tion.

23 It would not be unreasonable to provide two or  
24 more independent sumps and pumps considering the  
25 size of the building and the possibility of a cata-

WALTER L. FLEISHER

1       strophic accident at one location.

2   Q.   Are there any other obvious omissions?

3   A.   I cannot imagine how level indicators and pumps  
4       were not provided for the reactor vessel pit. The  
5       critical nature of submersion of the reactor vessel  
6       in cold water could not reasonably be ignored. A  
7       late patch job is not going to be satisfactory  
8       considering the high operating temperature and high  
9       levels of radiation.

10  Q.   Does that conclude your testimony?

11  A.   Yes.

APPENDIX A

WALTER L. FLEISHER  
443 Buena Vista Road  
New City, N.Y. 10956

Resumé

March, 1980

Resident of New City since 1923

Professional background:

- 1934-1936 Cornell University, Ithaca, N.Y.  
Sibley School of Mechanical Engineering
- 1936-1938 Polytechnic Institute of Brooklyn (N.Y.)  
School of Mechanical Engineering
- 1938-1946 Air & Refrigeration Corp., New York, N.Y.  
Atlanta, Ga. Branch and Plant Manager  
Design, manufacture and installation of  
industrial ventilation equipment and  
systems.  
Customers: U.S. Rubber Co.; Fisher Body  
Division of General Motors; Defense  
Plant Corp., synthetic rubber plants;  
Oak Ridge National Laboratory, uranium  
separation; and many others.
- 1945-1946 On leave for service in the United States  
Navy, Aircraft Electronics Technician Mate
- 1946-1951 Mance Corp., New York, N.Y.  
Project Engineer primarily for design/build  
projects for Alexander Stores; J.P. Morgan  
and Co.; National Biscuit Co.; Schaeffer  
Brewing Co.; E. R. Squibb & Co.; Sperry  
Gyroscope, etc., mostly industrial HVAC  
and special process work.
- 1951-1955 James H. Merritt Corp., New York, N.Y.  
Chief Engineer of Air Conditioning Div. and  
Chief Engineer of Environmental Test Equip-  
ment division. HVAC IBM first Watson Re-  
search Lab; altitude simulator and ex-  
plosive decompression chambers for U.S.  
Air Force; altitude test chambers (100,000  
feet altitudes and -100°F) for Arma Corp;  
Mergenthaler; General Electric; RCA;  
Fairchild; etc.
- 1955-1968 Rowland Tompkins Corp., Hawthorne, N.Y.  
Chief Engineer Air Conditioning Division  
Design/build and plan and specification  
projects for: Grumman Aircraft including  
Lunar Module engineering building, hangar  
building, simulator and computer center.  
Union Carbide (4) laboratory building and  
central power plant; laboratories for

- North American Phillips, Stauffer Chemical, Boeing-Vertol Div; industrial plants for IBM, Avon Products, Anaconda Copper.
- 1968-1972 Self-employed as a mechanical consultant. Major project, mechanical coordinator of \$30,000,000 research center for Union Carbide Corp., including office, specialized labs (Linde Div.), general laboratories, shops, central power plant, site utilities, and special services such as liquid nitrogen, liquid oxygen and hydrogen gas.
- 1972-1978 Columbia University, Nevis Cyclotron Laboratory, Irvington, N.Y.  
Senior Engineer in charge of design and installation of primary and secondary high purity cooling water system for the cyclotron; beam lines and beam stop. Design of central extraction components; radio frequency power system; vacuum system; designed and built two computer rooms; design and installation of CO<sub>2</sub> and Halon fire protection system; and multi building fire alarm system.
- 1978- Segner and Dalton Consulting Engineers P.C. Valhalla, New York.  
Senior Engineer. Design of HVAC and various process services for Resource Recovery plants at Brockton, MA and Bridgeport, CT. Energy conservation Study and Implementation Plan for three major laboratories for Mass. Institute of Technology. Also projects for General Foods, Stauffer Chemical (3), and State University At Purchase.
- 1945- Member American Society of Heating, Refrigeration and Air Conditioning Engineers.