



UNITED STATES
ATOMIC ENERGY COMMISSION
DIVISION OF COMPLIANCE
REGION I
970 BROAD STREET
NEWARK, NEW JERSEY 07102

REG files

201 645-3942

December 10, 1969

J. P. O'Reilly, Chief, Reactor Inspection and Enforcement Branch,
Division of Compliance, HQ

CONSOLIDATED EDISON COMPANY (INDIAN POINT 2)
DOCKET NO. 50-247

The attached report of inspection visits to the Con Ed engineering offices on November 3, 1969 and to the site on November 5-7, 1969 is forwarded for information.

Wedco has assumed managerial control of construction activities at the site. Our observations to date have not identified any resultant adverse effects on the quality of construction. We will continue to monitor this area closely.

Con Ed has completed the investigation into the previously reported pipe deficiency allegations. A final report has been issued and is currently under review by CO.

The licensee has raised some questions pertaining to the interpretation of the "Table A" NDT requirements. This matter was subsequently discussed by Con Ed in a meeting with DRL held on November 21, 1969. Early results of Con Ed's review in this area revealed a number of valve discs that will require radiography.

Con Ed and Westinghouse are continuing their investigation of the deficiencies identified previously regarding the eight check valves in the safety injection system. It appears that these components will also be encompassed by the "Table A" review.

Progress on the preparation of preoperational test procedures has been slow. Con Ed has been alerted to our concern and indicated that action is being taken in this regard. We will go to higher management if this proves unsatisfactory.

Our Quality Control task force inspection of this facility was initiated on December 5, 1969, and is scheduled to be completed on December 16, 1969. Included will be the items questioned in the electrical area in this and previous reports. The result of this effort will be documented in the report of the subject inspection.

8111030005 691210
PDR ADOCK 05000247
G PDR

R.T. Carlson
R. T. Carlson
Senior Reactor Inspector

Enclosure:
CO Report No. 247/69-11
by G. L. Madsen dtd 12/3/69

cc: E. G. Case, DRS
R. S. Boyd, DRL (2)
S. Levine, DRL (6)
D. J. Skovholt, DRL (3)
L. Kornblith, Jr., CO
Regional Directors, CO
REG files