



UNITED STATES  
ATOMIC ENERGY COMMISSION

WASHINGTON, D.C. 20545

JAN 20 1971

R. C. DeYoung, Assistant Director for Pressurized Water Reactors, DRL (2)

CONSOLIDATED EDISON COMPANY - INDIAN POINT 2, CO REPORT NO. 247/70-12

The enclosed report of a special meeting with licensee and Westinghouse personnel on December 2, 1970, is forwarded for your information. The purpose of this meeting was to discuss our review of the details of the preoperational and startup testing program for Indian Point 2.

Since the December 2, 1970, meeting, the licensee informed our Region I (Newark) office that they do not plan to conduct additional testing of the safety injection system and the control rod drive system, or to conduct a meaningful loss of A.C. power test. The licensee also stated that only minor improvement would be made to the hot functional testing program. It is our view, based on the information made available to CO, that the proposed testing does not meet the licensee's commitments as described in Section 13 of the Final Safety Analysis Report.

We discussed the above issues with cognizant members of your staff on January 12, 1971. It is our understanding that you concur in our position. As a result, we are currently conducting additional discussions with the licensee. We will inform you of developments.

A handwritten signature in dark ink, appearing to read "R. H. Engelken", is positioned above the typed name.

R. H. Engelken, Assistant Director  
for Inspection and Enforcement  
Division of Compliance

Enclosure:  
CO Report No. 247/70-12

cc w/enclosure:  
E. G. Case, DRS (3)  
P. A. Morris, DRL  
R. S. Boyd, DRL (2)  
D. J. Skovholt, DRL (3)  
P. W. Howe, DRL (2)  
A. Giambusso, CO  
L. Kornblith, Jr., CO  
Regional Directors, CO  
✓ REG Files  
N. C. Moseley, CO:I

811111038 710120  
PDR ADOCK 05000247  
Q PDR