



UNITED STATES
ATOMIC ENERGY COMMISSION
DIVISION OF COMPLIANCE
REGION I
970 BROAD STREET
NEWARK, NEW JERSEY 07102

201 645- 3941

AUG 20 1970

J. P. O'Reilly, Chief, Reactor Inspection and
Enforcement Branch, CO:HQ

CONSOLIDATED EDISON COMPANY (INDIAN POINT 2)
DOCKET NO. 50-247

The attached report of inspections at the subject facility on June 26, 29, July 8 and 9, 1970 is forwarded for information. No items of nonconformance and no safety problems were identified.

The inspector witnessed portions of the hydrostatic test on June 29, 1970. No deficiencies were noted.

A review by Con Ed of the redundancy of safeguards and protection cabling revealed that for containment pressure instrumentation, all transmitters were in one rack without separation, the cables were routed to a common terminal box, and some of the cables were adjacent in the control room area. Additional reviews are being made by Con Ed of redundant instrumentation.

A number of previously identified problems are resolved in the report.

Norman C. Moseley
Norman C. Moseley
Senior Reactor Inspector

Enclosure:
CO Report No. 247/70-7
by G. L. Madsen
dated 8/6/70

cc: E. G. Case, DRS (3)
P. A. Morris, DRL
R. S. Boyd, DRL (2)
R. C. DeYoung, DRL (2)
D. J. Skovholt, DRL (3)
P. W. Howe, DRL (2)
L. Kornblith, Jr., CO
Regional Directors, CO
REG Files ✓

8111120585 700820
PDR ADOCK 05000247
Q PDR