

**Bellefonte Nuclear Plant, Units 3 & 4  
COL Application  
Part 2, FSAR**

CHAPTER 4

REACTOR

TABLE OF CONTENTS

<u>Section</u>	<u>Title</u>	<u>Page</u>
4.1	SUMMARY DESCRIPTION.....	4.1-1
4.2	FUEL SYSTEM DESIGN.....	4.2-1
4.3	NUCLEAR DESIGN.....	4.3-1
4.4	THERMAL AND HYDRAULIC DESIGN .....	4.4-1
4.4.7	COMBINED LICENSE INFORMATION.....	4.4-1
4.5	REACTOR MATERIALS.....	4.5-1
4.6	FUNCTIONAL DESIGN OF REACTIVITY CONTROL SYSTEMS.....	4.6-1

**Bellefonte Nuclear Plant, Units 3 & 4  
COL Application  
Part 2, FSAR**

**CHAPTER 4**

**REACTOR**

4.1 SUMMARY DESCRIPTION

This **section** of the referenced DCD is incorporated by reference with no departures or supplements.

**Bellefonte Nuclear Plant, Units 3 & 4  
COL Application  
Part 2, FSAR**

4.2 FUEL SYSTEM DESIGN

This **section** of the referenced DCD is incorporated by reference with no departures or supplements.

**Bellefonte Nuclear Plant, Units 3 & 4  
COL Application  
Part 2, FSAR**

4.3 NUCLEAR DESIGN

This **section** of the referenced DCD is incorporated by reference with no departures or supplements.

**Bellefonte Nuclear Plant, Units 3 & 4**  
**COL Application**  
**Part 2, FSAR**

4.4 THERMAL AND HYDRAULIC DESIGN

This **section** of the referenced DCD is incorporated by reference with the following departures and/or supplements.

4.4.7 COMBINED LICENSE INFORMATION

---

Replace the second paragraph in DCD Subsection 4.4.7 with the following:

STD COL 4.4-2 Following selection of the actual plant operating instrumentation and calculation of the instrumentation uncertainties of the operating plant parameters as discussed in **DCD Subsection 7.1.6**, the design limit DNBR values will be calculated. The calculations will be completed using the RTDP with these instrumentation uncertainties and confirm that either the design limit DNBR values as described in **DCD Section 4.4** remain valid or that the safety analysis minimum DNBR bounds the new design limit DNBR values plus DNBR penalties, such as rod bow penalty. This will be completed prior to fuel load.

---

**Bellefonte Nuclear Plant, Units 3 & 4**  
**COL Application**  
**Part 2, FSAR**

4.5 REACTOR MATERIALS

This **section** of the referenced DCD is incorporated by reference with no departures or supplements.

**Bellefonte Nuclear Plant, Units 3 & 4**  
**COL Application**  
**Part 2, FSAR**

4.6 FUNCTIONAL DESIGN OF REACTIVITY CONTROL SYSTEMS

This **section** of the referenced DCD is incorporated by reference with no departures or supplements.