

JUN 19 1973

Consolidated Edison Company of New York, Inc. Docket No. 50-2#7
Attention: Mr. W. W. Lapsley
Executive Vice-President
Central Operations

4 Irving Place
New York, New York 10003

This refers to the inspection conducted by Mr. Meyer of this office on May 3 and 4, 1973, at Indian Point 2 of activities authorized by AEC License No. DPR-26 and to the discussions of our findings held by Mr. Meyer with Mr. Coulch and other members of your staff at the conclusion of the inspection, and to subsequent telephone discussions between Mr. Meyer and Mr. Koppe on May 18 and 30, 1973, and Mr. Meyer and Mr. Van Wyck on May 17 and 30, 1973.

Areas examined during this inspection are described in the Regulatory Operations Inspection Report which is enclosed with this letter. Within these areas, the inspection consisted of selective examinations of procedures and representative records, interviews with plant personnel, and observations by the inspector.

Within the scope of this inspection, no violations or safety items were observed.

In accordance with Section 2.790 of the AEC's "Rules of Practice," Part 2, Title 10, Code of Federal Regulations, a copy of this letter and the enclosed inspection report will be placed in the AEC's Public Document Room. If this report contains any information that you (or your contractor) believe to be proprietary, it is necessary that you make a written application within 20 days to this office to withhold such information from public disclosure. Any such application must include a full statement of the reasons on the basis of which it is claimed that the information is proprietary, and should be prepared so that proprietary information identified in the application is contained in a separate part of the document. If we do not hear from you in this regard within the specified period, the report will be placed in the Public Document Room.

CRESS-I

Meyer/mh Nelson Brunner O'Reilly

6/1/73

8111040056 730619
PDR ADOCK 05000247
G PDR

It is our understanding, based on the referenced discussions, that testing, evaluation, and installation of equipment will be accomplished, as noted below:

1. Tank volumes, pump flow, and flow meter calibration will be verified prior to release of liquid waste from the liquid radwaste system.
2. A system to continuously sample for iodine in the plant vent will be installed and operable by August 1, 1973.
3. The short radii bends in the plant vent particulate sampling line will be eliminated to minimize line losses. This is to be completed by September 1, 1973.
4. The capability to provide an isokinetic sample in the plant vent particulate sampling and monitoring system will be verified and documented. Additionally, line loss determinations will be made. These matters will be examined during a subsequent inspection.

Should you have any questions concerning this inspection, we will be pleased to discuss them with you.

Sincerely,

Paul R. Nelson, Chief
Radiological & Environmental
Protection Branch

Enclosure:

1. RO Inspection Report No. 50-247/73-10

cc: W. W. Cobean, Manager Nuclear Power Generation Department
Indian Point Station
Buchanan, N. Y.

A. Kohler, Indian Point Station Site Construction Manager

A. Upton
1821 Jefferson St., N.W.
Washington, D.C.

bcc: RO, Chief, Field Support & Enforcement Branch, HQ

RO:HQ (4)

Directorate of Licensing, HQ (4)

RO Directors

DR Central Files

GC

PDR

Local PDR

NSIC

TTC

State of New York

MEMO ROUTE SLIP Form AEC-93 (Rev. May 14, 1947) AECM 0240		See me about this. Note and return.	For concurrence. For signature.	For action. For information.
TO (Name and unit) H. D. Thornburg Chief, FS&EB		INITIALS	REMARKS RO INSPECTION REPORT NO. 50-247/73-10 CONSOLIDATED EDISON COMPANY INDIAN POINT NO. 2	
		DATE	The subject inspection report is forwarded for your	
TO (Name and unit) cc: RO:HQ (5) DR Central Files Reg Standards (3) Licensing (13) RO Regional Directors		INITIALS	REMARKS information. Distribution will be made by this office	
		DATE	to the PDR, LPDR, NSIC, DTIE and State representatives	
			after review by the licensee for proprietary informa-	
TO (Name and unit)		INITIALS	REMARKS tion.	
		DATE		
FROM (Name and unit) <i>P. R. Nelson</i> P. R. Nelson RO:I		REMARKS		
PHONE NO. X-3941	DATE 6/7/73			

USE OTHER SIDE FOR ADDITIONAL REMARKS

GPO : 1971 O - 445-469

Rg