

*DR Central files*

APR 23 1973

Consolidated Edison Company of New York  
Attention: Mr. W. W. Lapsley,  
Executive Vice President  
Central Operations  
4 Irving Place  
New York, New York

Docket No. 50-247

Gentlemen:

This refers to the inspection conducted by Mr. Rebelowski of this office on March 16, 22, 26, and 27, 1973 of activities authorized by AEC License No. DPR-26 and to the discussions of our findings held by Mr. Rebelowski with Mr. Makepeace of your staff at the conclusion of the inspection, and to a subsequent telephone discussion with Mr. Makepeace on April 2, 1973.

Areas examined during this inspection included: reactor coolant system hydrostatic testing; testing of the main steam safety valves; testing of control rods; and a review of your surveillance testing records. Within these areas, the inspection consisted of selective examinations of procedures and representative records, interviews with personnel, and observations by the inspector.

Within the scope of the inspection, no violations or safety items were observed.

In accordance with Section 2.790 of the AEC's "Rules of Practice," Part 2, Title 10, Code of Federal Regulations, a copy of this letter and the enclosed inspection report will be placed in the AEC's Public Document Room. If this report contains any information that you (or your contractor) believe to be proprietary, it is necessary that you make a written application within 20 days to this office to withhold such information from public disclosure. Any such application must include a full statement of the reasons on the basis of which it is claimed that the information is proprietary, and should be prepared so that proprietary information identified in the application is contained in a separate part of the document. If we do not hear from you in this regard within the specified period, the report will be placed in the Public Document Room.

CRESS I

Rebelowski:dw Brunner:dw  
4-16-73

8111040186 730417  
PDR ADOCK 05000247  
Q PDR

*Insp*

Should you have any questions concerning this inspection, we will be pleased to discuss them with you.

Sincerely,

Eldon J. Brunner, Chief  
Facility Test & Startup Branch

Enclosure:  
RO Inspection Report No. 50-247/73-07

cc: Mr. W. R. Cobean, Manager  
Nuclear Power Generation Department

Mr. A. Kohler, Site Construction  
Manager

Mr. A. E. Upton, Attorney-at-Law

bcc: RO Chief, Reactor Construction Branch, HQ  
RO Chief, Reactor Test & Operations Branch, HQ  
RO:HQ (4)  
Directorate of Licensing, HQ (4)  
RO Directors  
DR Central Files  
GC  
PDR  
Local PDR  
NSIC  
TIC  
State of New York