


D R Central File



UNITED STATES
ATOMIC ENERGY COMMISSION
DIVISION OF COMPLIANCE
REGION I
870 BROAD STREET
NEWARK, NEW JERSEY 07102

201 645 3942

MAR 15 1972

Consolidated Edison Company
Attention: Mr. W. W. Lapsley
Executive Vice President
Control Operations
4 Irving Place
New York, New York 10003

Docket No. 50-247

Gentlemen:

This refers to the inspection conducted by Mr. G. L. Madsen of this office on February 14, 17 and 18, 1972 of activities authorized by AEC License Nos. CPPR-21 and DPR-26 and to the discussions of our findings held by Mr. Madsen with Messrs. Makepeace and Kohler of your staff at the conclusion of the inspection.

Areas examined during this inspection included test programs relating to the November 4, 1971 fire; the subcritical test program; the power ascension program; the pipe hanger and restraint installation; the construction relating to plant security; the electrical separation barrier and fire stop installation; the Nuclear Facility Safety Committee minutes for the period of November 5, 1971 to January 21, 1972; the proposed safety injection system modification; and the resolution of previously identified unresolved items. Within these areas, the inspection consisted of selective examination of procedures and representative records; interviews with plant personnel, and observations by our inspector.

During the inspection, it was found that one of your activities was in non-compliance with the requirements of your Technical Specifications. The item and reference to the pertinent requirement are listed in the enclosure to this letter.

No reply to this letter is required in that the item of noncompliance listed in the enclosure was reported to this office on February 17, 1972 and a written report on this matter was submitted to the Director, Division of Reactor Licensing, on February 28, 1972.

811110965 720320
PDR ADOCK 05000247
E PDR

Should you have any questions concerning this inspection, we will be pleased to discuss them with you.

Very truly yours,

James P. O'Reilly
Director

Enclosure:
Description of Noncompliance Item

cc: Mr. W. R. Cobean
Mr. A. Kohler
Mr. A. E. Upton
bcc: L. Kornblith, CO
R. H. Engelken, CO
P. A. Morris, DRL
J. G. Keppler, CO
J. B. Henderson, CO
CO Files
DR Central Files. ✓
PDR
Local PDR
NSIC
T. Laughlin, DTIE