

CO INQUIRY REPORT NO. 50-247/72-07

CONSOLIDATED EDISON COMPANY
BUCHANAN, NEW YORK
INDIAN POINT 2
LICENSE NO. DPR-26
DOCKET NO. 50-247
PRIMARY SYSTEM - PRESSURE SURGE

Prepared by: Glen L. Madsen
Glen L. Madsen, Reactor Inspector

3/10/72
Date

A. Date and Manner AEC was Informed:

On March 9, 1972, a telephone call was received from Mr. A. Nespoli, Superintendent Operation at IP-2, informing CO:I that a primary system pressure to 630 psig was encountered at about 6:05 p.m. on March 8, 1972.

B. Description of Particular Event or Circumstance

The primary system was at 115° F, and 400 psig. The primary system letdown flow was increased and a primary pump was started. The licensee reports that the primary pressure increased to 630 psig. The letdown flow was increased and the pressure spike was terminated in about one minute.

C. Action by Licensee:

The licensee reports no apparent damage to systems or components. Investigations are being conducted by the licensee to determine a means of preventing similiar transients.

The licensee will submit a 10 day report to DRL on this matter.

8111110998 720310
PDR ADOCK 05000247
Q PDR