



UNITED STATES  
ATOMIC ENERGY COMMISSION  
DIVISION OF COMPLIANCE  
REGION I  
970 BROAD STREET  
NEWARK, NEW JERSEY 07102

201 645-3942

FEB 7 1972

James G. Keppler, Chief, Reactor Testing and Operations Branch,  
Division of Compliance, HQ

CONSOLIDATED EDISON COMPANY  
INDIAN POINT NO. 2  
CO INSPECTION REPORT NO. 50-247/72-02

The subject report is forwarded for information.

The items of concern to our consultant Arnold A. Weintraub relating to fire prevention and protection were well received by the licensee. Some of the items had already been corrected, and some items are under consideration by the licensee.

The test program, relating to the fire damage, is basically a check-out of the components affected by the fire. Con Ed plans to include the performance of most of the operational surveillance and preventive maintenance tests prior to going critical. The licensee's test program appears to be conservative and realistic.

In our letter to the licensee we have requested a written response to establish his schedule for the submittal to DRL of two reports on steam generator repair. These reports have not been received and were discussed in previous letters to the licensee.

*Eldon J. Brunner*  
Eldon J. Brunner  
Senior Reactor Inspector

Enclosure:  
Subject Inspection Report

cc: E. G. Case, DRS (3)  
R. S. Boyd, DRL (2)  
R. C. DeYoung, DRL (2)  
D. J. Skovholt, DRL (3)  
H. R. Denton, DRL (2)  
L. Kornblith, CO  
R. H. Engelken, CO  
J. B. Henderson, CO  
Regional Directors, CO  
CO Files  
DR Central Files ✓



8111120031 720207  
PDR ADOCK 05000247  
PDR  
Q