



UNITED STATES
ATOMIC ENERGY COMMISSION
DIVISION OF COMPLIANCE
REGION I
970 BROAD STREET
NEWARK, NEW JERSEY 07102

201 645.3942

OCT 14 1971

James G. Keppler, Chief, Reactor Testing and
Operations Branch, Division of Compliance, HQ

CO INQUIRY REPORT NO. 50-247/71-04
CONSOLIDATED EDISON COMPANY
INDIAN POINT 2
STEAM GENERATORS - ULTRASONIC FINDINGS

The subject inquiry report is forwarded for information.

We propose to review this matter in more detail during a future inspection. The objectives of our review will be to determine if the licensee's evaluation of this subject has been appropriately handled, if the steam generator is acceptable for use, and if there is a potential generic problem relating to in-service base line UT data. The condition is believed to be related to a failure to properly interpret and record data during the performance of base line data. Hence the real point of discussion is the credibility of base line data for this plant and perhaps other plants.

Eldon J. Brunner
Eldon J. Brunner
Senior Reactor Inspector

CO:I:GLM

Enclosure:

CO Inquiry Report No. 50-247/71-04 (Orig & 1 cy)

cc: E. G. Case, DRS (3)
R. S. Boyd, DRL (2)
R. C. DeYoung, DRL (2)
D. J. Skovholt, DRL (3)
H. R. Denton, DRS (2)
A. Giambusso, CO
L. Kornblith, CO
R. Engelken, CO
J. B. Henderson, CO
Regional Directors, CO (4)
DR Central Files ✓

U.S. Atomic Energy Comm.
Division of Compliance
Region I
Newark, New Jersey

1971 OCT 18 AM 10 29

RECEIVED

8111120449 711014
PDR ADDCK 05000247
Q PDR