

William J. Cahill, Jr.
Vice President

Consolidated Edison Company of New York, Inc.
4 Irving Place, New York, N Y 10003
Telephone (212) 460-3819

April 30, 1975

Mr. Eldon J. Brunner, Chief
Reactor Operations Branch
Nuclear Regulatory Commission
Region 1
631 Park Avenue
King of Prussia, Pennsylvania 19406

Dear Mr. Brunner:

This refers to your letter of April 10, 1975 concerning the inspection of our Unit No. 2 facility conducted by your office during the period March 10-14, 1975.

With regard to item No. 2 of the enclosure to your letter, Procedure PT-M20, "Auxiliary Component Cooling Pump Test", has been revised to specifically identify the system environmental conditions which must exist during conduct of the test. Moreover, as an outgrowth of your Inspector's inquiry into this matter, station personnel re-examined the basic procedural method used, with the determination that certain changes thereto would enable use of the manufacturer's pump performance curves as acceptance criteria. These changes have been incorporated in the aforementioned procedure and the piping change referenced in the inspection report (detail 5e) is no longer planned.

With respect to item No. 3, the subject voltmeter was checked for proper calibration subsequent to your Inspector's visit and the results were satisfactory. In addition, it is now included in our program which provides for such checks to be performed on a regular basis.

811240352 750513
PDR ADDCK 05000247
G PDR

I trust you will find the foregoing information satisfies your requirements. However, should you have any questions or require additional information, please do not hesitate to contact me.

Very truly yours,



William J. Cahill, Jr.
Vice President