

William J. Cahill, Jr.
Vice President

Consolidated Edison Company of New York, Inc.
4 Irving Place, New York, N Y 10003
Telephone (212) 460-3819

April 28, 1977

Indian Point Station

Docket Nos. 50-247
50-286

Mr. Eldon J. Brunner, Chief
Reactor Operations and Nuclear Support Branch
U. S. Nuclear Regulatory Commission, Region I
631 Park Avenue
King of Prussia, Pennsylvania 19406

Dear Mr. Brunner,

This refers to inspection Nos. 50-247/77-05 and 50-286/77-06, conducted by your Mr. D. Johnson on February 24 and 25, 1977 of activities authorized by NRC License Nos. DPR-26 and DPR-64 at our Indian Point Station. Your March 10, 1977 letter requested a supplemental response to our February 10, 1977 letter addressing the management controls we intend to employ to maintain a current and documented system lineup for safety related systems listed in Regulatory Guide 1.33.

Our administrative procedures will be revised to require that Operations shift personnel identify safety related system lineup changes that deviate from normal positions which, without an awareness of same on the part of other shift personnel, could possibly result in an adverse affect on equipment operability. The documentation of these lineup changes will be accomplished using special status boards located in the Control Room and at applicable field operator work locations. The Control Room status board will include a summary of the information contained on the field operator status boards and will thereby provide the shift supervisor with information as to these off-normal lineups. These administrative procedure changes will also require the review of applicable status boards by on-coming shift personnel.

It is expected that our administrative procedures will be revised and this system of off-normal lineup identification will be in effect by July 15, 1977.

8111240557 770512
PDR ADOCK 05000047
Q PDR

Mr. Eldon J. Brunner

- 2 -

These administrative changes will provide increased assurance that Operations staff personnel are kept aware of overall plant status.

Very truly yours,



William J. Cahill, Jr.
Vice President