

Murray Selman
Vice President

Consolidated Edison Company of New York, Inc.
Indian Point Station
Broadway & Bleakley Ave.
Buchanan, NY 10511
Telephone (914) 737-8116

May 30, 1985

Re: Indian Point Unit No. 2
Docket No. 50-247

Mr. Thomas T. Martin, Director
Division of Radiation Safety and Safeguards
U.S. Nuclear Regulatory Commission
Region I
631 Park Avenue
King of Prussia, Pa. 19406

Dear Mr. Martin:

This refers to I.E. Inspection 50-247/85-05 conducted by Mr. R. Struckmeyer of your office, on February 25 - March 1, 1985 of activities authorized by NRC License No. DPR-26 at Indian Point Unit No. 2. Your April 30, 1985 letter stated that it appeared that one of our activities was not conducted in full compliance with NRC requirements, as set forth in the Notice of Violation enclosed therewith as Appendix A. Our response to the Notice is presented in Attachment A to this letter.

Should you or your staff have any questions, please contact us.

Very truly yours,



cc: Senior Resident Inspector
U.S. Nuclear Regulatory Commission
P.O. Box 38
Buchanan, New York 10511

8506070126 850530
PDR ADOCK 05000247
G PDR

1/8
1E 06

ATTACHMENT A

Response To Notice of Violation, Appendix A

VIOLATION

Section 6.8.1 of the Unit 2 Technical Specifications states that written procedures and administrative policies shall be established, implemented and maintained covering the Offsite Dose Calculation Manual (ODCM) implementation.

Contrary to the above, no written procedures were established for performing the ODCM offsite dose calculations due to liquid and gaseous effluents.

This is a Severity Level IV violation (Supplement IV).

RESPONSE

The computer program utilized to perform the calculations required by the Offsite Dose Calculation Manual (ODCM) and referenced in the inspection report provides a reasonably effective means of addressing the procedural aspects of the calculation of offsite doses due to liquid and gaseous effluents. It is recognized, however, that no procedure exists to implement the calculations required should the computer become unavailable. Therefore, a procedure is under development to address this concern. This procedure is scheduled to be implemented by July 1, 1985.