

APPENDIX A

NOTICE OF VIOLATION

Consolidated Edison Company  
Indian Point Unit 2

Docket No. 50-247  
License No. DPR-26

As a result of the inspection conducted on April 1-30, 1986, and in accordance with the revised NRC Enforcement Policy (10CFR 2, Appendix C), published in the Federal Register on March 8, 1984 (49 FR 8583), the following violation was identified:

- A. Technical Specification 6.9.1.3 requires that the Annual Radiation Exposure Report be submitted no later than March 1 of each year. Technical Specification 3.13.A.3 requires that a telephone notification be made to Region I within 24 hours of identifying that the fire protection system is inoperable.

Contrary to the above, in April 1986, the inspector identified the following:

- (a) The Annual Radiation Exposure Report was submitted on March 31, 1986.
- (b) The fire protection system became inoperable on March 28, 1986, but the telephone notification to Region I was not made until March 31, 1986.

This is a Severity Level V Violation (Supplement 1).

Pursuant to the provisions of 10 CFR 2.201, Consolidated Edison Company of New York, Inc., is hereby required to submit to this office within thirty days of the date of the letter which transmitted this Notice, a written statement or explanation in reply, including: (1) the corrective steps which have been taken and the results achieved; (2) corrective steps which will be taken to avoid further violations; and (3) the date when full compliance will be achieved. Where good cause is shown, consideration will be given to extending the response time.

8605280035 860514  
PDR ADOCK 05000247  
Q PDR

OFFICIAL RECORD COPY

IR IP2 86-10 - 0003.0.0  
05/09/86