

APPENDIX A
NOTICE OF VIOLATION

Consolidated Edison Company of New York, Inc.
Indian Point Unit 2

Docket No. 50-247
License No. DPR-26

As a result of the inspection conducted on August 17-21, 1987, and in accordance with the "General Statement of Policy for NRC Enforcement Actions," 10 CFR 2, Appendix C (Enforcement Policy), the following violation was identified:

10 CFR 50.49 paragraphs (f) and (g) require that each item of electrical equipment important to safety be qualified and that qualification must be completed at a time no later than November 30, 1985.

1. Contrary to the above, on August 21, 1987, the inspector identified that the qualification documents used by the licensee to support the qualification of Raychem Model No. STICKY, SCL, TSC, and WCS cable splices do not contain sufficient evidence to demonstrate their qualification. The low insulation resistance during the test was not adequately addressed.
2. Contrary to the above, on August 20, 1987, the inspector identified three Raychem splices, in the Safety Injection pump room, which were installed over cable braiding on one end of each splice. Qualification for this type of installation was not established.

This is a Severity Level IV violation. (Supplement I)

Pursuant to the provisions of 10 CFR 2.201, Consolidated Edison Company of New York, Inc. is hereby required to submit to this office within thirty days of the date of the letter which transmitted this Notice, a written statement or explanation in reply, including: (1) the corrective steps which have been taken and the results achieved; (2) corrective steps which will be taken to avoid further violations; and (3) the date when full compliance will be achieved. Where good cause is shown, consideration will be given to extending this response time.

8711130213 871104
PDR ADOCK 05000247
Q PDR

OFFICIAL RECORD COPY

IR IP2 87-23 - 0003.0.0
11/03/87