

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

In the Matter of)
)
CONSOLIDATED EDISON COMPANY) Docket No. 50-247
OF NEW YORK, INC.)
(Indian Point Station,)
Unit No. 2))

APPLICATION FOR AMENDMENT
TO OPERATING LICENSE

Pursuant to Section 50.90 of the regulations of the Nuclear Regulatory Commission ("NRC"), Consolidated Edison Company of New York, Inc. ("Consolidated Edison"), as holder of Facility Operating License No. DPR-26, hereby applies for amendment of that license. Specifically, Consolidated Edison requests that the license be amended to increase the authorized operating limit of the river water temperature (Ultimate Heat Sink) from 85°F to 95°F and to allow unit operation at the higher river water temperature as well as with a maximum containment temperature of 130°F. Additionally, Consolidated Edison requests that Appendix A to the Facility Operating License Technical Specifications; Sections 3.3.F and 5.2.C; and Basis pages 3.3-10, 3.3-11, 3.3-14, 4.4-6 and Table 4.1-1 be amended accordingly.

The specific proposed Technical Specification revisions are set forth in Attachment A to this Application. A Safety Assessment of the proposed changes is set forth in the Attachment B to this Application. This assessment demonstrates that the proposed changes do not represent a significant hazards consideration as defined in 10 CFR 50.92(c).

As required by 10 CFR 50.91(b)(1), a copy of this application and our analysis concluding that the proposed changes do not constitute a significant hazards consideration have been sent to the appropriate New York State official designated to receive such amendments.

By: 

Stephen B. Bram
Vice President
Nuclear Power

Subscribed and sworn to
before me this 13th day
of July, 1989


Notary Public

KAREN L. LANCASTER
Notary Public, State of New York
No. 60-4843659
Qualified in Westchester County
Term Expires 9/30/89

8907180440 890713
PDR ADDCK 05000247
P PNU