

John D. O'Toole  
Vice President

Consolidated Edison Company of New York, Inc.  
4 Irving Place, New York, NY 10003  
Telephone (212) 460-2533

Letter No. 81-147  
September 4, 1981

Re: Indian Point Unit No. 2  
Docket No. 50-247

Director of Nuclear Reactor Regulation  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

ATTN: Mr. Steven A. Varga, Chief  
Operating Reactors Branch No. 1  
Division of Licensing



Dear Mr. Varga:

This letter is in response to your letter of May 21, 1981 regarding Environmental Qualification of Safety Related Electrical Equipment as modified by your letter of June 25, 1981. Our 90 day response to your Safety Evaluation is enclosed as Attachment 1. Your staff has approved extension of the response to this date.

With regard to my letters of April 13, 1981 and January 14, 1981, a tabulation of the Environmental Qualification data for Cold Shut-down Equipment is enclosed as Attachment 2. Your staff has approved submittal of this data coincident with our 90 day response.

Should you or your staff have any questions, please contact us.

Very truly yours,

*William P. Bennett* for  
John D. O'Toole

Attachments

8109250259 810704  
PDR ADOCK 05000247  
PDR

A048  
5/11  
LIMITED  
DISTRIBUTION

CONSOLIDATED EDISON COMPANY

OF NEW YORK

INDIAN POINT POWER STATION UNIT NO. 2

I. E. BULLETIN 79-01B SER RESPONSE

**— NOTICE —**

THE ATTACHED FILES ARE OFFICIAL RECORDS OF THE DIVISION OF DOCUMENT CONTROL. THEY HAVE BEEN CHARGED TO YOU FOR A LIMITED TIME PERIOD AND MUST BE RETURNED TO THE RECORDS FACILITY BRANCH 016. PLEASE DO NOT SEND DOCUMENTS CHARGED OUT THROUGH THE MAIL. REMOVAL OF ANY PAGE(S) FROM DOCUMENT FOR REPRODUCTION MUST BE REFERRED TO FILE PERSONNEL.

DEADLINE RETURN DATE **Docket # 50-247**  
**Control # 8109250259**  
**Date 9-04-81 of Document**  
**REGULATORY DOCKET FILE**

**REGULATORY DOCKET FILE COPY**

RECORDS FACILITY BRANCH

ATTACHMENT 1

Environmental Qualification  
90 Day Response to  
NRC Safety Evaluation for  
Safety-Related Electrical  
Equipment

Consolidated Edison Company of New York, Inc.  
Indian Point Unit No. 2  
Docket No. 50-247  
Facility Operating License No. DPR-26  
September, 1981

**REGULATORY DOCKET FILE COPY**

INDIAN POINT 2

Table of Contents

SER SECTION

3.1	Completeness of Safety Related Equipment
3.2	Service Conditions
3.3	Temperature, Pressure, and Humidity Conditions
3.4	Temperature, Pressure, and Humidity Conditions Outside Containment
3.5	Submergence
3.7	Aging
3.8	Radiation Inside Containment

Appendix A

Appendix B

Appendix C



INDIAN POINT 2

APPENDIX B

<u>(TAB)</u>	<u>TER ITEM</u>	<u>EQUIPMENT</u>
(1)	3	Limiterque MOV
(2)	15A, 16	Foxboro Transmitter
(3)	15D	Foxboro Transmitter
(4)	35	Westinghouse Electric Motor
(5)	36	Westinghouse Electric Motor
(6)	40A	GE/Raychem Cable/Splice
(7)	40B	Kerite/Raychem Cable/Splice
(8)	40D	Lewis Cable
(9)	41	Rosemount RTD
(10)	42A	Westinghouse CTL PNL Recombiner
(11)	8	GEMS Level Switch
(12)	9	Foxboro Transmitter
(13)	11A	Foxboro Transmitter
(14)	11B	Foxboro Transmitter
(15)	12	Foxboro Transmitter
(16)	14A	Foxboro Transmitter
(17)	14B	Foxboro Transmitter
(18)	15B, 15C	Foxboro Transmitter
(19)	10, 13	Foxboro Transmitter
(20)	18, 19, 21, 22A,B, C, 23, 24A,B, 25, 26	ASCO Solenoid Valves
(21)	20A, B 27	Laurence Solenoid Valve
(22)	28A, 30, 31A,B,C, 32A,b, 29A,B, 33	NAMCO Position Switches
(23)	34A	Westinghouse Motor
(24)	37A	Foxboro Transducer
(25)	38	Westinghouse Terminal Blocks
(26)	39	Crouse-Hinds Electrical Cable Penetrations
(27)	40C	GE/Raychem Cable/Splice
(28)	42B	Hydrogen Recombiner
(29)	--	Temperature

SER Section 3.1 Completeness of Safety-Related Equipment

Deficiency:

Several equipment items identified by FRC in the draft interim TER that may be subject to a harsh environment were not addressed by the licensee (RE: Paragraph 4.1.1 of the TER).

Response:

The items identified by the FRC in Section 4.1.1 of the TER are addressed in this SER response.

SER Section 3.2 Service Conditions

Deficiency:

Section 3.2 of the SER requires that the licensee verify that the containment spray system is not subjected to a disabling single component failure.

Response:

The licensee has verified that the containment spray system is not subjected to a disabling single component failure and therefore satisfies the DOR Guideline requirements of Section 4.2.1.

### SER Section 3.3 Temperature, Pressure and Humidity Conditions

#### Deficiency:

In this section of the SER, the Staff indicated that the licensee's service condition of 258°F does not satisfy the requirements for the minimum temperature profile. Furthermore, the Staff indicated that the licensee's specified pressure is low compared to plants of similar design.

#### Response:

The correct peak pressure is 40.6 psig. The peak temperature reported is the saturation temperature at the steam partial pressure of 36.9 psi. According to the SER, the peak temperature reported should be the saturation temperature corresponding to the total containment pressure to account for margin. The saturation temperature at 55.3 psia is 287°F.

NUREG-0588 Appendix A states that topical report WCAP-8312A is an acceptable method for calculating the mass and energy releases to the containment assuming a LOCA. This WCAP was followed in the Indian Point 2 analysis that resulted in the peak pressure and temperature reported above. The model for heat transfer to the containment heat sinks used in the analysis is in agreement with Appendix B.1 of NUREG-0588.

The references and assumptions can be found in WCAP-8312A (non-proprietary) or WCAP 8264 (Proprietary) for the mass and energy release analysis and in WCAP-7155 for the containment pressure transient analysis.

The equipment summary tables have been updated to reflect this change in specified qualification temperature. Individual equipment reviews have been conducted to ensure that equipment meets the new staff requirement for containment temperature. Justifications have been provided where necessary.

## Section 3.4 Temperature, Pressure and Humidity Conditions

### Outside Containment

#### Deficiency:

The licensee has used ambient temperature conditions in some areas outside containment. The Staff considers saturation temperature at the peak pressure resulting from a HELB as the minimum level for acceptance. The licensee should update his summary tables to reflect this change.

#### Response:

The HELB environments outside containment were addressed in Appendix B of the May 1980 submittal. The following additional information addressing saturation temperatures for peak pressures is provided as requested.

#### Aux. Feed Pump Room Accident Conditions

Maximum Pressure:	0.9 psig
Saturation Temperature:	215°F
Humidity:	100%
Radiation:	Negligible
Chemical Spray:	None
Submergence:	None

#### Main Feed and Steam Area

Maximum Pressure:	0.42 psig
Saturation Temperature:	213°F
Humidity:	100%
Radiation:	Negligible
Chemical Spray:	None
Submergence:	None

Reference: Analysis of High Energy Lines in letter from Trotsen to Giambusso dated May 14, 1973.

The equipment summary work sheets have been updated to reflect these changes. Justifications for interim operation are provided where necessary for the individual components in these areas.

Section 3.5 Submergence

Deficiency:

The maximum submergence levels have not been established and addressed by the licensee.

Response:

The licensee has established the maximum flood level to be at elevation 50 feet 1 inch inside containment. Containment floor elevation is 46 feet. The flood level is therefore 4 feet 1 inch above the containment floor.

Indian Point 2 has addressed the question of submergence outside containment as discussed in letters from Indian Point 2 to the NRC in December of 1972 and December of 1980.

Indian Point 2 has verified that no safety related electrical equipment is subject to submergence inside or outside containment.

### SER Section 3.7 Aging

The Indian Point 2 facility is in the process of gathering bills of materials from the manufacturers of the necessary components. Once these material lists are accumulated, a detailed comparison of the existing equipment to the materials identified in Appendix C of the DOR Guidelines and other sources will be conducted. Furthermore, in cases where the materials cannot be identified, operating experience and a literature search will be utilized to determine age related degradation. An ongoing program to review surveillance and maintenance records will be established to identify potential age related degradations. Component maintenance and replacement schedules which include consideration of aging characteristics of the installed components will be developed in conjunction with the material evaluations. Appropriate margins will be incorporated in the replacement schedules.

The specific results of these studies and the details of the evaluation/replacement programs will be provided to the Staff as required.

### SER Section 3.8 Radiation Inside Containment

The integrated beta and gamma radiation doses calculated at the center of the Indian Point 2 containment building for periods of 30 days and 1 year following a design basis LOCA are summarized as follows:

	<u>Gamma Dose</u> <u>(Rad)</u>	<u>Beta Dose</u> <u>(Rad)</u>
30 days	$1.4 \times 10^7$	$1.4 \times 10^8$
1 year	$2 \times 10^7$	$2 \times 10^8$

This data is based on the dose information documented in NUREG-0588 Appendix D and the DOR Guidelines Appendix B. A conservative thirty day dose was derived by use of the nomograms given in the DOR Guidelines. This method was utilized by assuming a containment volume of  $2.6 \times 10^6$  ft<sup>3</sup> and a reactor power level of 2758 MW for Indian Point 2. The thirty day beta dose was obtained from the information given in Appendix D of NUREG-0588.

The one year beta and gamma doses were predicted by extrapolating the 30 day doses to one year. In order to perform this extrapolation, the information tabulated in Table D-5 and Table D-6 of NUREG-0588 was plotted in order to establish the shape of the curves representing beta and gamma doses with respect to time. These curves were then conservatively extrapolated to one year. The shape of the individual curves were then used to extrapolate the plant specific 30 day doses for beta and gamma radiation to one year. Beta dose to cables will be reduced by 50% as suggested by NUREG-0588.

The post accident operability times assumed for cables are 30 days for instruments and one year for power cables. Total integrated doses for cables are shown below.



Instrument cables - 30 days

$$\begin{array}{r} 0.7 \times 10^8 \beta \\ \underline{0.14 \times 10^8 \gamma} \\ 0.84 \times 10^8 \text{ total} \end{array}$$

Power cables - one year

$$\begin{array}{r} 1 \times 10^8 \beta \\ \underline{0.2 \times 10^8 \gamma} \\ 1.2 \times 10^8 \text{ total} \end{array}$$

Instruments and motors are either sufficiently shielded or have such a short post accident requirement that beta radiation exposure is negligible. A factor of 2.7 reduction in total gamma dose may be utilized for equipment outside the crane wall.

With regard to the integrated dose applicable to a contained accident, transport calculations were performed by Westinghouse for a reactor coolant pipe geometry which yield the following post LOCA dose.

	Gamma Dose <u>(Rad)</u>
1 Year	$1.7 \times 10^8$

In this case, beta doses are considered to be insignificant due to shielding afforded by pressure boundary structures.

APPENDIX A

Equipment Requiring Immediate  
Corrective Action

TER Items number 10 and 13 were incorrectly listed in the SER under Appendix A. These items should have appeared in Appendix B. Corrective action has been completed for both of these items as discussed in Appendix B.

APPENDIX B

Equipment Requiring Additional  
Information and/or Corrective Action

Component:

TER Item #: 3

Device: Limitorque MOV

Model: SMB-00 with Class B Motor Insulation

Function: Actuates RHR Loop Flow Control Valves (HVC-638, 640) and RH Exchanger CW Supply Valves (MOV 822 A&B)

Location: Inside Containment

Deficiency:

OM, A, OT

Interim Justification:

The referenced test reports indicate proper valve operation for a period of 8 hours during accident conditions. This valve is not normally used during an accident. However if adjustment for flow is required it will be accomplished immediately following switchover to recirculation. No subsequent failures can cause the valve to change position. Indian Point 2 will verify that the installed valve and motor are similar to the one tested.

Final Resolution:

Due to the limited qualification time for this MOV, it will be replaced at the next outage of sufficient duration.

FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION	OUTSTAND.
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.	METHOD	ITEMS
SYSTEM: RH Exchanger CW Supply I.D. NO.: MOV-822B COMPONENT: Valve Actuator  MANUFACTURER: Limatorque  MODEL NO.: SMB-00 B-Insulation  FUNCTION: Positioning Valve  ACCURACY: (% OF SPAN) SPEC: N/A DEMON:  SERVICE: RH Exchanger CW Supply Valve Control LOCATION: Inside Containment	OPERATING TIME	8 Hrs.	8 Hrs.	--	3, 4	Type Test Simultaneous	note 2
	TEMPERATURE (°F) note 2	287	287	1	3, 4	Type Test Simultaneous	N/A
	PRESSURE (PSIG) note 2	40	60	1	3, 4	Type Test Simultaneous	N/A
	RELATIVE HUMIDITY (%)	100	100	1	3, 4	Type Test Simultaneous	N/A
	CHEMICAL SPRAY	Note 1	Note 2	1	3, 4	Type Test Simultaneous	N/A
	RADIATION (rads)	$1.54 \times 10^8$	$2 \times 10^8$	2	3, 4	Type Test Separate	N/A
	AGING (yrs)	40	--	N/A	--	--	--
	ABOVE FLOOD LEVEL: YES X NO	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A

NOTES:

- 2000 PPM boric acid spray with 40% NaOH to result in 10.0 ph
- Equipment committed for replacement.

REFERENCES:

- FSAR section 14.3
- IE Bulletin 70-01B, Attachment 4, Section 4.1.2
- Limatorque test report B0003.
- WCAP-7410L

FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION	OUTSTAND.
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.	METHOD	ITEMS
SYSTEM: RH Exchanger CW Supply I.D. NO.: MOV-822A COMPONENT: Valve Actuator MANUFACTURER: Limitorque MODEL NO.: SMB-00 FUNCTION: B Insulation Positioning Valve ACCURACY: (% OF SPAN) SPEC: N/A DEMON: SERVICE: RH Exchanger CW Supply Valve Control LOCATION: Inside Containment ABOVE FLOOD LEVEL: YES X NO	OPERATING TIME	8 Hrs.	8 Hrs.	--	3, 4	Type Test Simultaneous	Note 2
	TEMPERATURE (°F) note 2	287	287	1	3, 4	Type Test Simultaneous	N/A
	PRESSURE (PSIG) note 2	40	60	1	3, 4	Type Test Simultaneous	N/A
	RELATIVE HUMIDITY (%)	100	100	1	3, 4	Type Test Simultaneous	N/A
	CHEMICAL SPRAY	Note 1	Note 2	1	3, 4	Type Test Simultaneous	N/A
	RADIATION (rads)	$1.5 \times 10^8$	$2 \times 10^8$	2	3, 4	Type Test Separate	N/A
	AGING (yrs)	40	--	--	--	--	--
	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A	N/A

NOTES:

- 2000 PPM boric acid spray with 40% NaOH to result in 10.0 ph
- Equipment committed for replacement.

REFERENCES:

- FSAR section 14.3
- IE Bulletin 79-01B, Attachment 4, Section 4.3.1.2
- Limitorque test report B0003.
- WCAP-7410L

FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION	OUTSTAND.
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.	METHOD	ITEMS
SYSTEM: RH Loop Flow Control I.D. NO.: MOV-640 COMPONENT: Valve Actuator MANUFACTURER: Limatorque MODEL NO.: SMB-30 B Insulation FUNCTION: Positioning Valve ACCURACY: (% OF SPAN) SPEC: N/A DEMON: SERVICE: RH Loop Flow Valve Control LOCATION: Inside Containment	OPERATING TIME	8 hrs.	8 Hrs.	--	3,4	Type Test Simultaneous	Note 2
	TEMPERATURE (°F)	287	287	1	3,4	Type Test Simultaneous	N/A
	PRESSURE (PSIG)	40	60	1	3,4	Type Test Simultaneous	N/A
	RELATIVE HUMIDITY (%)	100	100	1	3,4	Type Test Simultaneous	N/A
	CHEMICAL SPRAY	Note 1	Note 2	1	3,4	Type Test Simultaneous	N/A
	RADIATION (rads)	$1.54 \times 10^8$	$2 \times 10^8$	2	3,4	Type Test Separate	N/A
	AGING (yrs)	40	--	N/A	--	--	--
	ABOVE FLOOD LEVEL: YES X NO	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A

NOTES:

- 2000 PPM boric acid spray with 40% NaOH to result in 10.0 ph.
- Equipment committed for replacement.

REFERENCES:

- FSAR Section 14.3.
- IE Bulletin 79-01B, Attachment 4, Section 4.1.2.
- Limatorque test report B0003.
- WCAP-7410L.

FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION	OUTSTAND.
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.	METHOD	ITEMS
SYSTEM: RH Loop Flow Control I.D. NO.: COMPONENT: MOV-638 Valve Actuator MANUFACTURER: Limitorque MODEL NO.: SMB-00 B-Insulator FUNCTION: Positioning Valve ACCURACY: (% OF SPAN) SPEC: N/A DEMON: SERVICE: RH Loop Flow Valve Control LOCATION: Inside Containment	OPERATING TIME	8 Hrs.	8 HRS.	--	3, 4	Type Test Simultaneous	Note 2
	TEMPERATURE (°F)	287	287	1	3, 4	Type Test Simultaneous	N/A
	PRESSURE (PSIG)	40	60	1	3, 4	Type Test Simultaneous	N/A
	RELATIVE HUMIDITY (%)	100	100	1	3, 4	Type Test Simultaneous	N/A
	CHEMICAL SPRAY	Note 1	Note 2	1	3, 4	Type Test Simultaneous	N/A
	RADIATION (rads)	$1.5 \times 10^8$	$2 \times 10^8$	2	3, 4	Type Test Separate	N/A
	AGING (yrs)	40	--	N/A	--	--	--
	ABOVE FLOOD LEVEL: YES X NO	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A

NOTES:

- 2000 PPM boric acid spray with 40% NaOH to result in 10.0 pH
- Equipment committed for replacement.

REFERENCES:

- FSAR Section 14.3
- IE Bulletin 79-01B, Attachment 4, Section 4.1.2
- Limitorque test report B0003
- WCAP-7410L.



Component:

TER Item #: 15A and 16

Device: Foxboro Transmitter

Model: 611GM

Function: Main Steam Pressure (PT-419A,B,C; PT-439A,B,C)

Location: Auxiliary Pump Room

Model: 613GM

Function: Main Feedwater Flow (FT-418A,B; 428A,B; 438A,B; 448A,B)

Location: Auxiliary Pump Room

Deficiency:

QM, A, QI

Interim Justification:

Indian Point 2 has established that these transmitters are 50 feet away from any potential pipe break and redundant transmitters would not be subjected to direct impingement during the short period of time required to isolate the break. Therefore, the units are not considered to be in a harsh environment and will perform as normal.

The Auxiliary Pump Room is protected by a temperature switch which actuates at 1350F to isolate the steam to the auxiliary feed pump. Once this switch actuates, the conditions in the room should quickly return to normal in case of an accident. The calculations performed showing 0.9 psig and a saturation temperature of 2150F assume that the temperature switch fails to operate and that the leak remains unisolated.

Even though this temperature switch is presently unqualified, it is felt that in the interim, its operation can be relied upon due to the low actuation temperature setpoint of 1350F. Assuming that this switch does operate in the event of a steam leak, the room conditions should not greatly exceed the 1350F setpoint.

Final Resolution:

The temperature switch relied upon in this accident will be qualified, replaced or modified to ensure its operation prior to June 30, 1982.

The licensee is also evaluating the effect on IE equipment of the temperature excursion expected in this area as a result of a steam line break. Additional action will be taken by the licensee based on the results of this study. It is anticipated that the results will confirm the belief that the rupture will be isolated by the temperature switch before the critical components of the IE devices become elevated to temperatures that will affect their operability.

157  
 FACILITY: Indian Point 2  
 DOCKET:

SYSTEM COMPONENT EVALUATION  
 WORK SHEET

ENCLOSURE  
 79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION	OUTSTAND.
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.	METHOD	ITEMS
SYSTEM: Main Steam I.D. NO.: PT-419A COMPONENT: Transmitter MANUFACTURER: Foxboro MODEL NO.: 11GM FUNCTION: Main Steam Pressure ACCURACY: (% OF SPAN) SPEC: +10% DEMON: -15% SERVICE: Pressure Transmitter LOCATION: Auxiliary Pump Room ABOVE FLOOD LEVEL: N/A YES NO	OPERATING TIME	5 Min.	N/A	---	--	N/A	N/A
	TEMPERATURE (°F)	135	N/A	1	--	N/A	N/A
	PRESSURE (PSIG)	0	N/A	1	--	N/A	N/A
	RELATIVE HUMIDITY (%)	100	Note 1	1	--	N/A	N/A
	CHEMICAL SPRAY	N/A	N/A	1	N/A	N/A	N/A
	RADIATION (rads)	N/A	N/A	1	N/A	N/A	N/A
	AGING (yrs)	40	--	N/A	--	--	--
	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A	N/A

NOTES:

1. A short excursion above ambient is considered to have a negligible effect.

REFERENCES:

1. Analysis of high energy lines in Letter Trosten to Giambusso of 5/14/73

FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION	OUTSTAND.
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.	METHOD	ITEMS
SYSTEM: Main Steam I.D. NO.: PT-419C COMPONENT: Transmitter MANUFACTURER: Foxboro MODEL NO.: 11-GM FUNCTION: Main Steam Pressure ACCURACY: (% OF SPAN) SPEC: +10% DEMON: -15% SERVICE: Pressure Transmitter LOCATION: Auxiliary Pump Room ABOVE FLOOD LEVEL: N/A YES NO	OPERATING TIME	5 Min.	N/A	--	--	N/A	N/A
	TEMPERATURE (°F)	135	N/A	1	--	N/A	N/A
	PRESSURE (PSIG)	0	N/A	1	--	N/A	N/A
	RELATIVE HUMIDITY (%)	100	Note 1	1	--	N/A	N/A
	CHEMICAL SPRAY	N/A	N/A	1	N/A	N/A	N/A
	RADIATION (rads)	N/A	N/A	1	N/A	N/A	N/A
	AGING (yrs)	40	--	N/A	--	--	--
	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A	N/A

NOTES:

1. A short excursion above ambient is considered to have a negligible effect.

REFERENCES:

1. Analysis of high energy lines in Letter Trosten to Giambusso of 5/14/73

FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION	OUTSTAND.
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.	METHOD	ITEMS
SYSTEM: Main Steam I.D. NO.: PT-419B COMPONENT: Transmitter MANUFACTURER: Foxboro MODEL NO.: 611 -GM FUNCTION: Main Steam Pressure ACCURACY: (% OF SPAN) SPEC: +10% DEMON: -15% SERVICE: Pressure Transmitter LOCATION: Auxiliary Pump Room ABOVE FLOOD LEVEL: N/A YES NO	OPERATING TIME	5 Min.	N/A	--	--	N/A	N/A
	TEMPERATURE (°F)	135	N/A	1	--	N/A	N/A
	PRESSURE (PSIG)	0	N/A	1	--	N/A	N/A
	RELATIVE HUMIDITY (%)	100	Note 1	1	--	N/A	N/A
	CHEMICAL SPRAY	N/A	N/A	1	N/A	N/A	N/A
	RADIATION (rads)	N/A	N/A	1	N/A	N/A	N/A
	AGING (yrs)	40	--	N/A	--	--	--
	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A	N/A

NOTES:

1. A short excursion above ambient is considered to have a negligible effect.

REFERENCES:

1. Analysis of high energy lines in Letter Trosten to Giambusso of 5/14/73

FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION	OUTSTAND.
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.	METHOD	ITEMS
SYSTEM: Main Steam	OPERATING TIME	5 Min.	N/A	--	--	N/A	N/A
I.D. NO.: PT-439A COMPONENT: Transmitter	TEMPERATURE (°F)	135	N/A	1	--	N/A	N/A
MANUFACTURER: Foxboro	PRESSURE (PSIG)	0	N/A	1	--	N/A	N/A
MODEL NO.: 11-GM	RELATIVE HUMIDITY (%)	100	Note 1	1	--	N/A	N/A
FUNCTION: Main Steam Pressure	CHEMICAL SPRAY	N/A	N/A	1	N/A	N/A	N/A
ACCURACY: (% OF SPAN) SPEC: +10% DEMON: -15%	RADIATION (rads)	N/A	N/A	1	N/A	N/A	N/A
SERVICE: Pressure Transmitter	AGING (yrs)	40	--	N/A	--	--	--
LOCATION: Auxiliary Pump Room	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A	N/A
ABOVE FLOOD LEVEL: N/A YES NO							

NOTES:

1. A short excursion above ambient is considered to have a negligible effect.

REFERENCES:

1. Analysis of high energy lines in letter Trosten to Giambusso of 5/14/73.

FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION	OUTSTAND.
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.	METHOD	ITEMS
SYSTEM: Main Steam	OPERATING TIME	5 Min.	N/A	--	--	N/A	N/A
I.D. NO.: PT-439B COMPONENT: Transmitter	TEMPERATURE (°F)	135	N/A	1	--	N/A	N/A
MANUFACTURER: Foxboro	PRESSURE (PSIG)	0	N/A	1	--	N/A	N/A
MODEL NO.: 11-GM	RELATIVE HUMIDITY (%)	100	Note 1	1	--	N/A	N/A
FUNCTION: Main Steam Pressure	CHEMICAL SPRAY	N/A	N/A	1	N/A	N/A	N/A
ACCURACY: (% OF SPAN) SPEC: +10% DEMON: -15%	RADIATION (rads)	N/A	N/A	1	N/A	N/A	N/A
SERVICE: Pressure Transmitter	AGING (yrs)	40	--	N/A	--	--	--
LOCATION: Auxiliary Pump Room	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A	N/A
ABOVE FLOOD LEVEL: N/A YES NO							

## NOTES:

1. A short excursion above ambient is considered to have a negligible effect.

## REFERENCES:

1. Analysis of high energy lines in letter Trosten to Giambusso of 5/14/73.

15A

FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION	OUTSTAND.
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.	METHOD	ITEMS
SYSTEM: Main Steam	OPERATING TIME	5 Min.	N/A	--	--	N/A	N/A
I.D. NO.: PT-439C COMPONENT: Transmitter	TEMPERATURE (°F)	135	N/A	1	--	N/A	N/A
MANUFACTURER: Foxboro	PRESSURE (PSIG)	0	N/A	1	--	N/A	N/A
MODEL NO.: 11-GM	RELATIVE HUMIDITY (%)	100	Note 1	1	--	N/A	N/A
FUNCTION: Main Steam Pressure	CHEMICAL SPRAY	N/A	N/A	1	N/A	N/A	N/A
ACCURACY: (% OF SPAN) SPEC: +10% DEMON: -15%	RADIATION (rads)	N/A	N/A	1	N/A	N/A	N/A
SERVICE: Pressure Transmitter	AGING (yrs)	40	--	N/A	--	--	--
LOCATION: Auxiliary Pump Room	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A	N/A
ABOVE FLOOD LEVEL: N/A YES NO							

## NOTES:

1. A short excursion above ambient is considered to have a negligible effect.

## REFERENCES:

1. Analysis of high energy lines in letter Trosten to Giambusso of 5/14/73.





FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION	OUTSTAND.
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.	METHOD	ITEMS
SYSTEM: Main Feedwater I.D. NO.: FT-418B COMPONENT: Transmitter MANUFACTURER: Foxboro MODEL NO.: 513-GM FUNCTION: Main Feedwater Flow ACCURACY: (% OF SPAN) SPEC: +10% DEMON: -15% SERVICE: Pressure Transmitter LOCATION: Auxiliary Pump Room	OPERATING TIME	5 Min.	N/A	--	--	N/A	N/A
	TEMPERATURE (°F)	135	N/A	1	--	N/A	N/A
	PRESSURE (PSIG)	0	N/A	1	--	N/A	N/A
	RELATIVE HUMIDITY (%)	100	Note 1	1	--	N/A	N/A
	CHEMICAL SPRAY	N/A	N/A	1	N/A	N/A	N/A
	RADIATION (rads)	N/A	N/A	1	N/A	N/A	N/A
	AGING (yrs)	40	--	N/A	--	--	--
	ABOVE FLOOD LEVEL: YES      NO      N/A	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A

## NOTES:

1. A short excursion above ambient is considered to have a negligible effect.

## REFERENCES:

1. Analysis of high energy lines in letter Trosten to Giambusso of 5/14/73.

FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION	OUTSTAND.
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.	METHOD	ITEMS
SYSTEM: Main Feedwater I.D. NO.: FT-428A COMPONENT: Transmitter  MANUFACTURER: Foxboro  MODEL NO.: 13-CM FUNCTION: Main Feedwater Flow ACCURACY: SPEC: +10% DEMON: -15%  SERVICE: Pressure Transmitter LOCATION: Auxiliary Pump Room	OPERATING TIME	5 Min.	N/A	--	--	N/A	N/A
	TEMPERATURE (°F)	135	N/A	1	--	N/A	N/A
	PRESSURE (PSIG)	0	N/A	1	--	N/A	N/A
	RELATIVE HUMIDITY (%)	100	Note 1	1	--	N/A	N/A
	CHEMICAL SPRAY	N/A	N/A	1	N/A	N/A	N/A
	RADIATION (rads)	N/A	N/A	1	N/A	N/A	N/A
	AGING (yrs)	40	--	N/A	--	--	--
	ABOVE FLOOD LEVEL: N/A YES NO	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A

## NOTES:

- A short excursion above ambient is considered to have a negligible effect.

## REFERENCES:

- Analysis of high energy lines in letter Trosten to Giambusso of 5/14/73.

FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION	OUTSTAND.
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.	METHOD	ITEMS
SYSTEM: Main Feedwater	OPERATING TIME	5 Min.	N/A	--	--	N/A	N/A
I.D. NO.: FT-428B COMPONENT: Transmitter	TEMPERATURE (°F)	135	N/A	1	--	N/A	N/A
MANUFACTURER: Foxboro	PRESSURE (PSIG)	0	N/A	1	--	N/A	N/A
MODEL NO.: G13-CM	RELATIVE HUMIDITY (%)	100	Note 1	1	--	N/A	N/A
FUNCTION: Main Feedwater Flow	CHEMICAL SPRAY	N/A	N/A	1	N/A	N/A	N/A
ACCURACY: (% OF SPAN) SPEC: +10% DEMON: -15%	RADIATION (rads)	N/A	N/A	1	N/A	N/A	N/A
SERVICE: Pressure Transmitter	AGING (yrs)	40	--	N/A	--	--	--
LOCATION: Auxiliary Pump Room	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A	N/A
ABOVE FLOOD LEVEL: N/A YES NO							

## NOTES:

1. A short excursion above ambient is considered to have a negligible effect.

## REFERENCES:

1. Analysis of high energy lines in letter Trosten to Giambusso of 5/14/73.

FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION	OUTSTAND.
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.	METHOD	ITEMS
SYSTEM: Main Feedwater I.D. NO.: FT-438A COMPONENT: Transmitter MANUFACTURER: Foxboro MODEL NO.: 13-GM FUNCTION: Main Feedwater Flow ACCURACY: (% OF SPAN) SPEC: +10% DEMON: -15% SERVICE: Pressure Transmitter LOCATION: Auxiliary Pump Room	OPERATING TIME	5 Min.	N/A	--	--	N/A	N/A
	TEMPERATURE (°F)	135	N/A	1	--	N/A	N/A
	PRESSURE (PSIG)	0	N/A	1	--	N/A	N/A
	RELATIVE HUMIDITY (%)	100	Note 1	1	--	N/A	N/A
	CHEMICAL SPRAY	N/A	N/A	1	N/A	N/A	N/A
	RADIATION (rads)	N/A	N/A	1	N/A	N/A	N/A
	AGING (yrs)	40	--	N/A	--	--	--
	ABOVE FLOOD LEVEL: N/A YES NO	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A

## NOTES:

1. A short excursion above ambient is considered to have a negligible effect.

## REFERENCES:

1. Analysis of high energy lines in letter Trosten to Giambusso of 5/14/73.

FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION	OUTSTAND.
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.	METHOD	ITEMS
SYSTEM: Main Feedwater I.D. NO.: FT-438B COMPONENT: Transmitter MANUFACTURER: Foxboro MODEL NO.: 13-GM FUNCTION: Main Feedwater Flow ACCURACY: (% OF SPAN) SPEC: +10% DEMON: -15% SERVICE: Pressure Transmitter LOCATION: Auxiliary Pump Room ABOVE FLOOD LEVEL: N/A YES NO	OPERATING TIME	5 Min.	N/A	--	--	N/A	N/A
	TEMPERATURE (°F)	135	N/A	1	--	N/A	N/A
	PRESSURE (PSIG)	0	N/A	1	--	N/A	N/A
	RELATIVE HUMIDITY (%)	100	Note 1	1	--	N/A	N/A
	CHEMICAL SPRAY	N/A	N/A	1	N/A	N/A	N/A
	RADIATION (rads)	N/A	N/A	1	N/A	N/A	N/A
	AGING (yrs)	40	--	N/A	--	--	--
	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A	N/A

## NOTES:

1. A short excursion above ambient is considered to have a negligible effect.

## REFERENCES:

1. Analysis of high energy lines in letter Trosten to Giambusso of 5/14/73.

FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION	OUTSTAND.
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.	METHOD	ITEMS
SYSTEM: Main Feedwater I.D. NO.: FT-448A COMPONENT: Transmitter MANUFACTURER: Foxboro MODEL NO.: 13-QM FUNCTION: Main Feedwater Flow ACCURACY: (% OF SPAN) SPEC: +10% DEMON: -15% SERVICE: Pressure Transmitter LOCATION: Auxiliary Pump Room	OPERATING TIME	5 Min.	N/A	--	--	N/A	N/A
	TEMPERATURE (°F)	135	N/A	1	--	N/A	N/A
	PRESSURE (PSIG)	0	N/A	1	--	N/A	N/A
	RELATIVE HUMIDITY (%)	100	Note 1	1	--	N/A	N/A
	CHEMICAL SPRAY	N/A	N/A	1	N/A	N/A	N/A
	RADIATION (rads)	N/A	N/A	1	N/A	N/A	N/A
	AGING (yrs)	40	--	N/A	--	--	--
	ABOVE FLOOD LEVEL: YES NO	N/A	SUBMERGENCE	N/A	N/A	N/A	N/A

## NOTES:

1. A short excursion above ambient is considered to have a negligible effect.

## REFERENCES:

1. Analysis of high energy lines in letter Trosten to Giambusso of 5/14/73.

FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION	OUTSTAND.
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.	METHOD	ITEMS
SYSTEM: Main Feedwater I.D. NO.: FT-448B COMPONENT: Transmitter  MANUFACTURER: Foxboro  MODEL NO.: 613-GM  FUNCTION: Main Feedwater Flow  ACCURACY: (% OF SPAN) SPEC: +10% DEMON: -15%  SERVICE: Pressure Transmitter  LOCATION: Auxiliary Pump Room  ABOVE FLOOD LEVEL: N/A YES NO	OPERATING TIME	5 Min.	N/A	--	--	N/A	N/A
	TEMPERATURE (°F)	135	N/A	1	--	N/A	N/A
	PRESSURE (PSIG)	0	N/A	1	--	N/A	N/A
	RELATIVE HUMIDITY (%)	100	Note 1	1	--	N/A	N/A
	CHEMICAL SPRAY	N/A	N/A	1	N/A	N/A	N/A
	RADIATION (rads)	N/A	N/A	1	N/A	N/A	N/A
	AGING (yrs)	40	--	N/A	--	--	--
	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A	N/A

## NOTES:

1. A short excursion above ambient is considered to have a negligible effect.

## REFERENCES:

1. Analysis of high energy lines in letter Trosten to Giambusso of 5/14/73.



Component:

TER Item #: 15D  
Device: Foxboro Transmitter  
Model: 611GM  
Function: AFP Discharge Pressure (PT-406A&B)  
Location: Auxiliary Pump Room

Deficiency:

QM, A, OI

Interim Justification:

Indian Point 2 has established that these transmitters are 8-10 feet away from any potential pipe break and redundant transmitters would not be subjected to direct impingement during the short period of time required to isolate the break. Therefore, the units are not considered to be in a harsh environment and will perform as normal.

The Auxiliary Pump Room is protected by a temperature switch which actuates at 135°F to isolate the steam to the auxiliary feed pump. Once this switch actuates the conditions in the room should quickly return to normal in case of an accident. The calculations performed showing 0.9 psig and a saturation temperature of 215°F assume that the temperature switch fails to operate and that the leak remains unisolated.

Even though this temperature switch is presently unqualified, it is felt that in the interim, its operation can be relied upon due to the low actuation temperature setpoint of 135°F. Assuming that this switch does operate in the event of a steam leak, the room conditions should not greatly exceed the 135°F setpoint.

Final Resolution:

The temperature switch relied upon in this accident will be qualified, replaced or modified to ensure its operation prior to June 30, 1982.

The licensee is also evaluating the effect on IE equipment of the temperature excursion expected in this area as a result of a steam line break. Additional action will be taken by the licensee based on the results of this study. It is anticipated that the results will confirm the belief that the rupture will be isolated by the temperature switch before the critical components of the IE devices become elevated to temperatures that will affect their operability.

FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION	OUTSTAND.
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.	METHOD	ITEMS
SYSTEM: Auxiliary Feedwater I.D. NO.: PT-406B COMPONENT: Transmitter MANUFACTURER: Foxboro MODEL NO.: 11-GM FUNCTION: Auxiliary Feedwater Pump Discharge Pressure ACCURACY: (% OF SPAN) SPEC: +10% DEMON: -15% SERVICE: Pressure Transmitter LOCATION: Auxiliary Pump Room ABOVE FLOOD LEVEL: N/A YES NO	OPERATING TIME	5 Min.	N/A	--	--	N/A	N/A
	TEMPERATURE (°F)	135	N/A	1	--	N/A	N/A
	PRESSURE (PSIG)	0	N/A	1	--	N/A	N/A
	RELATIVE HUMIDITY (%)	100	Note 1	1	--	N/A	N/A
	CHEMICAL SPRAY	N/A	N/A	1	N/A	N/A	N/A
	RADIATION (rads)	N/A	N/A	1	N/A	N/A	N/A
	AGING (yrs)	40	--	N/A	--	--	--
	SUBMERGENCE	N/A	N/A	N/A	--	N/A	N/A N/A

## NOTES:

1. A short excursion above ambient is considered to have a negligible effect.

## REFERENCES:

1. Analysis of high energy lines in letter Trosten to Giambusso of 5/14/73.

FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION	OUTSTAND.
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.	METHOD	ITEMS
SYSTEM: Auxiliary Feedwater I.D. NO.: PT-406A COMPONENT: Transmitter MANUFACTURER: Foxboro MODEL NO.: 611-GM FUNCTION: Auxiliary Feedwater Pump Discharge Pressure ACCURACY: (% OF SPAN) SPEC: +10% DEMON: -15% SERVICE: Pressure Transmitter LOCATION: Auxiliary Pump Room ABOVE FLOOD LEVEL: N/A YES NO	OPERATING TIME	5 Min.	N/A	--	--	N/A	N/A
	TEMPERATURE (°F)	135	N/A	1	--	N/A	N/A
	PRESSURE (PSIG)	0	N/A	1	--	N/A	N/A
	RELATIVE HUMIDITY (%)	100	Note 1	1	--	N/A	N/A
	CHEMICAL SPRAY	N/A	N/A	1	N/A	N/A	N/A
	RADIATION (rads)	N/A	N/A	1	N/A	N/A	N/A
	AGING (yrs)	40	--	N/A	--	--	--
	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A	N/A

## NOTES:

1. A short excursion above ambient is considered to have a negligible effect.

## REFERENCES:

1. Analysis of high energy lines in letter Trosten to Giambusso of 5/14/73.

Component:

TER Item #: 35

Device: Large Electric Motors  
SI Recirculating Pump Drive

Model: Westinghouse 588-5 Frame

Location: Inside Containment

Deficiency:

QI, QM, A

Interim Justification:

A preliminary review has established that the motor tested in the referenced test reports (WCAP's-7829, 7343L) is similar to the installed motors. The motor tested was designed to represent the worst case design of these motors.

Final Resolution:

Additional studies to document a comparison of the insulation system, lubricants, and bearings to the tested motor is underway and will be forwarded when complete. The bearings and lubricants are maintained as recommended by the manufacturer.

These motors will be included in the Indian Point 2 maintenance surveillance program to ensure that significant aging degradation is noted and corrected if it occurs.

FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION	OUTSTAND.
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.	METHOD	ITEMS
SYSTEM: Safety Injection I.D. NO.: COMPONENT: Motor MANUFACTURER: Westinghouse MODEL NO.: 588.5PH-Frame FUNCTION: Safety Injection Recirculation ACCURACY: N/A (% OF SPAN) SPEC: DEMON: SERVICE: Recirculation Pump Motor LOCATION: Inside Containment ABOVE FLOOD LEVEL: YES   X   NO	OPERATING TIME	30 days	30 days	—	5	Type Test Simultaneous	N/A
	TEMPERATURE (°F)	287	324	1	3	Type Test Simultaneous	N/A
	PRESSURE (PSIG)	40 .6	80	1	3	Type Test Simultaneous	N/A
	RELATIVE HUMIDITY (%)	100	100	1	3	Type Test Simultaneous	N/A
	CHEMICAL SPRAY	Note 1	Note 2	1	3	Type Test Simultaneous	N/A
	RADIATION (rads)	0.52 x 10 <sup>7</sup> Note 3	1.4 x 10 <sup>8</sup>	2	3	Type Test Simultaneous	N/A
	AGING (yrs)	40	40 Note 4	N/A	N/A	N/A	N/A
	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A	N/A

NOTES:

REFERENCES:

- 2000 PPM boric acid spray with 40% NaOH to result in 10.0 ph.
- 1.43 wt % Boric acid with NaOH to ph of 9.5.
- Radiation dose base on motor located outside cranewall.
- 40 Yr. Life obtained through maintenance surveillance program.

- FSAR Section 14.3
- IE Bulletin 79-01B Attachment 4, Section 4.1.2.
- Westinghouse Report WCAP 7829.

Component:

TER Item #: 36  
Device: Large Electric Motors  
Fan Cooler Motor  
Manufacturer: Westinghouse 69F97009  
Location: Inside Containment

Deficiency:

QI, QM, A

Interim Justification:

A preliminary review has established that the motor tested in the referenced test reports (WCAP's-7829, 7343L) is similar to the installed motors. The motor tested was designed to represent the worst case design of these motors.

Final Resolution:

Additional studies to document a comparison of the insulation system, lubricants, and bearings to the tested motor is underway and will be forwarded when complete. The bearings and lubricants are maintained as recommended by the manufacturer.

These motors will be included in the Indian Point 2 maintenance surveillance program to ensure that significant aging degradation is noted and corrected if it occurs.

FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION	OUTSTAND.
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.	METHOD	ITEMS
SYSTEM: Containment Fan Coolers I.D. NO.: COMPONENT: Motor MANUFACTURER: Westinghouse MODEL NO.: 69F97009 FUNCTION: Containment Cooling ACCURACY: N/A (% OF SPAN) SPEC: DEMON: SERVICE: Fan Cooler Motor LOCATION: Inside Containment	OPERATING TIME	30 days	30 days	—	3	Type Test Simultaneous	N/A
	TEMPERATURE (°F)	287	324	1	3	Type Test Simultaneous	N/A
	PRESSURE (PSIG)	40 .6	80	1	3	Type-Test Simultaneous	N/A
	RELATIVE HUMIDITY (%)	100	100	1	3	Type Test Simultaneous	N/A
	CHEMICAL SPRAY	Note 1	Note 2	1	3	Type Test Simultaneous	N/A
	RADIATION (rads)	0.52 x 10 <sup>7</sup> Note 3	1.4 x 10 <sup>8</sup>	2	3	Type Test Simultaneous	N/A
	AGING (yrs)	40	Note 4	N/A	N/A	N/A	N/A
	ABOVE FLOOD LEVEL: YES X NO	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A

NOTES:

- 2000 PPM boric acid spray with 40% NaOH to result in 10.0 ph:
- 1.43wt% boric acid with NaOH to ph of 9.5.
- Radiation dose base on motor located outside cranewall
- 40 Yr. life obtained through maintenance surveillance program.

REFERENCES:

- FSAR Section 14.3
- IE Bulletin 79-01B Attachment 4, Section 4.1.2.
- Westinghouse Report WCAP-7829.



FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION	OUTSTAND.
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.	METHOD	ITEMS
SYSTEM: Containment Fan Coolers I.D. NO.: COMPONENT: Motor MANUFACTURER: Westinghouse MODEL NO.: 69F97009 FUNCTION: Containment Cooling ACCURACY: N/A (% OF SPAN) SPEC: DEMON: SERVICE: Fan Cooler Motor LOCATION: Inside Containment ABOVE FLOOD LEVEL: YES X NO	OPERATING TIME	30 Days	30 days	—	3	Type Test Simultaneous	N/A
	TEMPERATURE (°F)	287	324	1	3	Type Test Simultaneous	N/A
	PRESSURE (PSIG)	40.6	80	1	3	Type Test Simultaneous	N/A
	RELATIVE HUMIDITY (%)	100	100	1	3	Type Test Simultaneous	N/A
	CHEMICAL SPRAY	Note 1	Note 2	1	3	Type Test Simultaneous	N/A
	RADIATION (rads)	0.52 x 10 <sup>7</sup> Note 3	1.4x10 <sup>8</sup>	2	3	Type Test Simultaneous	N/A
	AGING (yrs)	40	Note 4	N/A	N/A	N/A	N/A
	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A	N/A

NOTES:

- 2000 PPM boric acid spray with 40% NaOH to result in 10.0 ph.
- 1.43wt% boric acid with NaOH to ph of 9.5.
- Radiation dose base on motor located outside cranewall.
- 40Yr. life obtained through maintenance surveillance program.

REFERENCES:

- FSAR Section 14.3
- IE Bulletin 79-01B Attachment 4, Section 4.1.2.
- Westinghouse Report WCAP-7829

Component:

TER Item #: 40A  
Device: Cable/Splice  
Manufacturer: GE/Ray Chem  
Model: NA  
Location: In Containment

Deficiency:

QI, A, R

Interim Justification:

Samples of cable were removed from Indian Point 2 and were tested under different programs run by both Westinghouse and the different cable manufacturers. This justification summarizes these tests as well as establishes traceability for manufacturers versus test.

During all of the tests only one failure was reported. This was described in the Westinghouse test report in WCAP-7410L Volume 2 of 2. This failure resulted from apparent steam impingement on the cable splice. Since steam impingement is not a factor on field mounted cables, this failure was not considered relevant.

The test conditions are as follows:

Note: all tests are summarized

1. HELB (WCAP-7410L)

Steam and Chemical Environment

Pressure = 80 psig

Temperature = 300°F

Time = 200 hours, 68 hours at a steam pressure higher than  
containment design pressure

1.5 weight percent boric acid with NaOH added to yield a pH of 9.25.

2. Radiation and Steam (WCAP-7410L)

Gamma -  $2.8 \times 10^7$  Rads followed by exposure to a steam environment of 85 psig for 2(two) - 30 minute cycles.

3. Aging, Steam and Radiation (WCAP-7410L)

40 year equivalent followed by 4 hours of steam at 287°F and 50 psig followed by irradiation exposure to  $2 \times 10^8$  Rads.

4. Radiation and steam (Franklin Institute Report #F-C2442-02)

Gamma -  $2.5 \times 10^7$  Rads  
328°F, 85 psig

5. Submergence (Phelps-Dodge R&D Report #10519)

Submerged in simulated river water for 2 weeks.

IR tests -  $4 \times 10^6$  meg ohms.

DC withstand test - 18 KVdc for 15 minutes and 6 KVdc for 5 minutes

6. Radiation and HELB (Franklin Institute Report #F-C2781)

100 MRAD gamma radiation followed by steam and chemical environment

Pressure = 50 psig

Temperature = 298°F

Time = 7 days (12 hours at steam pressure and temperature)

7. Steam and Chemical Spray (Raychem Thermofit Report 71100 Rev. 1)

(250°F, 21 psig, 0.2% Boric Acid Spray for 24 hours).

NOTE: Tests 1 through 4 apply to Kerite cables

Tests 1 through 5 apply to GE cables.

Test 6 applies to Lewis cables

Tests 1 through 7 apply to Raychem splices

The above test data provides sufficient justification for interim operation since no absolute failures occurred as a result of anticipated environmental conditions.

Final Resolution:

The tests reported in WCAP-7410L demonstrate the capability of this cable/splice combination to survive accident conditions in an aged condition. Radiation tests exceeding the requirement were also performed before and after high energy line break test simulations. The successful submergence test was performed on an 8 - 10 year old cable removed from the site for this purpose.

FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION	OUTSTAND.
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.	METHOD	ITEMS
SYSTEM: Electrical I.D. NO.: COMPONENT: Cable/Splice MANUFACTURER: GE /Raychem MODEL NO.: Note 4 FUNCTION: ACCURACY: (% OF SPAN) SPEC: DEMON: SERVICE: LOCATION: Inside Containment ABOVE FLOOD LEVEL: YES X NO	OPERATING TIME	30 days	70 days Note 2	---	3	Separate Test	N/A
	TEMPERATURE (°F)	287	300	1	3	Simultaneous Test	N/A
	PRESSURE (PSIG)	40	80	1	3	Simultaneous Test	N/A
	RELATIVE HUMIDITY (%)	100	100	1	3	Simultaneous Test	N/A
	CHEMICAL SPRAY	Note 1	Note 3	1	3	Simultaneous Test	N/A
	RADIATION (rads)	$1.2 \times 10^8$	$2 \times 10^8$	2	3	Separate Test	NA
	AGING (yrs)	40 Yr.	40 yrs.	N/A	3	Separate Test	N/A
	SUBMERGENCE	assumed	Ref. 4	N/A	4	none	N/A

NOTES:

REFERENCES:

- 2000 PPM boric acid spray with 40% NaOH to result in 10.0 ph.
- Based on test reported in WCAP-7410L of 486 hrs. at 214°F (steam) and using 0.5 ev and a ambient of 160°F in the Arrhenius equation.
- 1.5 percent of boric acid (by weight) in water and adding sodium hydroxide to buffer the ph to a value of 9.25.
- 600 V Power Cable, Single conductor, silicone rubber insulation, asbestos braid jacket (12, 10, 8) raychem splices.

- FSAR Section 14.3
- IE Bulletin 79-01B, Attachment 4, Section 4.1.
- WCAP-7410L
- Phelps-Dodge R&D report #10519.

Component:

TER Item #: 40B  
Device: Cable/Splice  
Manufacturer: Kerite/Ray Chem  
Model: NA  
Location: In Containment

Deficiency:

QI, A, R

Interim Justification:

Samples of cable were removed from Indian Point and were tested under different programs run by both Westinghouse and the different cable manufacturers. This justification summarizes these tests as well as establishes traceability for manufacturers versus test.

During all of the tests only one failure was reported. This was described in the Westinghouse test report in WCAP-7410L Volume 2 of 2. This failure resulted from apparent steam impingement on the cable splice. Since steam impingement is not a factor on field mounted cables, this failure was not considered relevant.

The test conditions are as follows:

Note: all tests are summarized

1. HELB (WCAP-7410L)

Steam and Chemical Environment

Pressure = 80 psig

Temperature = 300°F

Time = 200 hours, 68 hours at a steam pressure higher than  
containment design pressure

1.5 weight percent boric acid with NaOH added to yield a pH of 9.25.

2. Radiation and Steam (WCAP-7410L)

Gamma -  $2.8 \times 10^7$  Rads followed by exposure to a steam environment of 85 psig for 2(two) - 30 minute cycles.

3. Aging, Steam and Radiation (WCAP-7410L)

40 year equivalent followed by 4 hours of steam at 287°F and 60 psig followed by irradiation exposure to  $2 \times 10^8$  Rads.

4. Radiation and steam (Franklin Institute Report #F-C2442-02)

Gamma -  $2.5 \times 10^7$  Rads  
328°F, 85 psig

5. Submergence (Phelps-Dodge R&D Report #10519)

Submerged in simulated river water for 2 weeks.

IR tests -  $4 \times 10^6$  meg ohms.

DC withstand test - 18 KVdc for 15 minutes and 6 KVdc for 5 minutes

6. Radiation and HELB (Franklin institute Report #F-C2781)

100 MRAD gamma radiation followed by steam and chemical environment

Pressure = 50 psig

Temperature = 298°F

Time = 7 days (12 hours at steam pressure and temperature)

7. Steam and Chemical Spray (Raychem Thermofit Report 71100 Rev. 1)

(250°F, 21 psig, 0.2% Boric Acid Spray for 24 hours).

NOTE: Tests 1 through 4 apply to Kerite cables

Tests 1 through 5 apply to GE cables

Test 6 applies to Lewis cables

Tests 1 through 7 apply to Raychem splices

The above test data provides sufficient justification for interim operation since no absolute failures occurred as a result of anticipated environmental conditions.

Final Resolution:

The tests reported in WCAP-7410L demonstrate the capability of this cable/splice combination to survive accident conditions in an aged condition. Radiation tests exceeding the requirement were also performed before and after high energy line break test simulations. The successful submergence test was performed on an 8 - 10 year old cable removed from the site for this purpose. This along with the Kerite evaluation demonstrate submergence capability for this cable/splice combination.



FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION	OUTSTAND.
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.	METHOD	ITEMS
SYSTEM: Electrical I.D. NO.: COMPONENT: Cable/Splice MANUFACTURER: Kerite/Raychem MODEL NO.: Note 5 FUNCTION: ACCURACY: (% OF SPAN) SPEC: DEMON: SERVICE: LOCATION: Inside Containment ABOVE FLOOD LEVEL: YES X NO	OPERATING TIME	30 days	Note 2 70 Days		3	Separate Test	N/A
	TEMPERATURE (°F)	287	328	1	3	Simultaneous Test	N/A
	PRESSURE (PSIG)	40	85	1	3	Simultaneous Test	N/A
	RELATIVE HUMIDITY (%)	100	100	1	3	Simultaneous Test	N/A
	CHEMICAL SPRAY	Note 1	Note 3	1	3	Simultaneous Test	N/A
	RADIATION (rads)	$1.2 \times 10^8$	$2 \times 10^8$	2	3	Separate Test	N/A
	AGING (yrs)	40 Yr.	40 yr.	N/A	3	Separate Test	N/A
	SUBMERGENCE	assumed	Ref: 4 & 5	N/A	4	Separate Test & Analysis	Note 4

NOTES:

REFERENCES:

- 2000 PPM boric acid spray with 40% NaOH to result in 10.0 ph.
- Based on test reported in WCAP-7410L of 486 hrs. at 214°F (steam) and used 0.5 ev and an ambient of 160°F in the Arrhenius equation.
- 1.5 percent of boric acid (by weight) in water and adding sodium hydroxide to buffer the ph to a value of 9.25.
- Submergence test performed as GE cables and Raychem splices.
- 600V Power & Control multi-conductor #12 Kerite Insulation w/pair zinc, tape, kerite jacket overall raychem splices.
- FSAR Section 14.3
- IE Bulletin 79-01B, Attachment 4, Section 4.1.
- WCAP - 7410L
- Phelps-Dodge R&D Report #10519.
- Kerite Letter from C. Lundy of Kerite to G. Blinker of Con-ed dated November 6, 1980.

Component:

TER Item #: 400  
Device: Cable  
Manufacturer: Lewis  
Model: NA  
Location: In Containment

Deficiency:

QI, A, R

Interim Justification:

Samples of cable were removed from Indian Point 2 and were tested under different programs run by both Westinghouse and the different cable manufacturers. This justification summarizes these tests as well as establishes traceability for manufacturer versus test.

During all of the tests only one failure was noticed. This was described in the Westinghouse test report in WCAP-74102 Vol. 2 of 2. This failure resulted from apparent steam impingement on the cable splice. Since steam impingement is not a factor on field mounted cables this failure was not considered relevant.

The test conditions are as follows:

(Note all tests are summarized)

1. HELB (WCAP-7410L)

Steam and Chemical Environment

Pressure = 80 psig

Temperature = 300°F

Time = 200 hours; 68 hours at a steam pressure higher than containment design pressure

1.5 weight percent boric acid with NaOH added to yield a pH of 9.25.

2. Radiation and Steam (WCAP-7410L)

Gamma -  $2.8 \times 10^7$  Rads followed by exposure to a steam environment of 85 psig for 2 (two) - 30 minute cycles.

3. Aging, Steam and Radiation (WCAP-7410L)

40 year equivalent followed by 4 hours of steam at 287°F and 60 psig followed by irradiation exposure to  $2 \times 10^8$  Rads.

4. Radiation and steam (Franklin Institute Report #F-C2442-02)

Gamma -  $2.5 \times 10^7$  Rads  
328°F, 85 psig

5. Submergence (Phelps-Dodge R&D Report #10519)

Submerged in simulated river water for 2 weeks.

IR tests -  $4 \times 10^6$  megohms.

DC withstand test - 18 KVDC for 15 minutes and 6 KVDC for 5 minutes.

6. Radiation and HELB (Franklin Institute Report #F-C2781)

100 M Rads gamma radiation followed by Steam and Chemical Environment

Pressure = 50 psig

Temperature = 298°F

Time = 7 days (12 hours at a steam pressure and temperature)

7. Steam and Chemical Spray (Raychem Thermofit Report 71100 Rev. 1)

(250°F, 21 psig, 0.2% Boric Acid Spray for 24 hours).

Note: Tests 1 through 4 apply to Kerite cables.

Tests 1 through 5 apply to GE cables

Test 6 applies to Lewis cables.

Tests 1 through 7 apply to Raychem splices

The above test data provides sufficient justification for interim operation since no absolute failures occurred as a result of anticipated environmental conditions.

#### Final Resolution

The resolution of the deficiencies associated with these cables is ongoing. Appropriate action will be taken once these deficiencies are resolved.

FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION METHOD	OUTSTAND. ITEMS
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.		
SYSTEM: Electrical	OPERATING TIME	30 days	7 days	---	4	Simulation Test	Note 2
I.D. NO.: COMPONENT: Cable	TEMPERATURE (°F)	287	298	1	3	Simulation Test	N/A
MANUFACTURER: Lewis	PRESSURE (PSIG)	40	50	1	3	Simulation Test	N/A
MODEL NO.: Note C	RELATIVE HUMIDITY (%)	100	100	1	3	Simulation Test	N/A
FUNCTION:	CHEMICAL SPRAY	Note 1	Note 3	1	3	Simulation Test	N/A
ACCURACY: (% OF SPAN) SPEC: DEMON:	RADIATION (rads)	$0.84 \times 10^8$	$1 \times 10^8$	2	3	Sequential Test	N/A
SERVICE:	AGING (yrs)	40	---	N/A	---	---	Note 4
LOCATION: Inside Containment	SUBMERGENCE	assumed	---	N/A	---	---	Note 5
ABOVE FLOOD LEVEL: YES <input checked="" type="checkbox"/> NO							

NOTES:

- 2000 PPM boric acid spray with 40% NaOH to result in 10.0 ph.
- Test performed at 160°F for 7 days. IR improved as test progressed.
- 1.23 parts boric acid per 100 parts H<sub>2</sub>O buffered to a pH of 9.0 with NaOH.
- Aging not part of test sequence.
- Submergence not part of test sequence.

REFERENCES:

- FSAR Section 14.3.
- IE Bulletin 79-01B, Attachment 4, Section 4.1.2.
- Franklin Insitute Report #F-C2781
- WCAP - 7410L
- Electrical instrument cable, silicone-rubber glass-braid-insulation/silicone rubber jacket

FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION	OUTSTAND.
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.	METHOD	ITEMS
SYSTEM: Electrical	OPERATING TIME	30 days.	7 days	---	4	Simulation Test	Note 2
I.D. NO.: COMPONENT: Cable	TEMPERATURE (°F)	287	298	1	3	Simulation Test	N/A
MANUFACTURER: Lewis	PRESSURE (PSIG)	40	50	1	3	Simulation Test	N/A
MODEL NO.: Note G	RELATIVE HUMIDITY (%)	100	100	1	3	Simulation Test	N/A
FUNCTION:	CHEMICAL SPRAY	Note 1	Note 3	1	3	Simulation Test	N/A
ACCURACY: (% OF SPAN) SPEC: DEMON:	RADIATION (rads)	$0.84 \times 10^8$	$1 \times 10^8$	2	3	Sequential Test	N/A
SERVICE:	AGING (yrs)	40	---	N/A	---	---	Note 4
LOCATION: Inside Containment	SUBMERGENCE	assumed	---	N/A	---	---	Note 5
ABOVE FLOOD LEVEL: YES X NO							

NOTES:

- 2000 PPM boric acid spray with 40% NaOH to result in 10.0 ph.
- Test performed at 160°F for 7 days. IR improved as test progressed.
- 1.23 parts boric acid per 100 parts H<sub>2</sub>O buffered to a pH of 9.0 with NaOH.
- Aging not part of test sequence.
- Submergence not part of test sequence.

REFERENCES:

- FSAR Section 14.3.
- IE Bulletin 79-01B, Attachment 4, Section 4.1.2.
- Franklin Insitute Report #F-C2781
- WCAP - 7410L
- Electrical instrument cable, silicone-rubber glass-braid-insulation/silicone rubber jacket

Component:

TER Item #: 41  
Device: RTD (Wide Range)  
Manufacturer: Rosemount  
Model: 176 JA  
Location: Inside Containment

Deficiency:

A, T, R

Interim Justification:

The wide range RTDs are utilized for providing information to the operator on RCS hot leg and cold leg temperature. The wide range RTDs are used for indicating temperatures from 0 to approximately 700°F. If the wide range RTDs are lost due to an adverse environment resulting from a high energy line rupture inside containment, the operator can use steam generator pressure as an alternate indication of RCS temperature.

Steam generator pressure can be used to infer RCS cold leg temperature. To use this variable, any uncontrolled releases of energy on the secondary side must be isolated from the non-faulted loops. Also an adequate supply of water must be supplied to the non-faulted steam generators to ensure primary to secondary heat transfer (flow through steam generator U-tubes). During quasi-steady state conditions in the RCS (secondary heat removal greater than the core decay heat plus reactor coolant pump heat), the saturation temperature corresponding to the steam generator pressure is approximately equal to the RCS cold leg temperature.

Final Resolution:

Indian Point 2 is presently evaluating replacement RTD suppliers and replacement will be completed as soon as possible after receipt of qualified units during an outage of sufficient duration.

FACILITY: Indian Point 2  
 DOCKET:

SYSTEM COMPONENT EVALUATION  
 WORK SHEET

ENCLOSURE  
 79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION	OUTSTAND.
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.	METHOD	ITEMS
SYSTEM: Reactor Coolant System	OPERATING TIME	30 days	Note 2	---	--	N/A	Note 2
I.D. NO.: COMPONENT: Resistance Temperature Detector (Wide Range) MANUFACTURER: Rosemount	TEMPERATURE (°F)	287	Note 2	1	--	N/A	Note 2
MODEL NO.: 176JA	PRESSURE (PSIG)	40	Note 2	1	--	N/A	Note 2
FUNCTION:	RELATIVE HUMIDITY (%)	100	Note 2	1	--	N/A	Note 2
ACCURACY: (% OF SPAN) SPEC: DEMON:	CHEMICAL SPRAY	Note 1	Note 2	1	--	N/A	Note 2
SERVICE:	RADIATION (rads)	$1.54 \times 10^8$	Note 2	2	--	N/A	Note 2
LOCATION: Inside Containment	AGING (yrs)	40	Note 2	N/A	--	N/A	Note 2
ABOVE FLOOD LEVEL: YES X NO	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A	N/A

NOTES:

- 2000 PPM boric acid spray with 40% NaOH to result in 10.0 ph.
- Interim justification provided. RTD's to be replaced.

REFERENCES:

- FSAR Section 14.3
- Bulletin 79-01B, Attachment 4, Section 4.1.2.



Component:

TER Item #: 42A  
Device: Hydrogen Recombiner Panel  
Model: Westinghouse  
Function: Control Panel for Recombiner  
Location: Pipe Penetration Area

Deficiency:

RPN

Interim Justification:

It has been determined that the design basis event environment deviates only slightly from ambient conditions.

Final Resolution:

Indian Point 2 has determined that the area where the H<sub>2</sub> Recombiner Panel is located is a mild environmental zone. The radiation levels are  $2 \times 10^2$  rads/year due to the shielding effects of 1 foot 9 inches of concrete separating the pipe penetration area from this panel. This device should therefore not be listed as subject to harsh environments.

FACILITY:  
DOCKET:

Indian Point 2

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION	OUTSTAND.
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.	METHOD	ITEMS
SYSTEM: Hydrogen Recombiner	OPERATING TIME	30 days	--	--	--	N/A	N/A
I.D. NO.: COMPONENT: Hydrogen Recombiner Panel	TEMPERATURE (°F)	104 Note 1	--	1	--	N/A	N/A
MANUFACTURER: Westinghouse	PRESSURE (PSIG)	0 Note 1	--	1	--	N/A	N/A
MODEL NO.: N/A	RELATIVE HUMIDITY (%)	60	--	1	--	N/A	N/A
FUNCTION: Operation of Hydrogen Recombiner	CHEMICAL SPRAY	N/A	--	1	--	N/A	N/A
ACCURACY: (% OF SPAN) SPEC: DEMON:	RADIATION (rads)	$2.0 \times 10^2$ Note 2	--	1	--	/A	N/A
SERVICE: Hydrogen Recombiner	AGING (yrs)	40	--	N/A	--	N/A	N/A
LOCATION: Pipe Penetration Area	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A	N/A
ABOVE FLOOD LEVEL: YES NO							

NOTES:

1. Normal operating conditions.
2. Additional shielding reduces dose to  $2 \times 10^2$  rads.

REFERENCES:

1. IE Bulletin 79-01B, Attachment 4, Section 4.3.

Component:

TER Item #: 8  
Device: Level Switch  
Manufacturer: GEMS  
Model: LS 800  
Location: In Containment

Deficiency:

QI

Interim Justification:

These units at Indian Point 2 have been replaced with Barton Lot 4 transmitters.

With the large range of experience and the amount of testing on this type of transmitter, it is known that the material and components used do not have an identified thermal aging mechanism (as compared to Appendix C of IE Bulletin 79-013) that could affect the performance of these transmitters during reactor operation.

Until Lot 4 Barton testing has been completed, the radiation aging has been addressed adequately by the Lot 2 testing program. Barton Lot 2 WCAP-9885 is sufficient for qualification data of Lot 4 Barton's. This is possible due to the similarity of the transmitters. In addition, upon completion of the Lot 4 tests, which include aging, Westinghouse will provide the WCAP qualifying these transmitters.

The documentation review for aging is on going. Interim operation is justified based on the fact that aging is a long term parameter and should not adversely affect equipment operability until the question is more fully resolved. In addition to the material evaluation being conducted, Indian Point 2 will establish an ongoing program to review the surveillance and maintenance records of the plant in order to

identify equipment degradation which may be age related. A maintenance program will be established which, in conjunction with the surveillance program and materials study results, will lead to the establishment of a replacement schedule for equipment that is qualified for less than the life after plant.

Final Resolution

These units have been replaced with Barton Lot 4 Model 764 transmitters. The replacement date was May 1981.

FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION	OUTSTAND.
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.	METHOD	ITEMS
SYSTEM: Containment Sump Level I.D. NO.: LT-3300 COMPONENT: Level Transmitter MANUFACTURER: Barton MODEL NO.: 764 (Lot 4) FUNCTION: Containment Sump Level ACCURACY: N/A (% OF SPAN) SPEC: DEMON: SERVICE: Containment Sump LOCATION: Inside Containment ABOVE FLOOD LEVEL: YES <input checked="" type="checkbox"/> NO	OPERATING TIME	30 days	Trip 5 min. Post DBE 4 mos.	-	3	Simultaneous Test	N/A
	TEMPERATURE (°F)	287	380	1	3	Simultaneous Test	N/A
	PRESSURE (PSIG)	40	89.7	1	3	Simultaneous Test	N/A
	RELATIVE HUMIDITY (%)	100	100	1	3	Simultaneous Test	N/A
	CHEMICAL SPRAY	Note 1	1.4 wt boric acid + 0.17 wt. of NaOH	1	3	Simultaneous Test	N/A
	RADIATION (rads)	1.4 X 10 <sup>7</sup> Note 2	5 X 10 <sup>7</sup>	2	3	Simultaneous Test	N/A
	AGING (yrs)	40	---	N/A	3	Simultaneous Test	N/A
	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A	N/A

NOTES:

- 2000 PPM boric acid spray with 40% NaOH to result in 10.0 ph.
- Gamma only. See section 3.8

REFERENCES:

- FSAR Section 14.3.
- IE Bulletin 79-01B, Attachment 4, Section 4.1.2.
- WCAP-9885 (lot 2).

NOTES:

- Accuracy requirements: +10% for 0 to 5 min.  
5 min. to 4 mos. +25%  
Accuracy demonstrated: max. error 0-5min. +5%, -17%  
5 min. to 4 mos. +19%  
-17% Error discussed in ref 3

FACILITY: INDIAN POINT 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION	OUTSTAND.
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.	METHOD	ITEMS
SYSTEM: Containment I.D. NO.: LT-3301 COMPONENT: Level Transmitter MANUFACTURER: Barton MODEL NO.: 764 (Lot 4) FUNCTION: Containment Sump Level ACCURACY: N/A (% OF SPAN) SPEC: DEMON: SERVICE: Recirculation Sump LOCATION: Inside Containment ABOVE FLOOD LEVEL: YES X NO	OPERATING TIME	30 days	Trip 5 min. Post DEB 4 mos.	-	3	Simultaneous Test	N/A
	TEMPERATURE (°F) note	287	380	1	3	Simultaneous Test	N/A
	PRESSURE (PSIG) note	40	89.7	1	3	Simultaneous Test	N/A
	RELATIVE HUMIDITY (%)	100	100	1	3	Simultaneous Test	N/A
	CHEMICAL SPRAY	Note 1	1.4 wt boric acid + 0.17 wt. of NaOH	1	3	Simultaneous Test	N/A
	RADIATION (rads)	1.4 x 10 <sup>7</sup> Note 2	5 x 10 <sup>7</sup>	2	3	Simultaneous Test	N/A
	AGING (yrs)	40	---	N/A	3	Simultaneous Test	N/A
	SUBMERGENCE	N/A	N/A	N/A	N/A	Simultane N/A	N/A

NOTES:

- 2000 PPM boric acid spray with 40% NaOH to result in 10.0 ph.
  - Gamma only. See section 3.8
  - Accuracy requirements: +10% for 0 to 5 min  
- 5 min to 4 mos. +25%
- Accuracy demonstrated: max. error 0-5 min. +5%, -17%  
5 min. to 4 mos. +19%  
-17% Error discussed in ref 3

REFERENCES:

- FSAR Section 14.3.
- IE Bulletin 79-01B, Attachment 4, Section 4.1.2.
- WCAP-9885 (lot 2).

Component:

TER Item #: 9  
Device: Transmitter Foxboro  
Model: 613DM  
Function: Steam Generator Narrow Range Level  
(LT417A through C, LT427A through C,  
LT437A through C, and LT447A through C.)  
Location: In Containment

Deficiency:

QI, QM, A, CS, R

Interim Justification:

These narrow range units at Indian Point 2 have been replaced with Barton Lot 4 transmitters. The wide range level transmitters were incorrectly identified as a potential deficiency.

With the large range of experience and the amount of testing on this type of transmitter, it is known that the material and components used do not have an identified thermal aging mechanism (as compared to Appendix C of IE Bulletin 79-01B) that could affect the performance of these transmitters during reactor operation.

Until Lot 4 Barton testing has been completed, the radiation aging has been addressed adequately by the Lot 2 testing program. Barton Lot 2 WCAP-9885 is sufficient for qualification data of Lot 4 Barton's. This is possible due to the similarity of the transmitters. In addition, upon completion of the Lot 4 tests, which include aging, Westinghouse will provide the WCAP qualifying these transmitters.

The documentation review for aging is on going. Interim operation is justified based on the fact that aging is a long term parameter and should not adversely affect equipment operability until the question is

more fully resolved. In addition to the material evaluation being conducted, Indian Point 2 will establish an ongoing program to review the surveillance and maintenance records of the plant in order to identify equipment degradation which may be age related. A maintenance program will be established which, in conjunction with the surveillance program and materials study results, will lead to the establishment of a replacement schedule for equipment that is qualified for less than the life after plant.

#### Final Resolution

These units have been replaced with Barton Lot 4 Model 764 transmitters. The replacement date was May 1981.



FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION METHOD	OUTSTAND. ITEMS
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.		
SYSTEM: Steam Generator Level I.D. NO.: LT-417A COMPONENT: Level Transmitter MANUFACTURER: Barton MODEL NO.: 764 (Lot 4) FUNCTION: Steam Generator Level ACCURACY: (% OF SPAN) SPEC: Note 4 DEMON: Note 4 SERVICE: Steam Generator Level LOCATION: Inside Containment	OPERATING TIME	5 min.	Trip 5 min. Post DBE 4 mos.	—	Note 3	Simultaneous Test	N/A
	TEMPERATURE (°F)	287	380	1	Note 3	Simultaneous Test	N/A
	PRESSURE (PSIG)	40	89.7	1	Note 3	Simultaneous Test	N/A
	RELATIVE HUMIDITY (%)	100	100	1	Note 3	Simultaneous Test	N/A
	CHEMICAL SPRAY	Note 1	1.4 wt. boric acid + 0.17 wt. of NaOH	1	Note 3	Simultaneous Test	N/A
	RADIATION (rads)	.52 x 10 <sup>7</sup> Note 2	5 x 10 <sup>7</sup>	2	Note 3	Sequential Test	N/A
	AGING (yrs)	40	40 Note 3	N/A	Note 3	Sequential Test	N/A
ABOVE FLOOD LEVEL: YES X NO	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A	N/A

NOTES:

- 2000 PPM boric acid spray with 40% NaOH to result in 10.0 ph.
- Radiation dose is base on the transmitter located outside the crane wall.
- Equipment committed for maintenance.
- Accuracy requirements: +10% for 0 to 5 min.  
5 min. to 4 mos. +25%  
Accuracy demonstrated: max. error 0-5 min. + 5%, -17%  
5 min. to 4 mos. +19%

REFERENCES:

- FSAR section 14.3
- IE Bulletin 79-01B, Attachment 4, section 4.1.2
- WCAP-9885 (lot 2)

FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION	OUTSTAND.
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.	METHOD	ITEMS
SYSTEM: Steam Generator Level I.D. NO.: LT-417B COMPONENT: Level Transmitter MANUFACTURER: Barton MODEL NO.: 764 (Lot 4) FUNCTION: Steam Generator Level ACCURACY: (% OF SPAN) SPEC: Note 4 DEMON: Note 4 SERVICE: Steam Generator Level LOCATION: Inside Containment ABOVE FLOOD LEVEL: YES X NO	OPERATING TIME	5 min.	Trip 5 min. Post DBE 4 mos.	---	Note 3	Simultaneous Test	N/A
	TEMPERATURE (°F)	287	380	1	Note 3	Simultaneous Test	N/A
	PRESSURE (PSIG)	40	89.7	1	Note 3	Simultaneous Test	N/A
	RELATIVE HUMIDITY (%)	100	100	1	Note 3	Simultaneous Test	N/A
	CHEMICAL SPRAY	Note 1	1.4 wt. boric acid + 0.17 wt. of NaOH	1	Note 3	Simultaneous Test	N/A
	RADIATION (rads)	.52X 10 <sup>7</sup> Note 2	5 X 10 <sup>7</sup>	2	Note 3	Sequential Test	N/A
	AGING (yrs)	40	40 Note 3	N/A	Note 3	Sequential Test	N/A
	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A	N/A

NOTES:

- 2000 PPM boric acid spray with 40% NaOH to result in 10.0 ph.
- Radiation dose is base on the transmitter located outside the crane wall.
- Equipment committed for maintenance.
- Accuracy requirements: +10% for 0 to 5 min.  
5 min. to 4 mos. +25%  
Accuracy demonstrated: max. error 0-5 min. + 5%, -17%  
5 min. to 4 mos. +19%

REFERENCES:

- FSAR section 14.3
- IE Bulletin 79-01B, Attachment 4, section 4.1.2.
- WCAP-9885 (lot 2)

FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION	OUTSTAND.
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.	METHOD	ITEMS
SYSTEM: Steam Generator Level I.D. NO.: LT-417C COMPONENT: Level Transmitter MANUFACTURER: Barton MODEL NO.: 764 (Lot 4) FUNCTION: Steam Generator Level ACCURACY: (% OF SPAN) SPEC: Note 4 DEMON: Note 4	OPERATING TIME	5 min.	Trip 5 min. Post DBE 4 mos.		Note 3	Simultaneous Test	N/A
	TEMPERATURE (°F)	287	380	1	Note 3	Simultaneous Test	N/A
	PRESSURE (PSIG)	40	89.7	1	Note 3	Simultaneous Test	N/A
	RELATIVE HUMIDITY (%)	100	100	1	Note 3	Simultaneous Test	N/A
	CHEMICAL SPRAY	Note 1	1.4 wt. boric acid + 0.17 wt. of NaOH	1	Note 3	Simultaneous Test	N/A
SERVICE: Steam Generator Level LOCATION: Inside Containment	RADIATION (rads)	.52x 10 <sup>7</sup> Note 2	5 X 10 <sup>7</sup>	2	Note 3	Sequential Test	N/A
	AGING (yrs)	40	40 Note 3	N/A	Note 3	Sequential Test	N/A
ABOVE FLOOD LEVEL: YES X NO	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A	N/A

NOTES:

- 2000 PPM boric acid spray with 40% NaOH to result in 10.0 ph.
- Radiation dose is base on the transmitter located outside the crane wall.
- Equipment committed for maintenance.
- Accuracy requirements: +10% for 0 to 5 min.  
5 min. to 4 mos. +25%  
Accuracy demonstrated: max. error 0-5 min. + 5%, -17%  
5 min. to 4 mos. +19%

REFERENCES:

- FSAR section 14.3
- IE Bulletin 79-01B, Attachment 4, section 4.1.2
- WCAP-9885 (lot 2)

FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION	OUTSTAND.
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.	METHOD	ITEMS
SYSTEM: Steam Generator Level I.D. NO.: LT-427A COMPONENT: Level Transmitter	OPERATING TIME	5 min.	Trip 5 min. Post DBE 4 mos.		Note 3	Simultaneous Test	N/A
MANUFACTURER: Barton	TEMPERATURE (°F)	287	380	1	Note 3	Simultaneous Test	N/A
MODEL NO.: 764 (Lot 4)	PRESSURE (PSIG)	40	89.7	1	Note 3	Simultaneous Test	N/A
FUNCTION: Steam Generator Level	RELATIVE HUMIDITY (%)	100	100	1	Note 3	Simultaneous Test	N/A
ACCURACY: (% OF SPAN) SPEC: Note 4 DEMON:	CHEMICAL SPRAY	Note 1	1.4 wt. boric acid + 0.17 wt. of NaOH	1	Note 3	Simultaneous Test	N/A
SERVICE: Steam Generator Level	RADIATION (rads)	.52x 10 <sup>7</sup> Note 2	5 X 10 <sup>7</sup>	2	Note 3	Sequential Test	N/A
LOCATION: Inside Containment	AGING (yrs)	40	40 Note 3	N/A	Note 3	Sequential Test	N/A
ABOVE FLOOD LEVEL: YES X NO	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A	N/A

NOTES:

- 2000 PPM boric acid spray with 40% NaOH to result in 10.0 ph.
- Radiation dose is base on the transmitter located outside the crane wall.
- Equipment committed for maintenance.
- Accuracy requirements: +10% for 0 to 5 min.  
5 min. to 4 mos. +25%  
Accuracy demonstrated: max. error 0-5 min. +.5%, -17%  
5 min. to 4 mos. +19%

REFERENCES:

- FSAR section 14.3
- IE Bulletin 79-01B, Attachment 4, section 4.1.2
- WCAP-9885 (lot 2)

FACILITY: Indian Point 2.  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION	OUTSTAND.
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.	METHOD	ITEMS
SYSTEM: Steam Generator Level I.D. NO.: LT-4278 COMPONENT: Level Transmitter MANUFACTURER: Barton MODEL NO.: 764 (Lot 4) FUNCTION: Steam Generator Level ACCURACY: (% OF SPAN) SPEC: Note 4 DEMON: Note 4 SERVICE: Steam Generator Level LOCATION: Inside Containment	OPERATING TIME	5 min.	Trip 5 min. Post-DBE 4 mos.	—	Note 3	Simultaneous Test	N/A
	TEMPERATURE (°F)	287	380	1	Note 3	Simultaneous Test	N/A
	PRESSURE (PSIG)	40	89.7	1	Note 3	Simultaneous Test	N/A
	RELATIVE HUMIDITY (%)	100	100	1	Note 3	Simultaneous Test	N/A
	CHEMICAL SPRAY	Note 1	1.4 wt. boric acid + 0.17 wt. of NaOH	1	Note 3	Simultaneous Test	N/A
	RADIATION (rads)	$5.2 \times 10^7$ Note 2	$5 \times 10^7$	2	Note 3	Sequential Test	N/A
	AGING (yrs)	40	40 Note 3	N/A	Note 3	Sequential Test	N/A
ABOVE FLOOD LEVEL: YES X- NO	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A	N/A

NOTES:

- 2000 PPM boric acid spray with 40% NaOH to result in 10.0 pH.
- Radiation dose is base on the transmitter located outside the crane wall.
- Equipment committed for maintenance.
- Accuracy requirements: +10% for 0 to 5 min.  
5 min. to 4 mos. +25%  
Accuracy demonstrated: max. error 0-5 min. + 5%, -17%

REFERENCES:

- FSAR section 14.3
- IE Bulletin 79-01B, Attachment 4, section 4.1.2
- WCAP-9885 (lot 2)

FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION	OUTSTAND.
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.	METHOD	ITEMS
SYSTEM: Steam Generator Level I.D. NO.: LT-427C COMPONENT: Level Transmitter  MANUFACTURER: Barton  MODEL NO.: 764 (Lot 4)  FUNCTION: Steam Generator Level  ACCURACY: (% OF SPAN) SPEC: Note 4 DEMON:  SERVICE: Steam Generator Level  LOCATION: Inside Containment  ABOVE FLOOD LEVEL: YES X NO	OPERATING TIME	5 min.	Trip 5 min. Post DBE 4 mos.	---	Note 3	Simultaneous Test	N/A
	TEMPERATURE (°F)	287	380	1	Note 3	Simultaneous Test	N/A
	PRESSURE (PSIG)	40	89.7	1	Note 3	Simultaneous Test	N/A
	RELATIVE HUMIDITY (%)	100	100	1	Note 3	Simultaneous Test	N/A
	CHEMICAL SPRAY	Note 1	1.4 wt. boric acid + 0.17 wt. of NaOH	1	Note 3	Simultaneous Test	N/A
	RADIATION (rads)	$.52 \times 10^7$ Note 2	$5 \times 10^7$	2	Note 3	Sequential Test	N/A
	AGING (yrs)	40	40 Note 3	N/A	Note 3	Sequential Test	N/A
	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A	N/A

NOTES:

1. 2000 PPM boric acid spray with 40% NaOH to result in 10.0 ph.

Radiation dose is base on the transmitter located outside the crane wall.

3. Equipment committed for maintenance.

4. Accuracy requirements: +10% for 0 to 5 min.

5 min. to 4 mos. +25%

Accuracy demonstrated: max. error 0-5 min. + 5%, -17%

5 min. to 4 mos. ±19%

REFERENCES:

1. FSAR section 14.3
2. IE Bulletin 79-01B, Attachment 4, section 4.1.2
3. WCAP-9885 (Lot 2)

FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION	OUTSTAND.
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.	METHOD	ITEMS
SYSTEM: Steam Generator Level I.D. NO.: LT-437A COMPONENT: Level Transmitter	OPERATING TIME	5 min.	Trip 5 min. Post DBE 4 mos.	—	Note 3	Simultaneous Test	N/A
MANUFACTURER: Barton	TEMPERATURE (°F)	287	380	1.	Note 3	Simultaneous Test	N/A
MODEL NO.: 764 (Lot 4)	PRESSURE (PSIG)	40	89.7	1	Note 3	Simultaneous Test	N/A
FUNCTION: Steam Generator Level	RELATIVE HUMIDITY (%)	100	100	1	Note 3	Simultaneous Test	N/A
ACCURACY: (% OF SPAN) SPEC: Note 4 DEMON:	CHEMICAL SPRAY	Note 1	1.4 wt. boric acid + 0.17 wt. of NaOH	1.	Note 3	Simultaneous Test	N/A
SERVICE: Steam Generator Level	RADIATION (rads)	.52 X 10 <sup>7</sup> /Note 2	5 X 10 <sup>7</sup>	2	Note 3	Sequential Test	N/A
LOCATION: Inside Containment	AGING (yrs)	40	40 Note 3	N/A	Note 3	Sequential Test	N/A
ABOVE FLOOD LEVEL: YES X NO	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A	N/A

NOTES:

- 2000 PPM boric acid spray with 40% NaOH to result in 10.0 ph.
- Radiation dose is base on the transmitter located outside the crane wall.
- Equipment committed for maintenance.
- Accuracy requirements: +10% for 0 to 5 min.  
5 min. to 4 mos. +25%  
Accuracy demonstrated: max. error 0-5 min. + 5%, -17%  
5 min. to 4 mos. +19%

REFERENCES:

- FSAR section 14.3
- IE Bulletin 79-01B, Attachment 4, section 4.1.2
- WCAP-9885 (Lot 2)

FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION	OUTSTAND.
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.	METHOD	ITEMS
SYSTEM: Steam Generator Level I.D. NO.: LT-437B COMPONENT: Level Transmitter MANUFACTURER: Barton MODEL NO.: 764 (Lot 4) FUNCTION: Steam Generator Level ACCURACY: (X OF SPAN) SPEC: Note 4 DEMON: Note 4 SERVICE: Steam Generator Level LOCATION: Inside Containment	OPERATING TIME	5 min.	Trip 5 min. Post DBE 4 mos.	---	Note 3	Simultaneous Test	N/A
	TEMPERATURE (°F)	287	380	1	Note 3	Simultaneous Test	N/A
	PRESSURE (PSIG)	40	89.7	1	Note 3	Simultaneous Test	N/A
	RELATIVE HUMIDITY (%)	100	100	1	Note 3	Simultaneous Test	N/A
	CHEMICAL SPRAY	Note 1	1.4 wt. boric acid + 0.17 wt. of NaOH	1	Note 3	Simultaneous Test	N/A
	RADIATION (rads)	.52 X 10 <sup>7</sup> Note 2	5 X 10 <sup>7</sup>	2	Note 3	Sequential Test	N/A
	AGING (yrs)	40	40 Note 3	N/A	Note 3	Sequential Test	N/A
ABOVE FLOOD LEVEL: YES X NO	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A	N/A

NOTES:

- 2000 PPM boric acid spray with 40% NaOH to result in 10.0 ph.
- Radiation dose is base on the transmitter located outside the crane wall.
- Equipment committed for maintenance.
- Accuracy requirements: +10% for 0 to 5 min.  
5 min. to 4 mos. +25%  
Accuracy demonstrated: max. error 0-5 min. + 5%, -17%  
5 min. to 4 mos. +19%

REFERENCES:

- FSAR section 14.3
- IE Bulletin 79-01B, Attachment 4, section 4.1.2
- WCAP-9885 (Lot 2)



FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION	OUTSTAND.
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.	METHOD	ITEMS
SYSTEM: Steam Generator Level I.D. NO.: LT-437C COMPONENT: Level Transmitter MANUFACTURER: Barton	OPERATING TIME	5 min.	Trip 5 min. Post DBE 4 mos.	---	Note 3	Simultaneous Test	N/A
MODEL NO.: 764 (Lot 4)	TEMPERATURE (°F)	287	380	1	Note 3	Simultaneous Test	N/A
FUNCTION: Steam Generator Level	PRESSURE (PSIG)	40	89.7	1	Note 3	Simultaneous Test	N/A
ACCURACY: (% OF SPAN) SPEC: Note 4 DEMON: Note 4	RELATIVE HUMIDITY (%)	100	100	1	Note 3	Simultaneous Test	N/A
SERVICE: Steam Generator Level	CHEMICAL SPRAY	Note 1	1.4 wt. boric acid + 0.17 wt. of NaOH	1	Note 3	Simultaneous Test	N/A
LOCATION: Inside Containment	RADIATION (rads)	.52 X 10 <sup>7</sup> note 2	5 X 10 <sup>7</sup>	2	Note 3	Sequential Test	N/A
ABOVE FLOOD LEVEL: YES X NO	AGING (yrs)	40	40 Note 3	N/A	Note 3	Sequential Test	N/A
	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A	N/A

NOTES:

- 2000 PPM boric acid spray with 40% NaOH to result in 10.0 ph.
- Radiation dose is base on the transmitter located outside the crane wall.
- Equipment committed for maintenance.
- Accuracy requirements: +10% for 0 to 5 min.  
5 min. to 4 mos. +25%  
Accuracy demonstrated: max. error 0-5 min. + 5%, -17%  
5 min. to 4 mos. +19%

REFERENCES:

- FSAR section 14.3
- IE Bulletin 79-01B, Attachment 4, section 4.1.2
- WCAP-9885 (lot 2)

FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION	OUTSTAND.
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.	METHOD	ITEMS
SYSTEM: Steam Generator Level I.D. NO.: LT-447A COMPONENT: Level Transmitter MANUFACTURER: Barton MODEL NO.: 764 (Lot 4) FUNCTION: Steam Generator Level ACCURACY: (X OF SPAN) SPEC: Note 4 DEMON: Note 4 SERVICE: Steam Generator Level LOCATION: Inside Containment ABOVE FLOOD LEVEL: YES X NO	OPERATING TIME	5 min.	Trip 5 min. Post DBE 4 mos.		Note 3	Simultaneous Test	N/A
	TEMPERATURE (°F)	287	380	1	Note 3	Simultaneous Test	N/A
	PRESSURE (PSIG)	40	89.7	1	Note 3	Simultaneous Test	N/A
	RELATIVE HUMIDITY (%)	100	100	1	Note 3	Simultaneous Test	N/A
	CHEMICAL SPRAY	Note 1	1.4 wt. boric acid + 0.17 wt. of NaOH	1	Note 3	Simultaneous Test	N/A
	RADIATION (rads)	$52 \times 10^7$ Note 2	$5 \times 10^7$	2	Note 3	Sequential Test	N/A
	AGING (yrs)	40	40 Note 3	N/A	Note 3	Sequential Test	N/A
	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A	N/A

NOTES:

- 2000 PPM boric acid spray with 40% NaOH to result in 10.0 ph.
- Radiation dose is base on the transmitter located outside the crane wall.
- Equipment committed for maintenance.
- Accuracy requirements:  $\pm 10\%$  for 0 to 5 min.  
5 min. to 4 mos.  $\pm 25\%$   
Accuracy demonstrated: max. error 0-5 min. + 5%, -17%  
5 min. to 4 mos.  $\pm 19\%$

REFERENCES:

- FSAR section 14.3
- IE Bulletin 79-01B, Attachment 4, section 4.1.2
- WCAP-9885 (lot 2)

FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION	OUTSTAND.
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.	METHOD	ITEMS
SYSTEM: Steam Generator Level I.D. NO.: LT-447B COMPONENT: Level Transmitter	OPERATING TIME	5 min.	Trip 5 min. Post DBE 4 mos.		Note 3	Simultaneous Test	N/A
MANUFACTURER: Barton	TEMPERATURE (°F)	287	380	1	Note 3	Simultaneous Test	N/A
MODEL NO.: 764 (Lot 4)	PRESSURE (PSIG)	40	89.7	1	Note 3	Simultaneous Test	N/A
FUNCTION: Steam Generator Level	RELATIVE HUMIDITY (%)	100	100	1	Note 3	Simultaneous Test	N/A
ACCURACY: (% OF SPAN) SPEC: Note 4 DEMON:	CHEMICAL SPRAY	Note 1	1.4 wt. boric acid + 0.17 wt. of NaOH	1	Note 3	Simultaneous Test	N/A
SERVICE: Steam Generator Level	RADIATION (rads)	.52 X 10 <sup>7</sup> Note 2	5 X 10 <sup>7</sup>	2	Note 3	Sequential Test	N/A
LOCATION: Inside Containment	AGING (yrs)	40	40 Note 3	N/A	Note 3	Sequential Test	N/A
ABOVE FLOOD LEVEL: YES X NO	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A	N/A

NOTES:

- 2000 PPM boric acid spray with 40% NaOH to result in 10.0 ph.
- Radiation dose is base on the transmitter located outside the crane wall.
- Equipment committed for maintenance.
- Accuracy requirements: +10% for 0 to 5 min.  
5 min. to 4 mos. +25%  
Accuracy demonstrated: max. error 0-5 min. + 5%, -17%  
5 min. to 4 mos. +19%

REFERENCES:

- FSAR section 14.3
- IE Bulletin 79-01B, Attachment 4, section 4.1.2
- WCAP-9885 (Lot 2)

FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION	OUTSTAND.
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.	METHOD	ITEMS
SYSTEM: Steam Generator Level U.D. NO.: LT-447C COMPONENT: Level Transmitter MANUFACTURER: Barton MODEL NO.: 764 (Lot 4) FUNCTION: Steam Generator Level ACCURACY: (% OF SPAN) SPEC: Note 4 DEMON: Note 4 SERVICE: Steam Generator Level LOCATION: Inside Containment ABOVE FLOOD LEVEL: YES X NO	OPERATING TIME	5 min.	Trip 5 min. Post DBE 4 mos.	---	Note 3	Simultaneous Test	N/A
	TEMPERATURE (°F)	287	380	1	Note 3	Simultaneous Test	N/A
	PRESSURE (PSIG)	40	89.7	1	Note 3	Simultaneous Test	N/A
	RELATIVE HUMIDITY (%)	100	100	1	Note 3	Simultaneous Test	N/A
	CHEMICAL SPRAY	Note 1	1.4 wt. boric acid + 0.17 wt. of NaOH	1	Note 3	Simultaneous Test	N/A
	RADIATION (rads)	.52 x 10 <sup>7</sup> Note 2	5 x 10 <sup>7</sup>	2	Note 3	Sequential Test	N/A
	AGING (yrs)	40	40 Note 3	N/A	Note 3	Sequential Test	N/A
	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A	N/A

NOTES:

- 2000 PPM boric acid spray with 40% NaOH to result in 10.0 ph.
- Radiation dose is base on the transmitter located outside the crane wall.
- Equipment committed for maintenance.
- Accuracy requirements: +10% for 0 to 5 min.  
5 min. to 4 mos. +25%  
Accuracy demonstrated: max. error 0-5 min. + 5%, -17%  
5 min. to 4 mos. +19%

REFERENCES:

- FSAR section 14.3
- IE Bulletin 79-01B, Attachment 4, section 4.1.2
- WCAP-9885 (lot 2)

Component:

TER Item #: 11A

Device: Transmitter Foxboro

Model: 513DM HSI

Function: Recirculation Spray Flow

Location: In Containment

Deficiency:

QI, QM, A, CS, R

Interim Justification:

These units at Indian Point 2 have been replaced with Barton Lot 4 transmitters.

With the large range of experience and the amount of testing on this type of transmitter, it is known that the material and components used do not have an identified thermal aging mechanism (as compared to Appendix C of IE Bulletin 79-01B) that could affect the performance of these transmitters during reactor operation.

Until Lot 4 Barton testing has been completed, the radiation aging has been addressed adequately by the Lot 2 testing program. Barton Lot 2 WCAP-9885 is sufficient for qualification data of Lot 4 Barton's. This is possible due to the similarity of the transmitters. In addition, upon completion of the Lot 4 test, which includes aging, Westinghouse will provide the WCAP qualifying these transmitters.

The documentation review for aging is on going. Interim operation is justified based on the fact that aging is a long term parameter and should not adversely affect equipment operability until the question is more fully resolved. In addition to the material evaluation being conducted, Indian Point 2 will establish an ongoing program to review the surveillance and maintenance records of the plant in order to

identify equipment degradation which may be age related. A maintenance program will be established which, in conjunction with the surveillance program and materials study results, will lead to the establishment of a replacement schedule for equipment that is qualified for less than the life after plant.

Final Resolution

These units have been replaced with Barton Lot 4 Model 764 transmitters. The replacement date was May 1981.

FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION	OUTSTAND.
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.	METHOD	ITEMS
SYSTEM: Recirculation Spray Flow I.D. NO.: FT-945A COMPONENT: Flow Transmitter MANUFACTURER: Barton MODEL NO.: 764 (Lot 4) FUNCTION: Recirculation Spray Flow ACCURACY: (% OF SPAN) SPEC: Note 4 DEMON: Note 4 SERVICE: Recirculation Spray Flow LOCATION: Inside Containment ABOVE FLOOD LEVEL: YES X NO	OPERATING TIME	5 min.	Trip 5 min. <sup>o</sup> Post DBE 4 mos.		Note 3	Simultaneous Test	N/A
	TEMPERATURE (°F)	287	380	1	Note 3	Simultaneous Test	N/A
	PRESSURE (PSIG)	40	89.7	1	Note 3	Simultaneous Test	N/A
	RELATIVE HUMIDITY (%)	100	100	1	Note 3	Simultaneous Test	N/A
	CHEMICAL SPRAY	Note 1	1.4 wt. boric acid + 0.17 wt. of NaOH	1	Note 3	Simultaneous Test	N/A
	RADIATION (rads)	.52 X 10 <sup>7</sup> Note 2	5 X 10 <sup>7</sup>	2	Note 3	Sequential Test	N/A
	AGING (yrs)	40	40 Note 3	N/A	Note 3	Sequential Test	N/A
	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A	N/A

NOTES:

- 2000 PPM boric acid spray with 40% NaOH to result in 10.0 ph.
- Radiation dose is base on the transmitter located outside the crane wall.
- Equipment committed for maintenance.
- Accuracy requirements: +10% for 0 to 5 min.  
5 min. to 4 mos. +25%  
Accuracy demonstrated: max. error 0-5 min. +5%, -17%  
5 min. to 4 mos. +19%

REFERENCES:

- FSAR section 14.3
- IE Bulletin 79-01B, Attachment 4, section 4.1.2
- WCAP-9885 (Lot 2)

FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION	OUTSTAND.
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.	METHOD	ITEMS
SYSTEM: Recirculation Spray Flow I.D. NO.: FT-945B COMPONENT: Flow Transmitter MANUFACTURER: Barton MODEL NO.: 764 (Lot 4) FUNCTION: Recirculation Spray Flow ACCURACY: (% OF SPAN) SPEC: Note 4 DEMON: Note 4 SERVICE: Recirculation Spray Flow LOCATION: Inside Containment ABOVE FLOOD LEVEL: YES <input checked="" type="checkbox"/> NO	OPERATING TIME	5 min.	Trip 5 min. Post DBE 4 mos.		Note 3	Simultaneous Test	N/A
	TEMPERATURE (°F)	287	380	1	Note 3	Simultaneous Test	N/A
	PRESSURE (PSIG)	40	89.7	1	Note 3	Simultaneous Test	N/A
	RELATIVE HUMIDITY (%)	100	100	1	Note 3	Simultaneous Test	N/A
	CHEMICAL SPRAY	Note 1	1.4 wt. boric acid + 0.17 wt. of NaOH	1	Note 3	Simultaneous Test	N/A
	RADIATION (rads)	.52 X 10 <sup>7</sup> Note 2	5 X 10 <sup>7</sup>	2	Note 3	Sequential Test	N/A
	AGING (yrs)	40	40 Note 3	N/A	Note 3	Sequential Test	N/A
	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A	N/A

NOTES:

- 2000 PPM boric acid spray with 40% NaOH to result in 10.0 ph.
- Radiation dose is base on the transmitter located outside the crane wall.
- Equipment committed for maintenance.
- Accuracy requirements: ±1.0% for 0 to 5 min.  
5 min. to 4 mos. +25%  
Accuracy demonstrated: max. error 0-5 min. + 5%, -17%  
5 min. to 4 mos. +19%

REFERENCES:

- FSAR section 14.3
- IE Bulletin 79-01B, Attachment 4, section 4.1.2
- WCAP-9885 (lot 2)



Component:

TER Item #: 113

Device: Transmitter Foxboro

Model: 611DM C

Function: High Head Flow

Location: In Containment

Deficiency:

QI, OM, A, CS, R

Interim Justification:

This unit at Indian Point 2 has been replaced with Barton Lot 4 transmitters.

With the large range of experience and the amount of testing on this type of transmitter, it is known that the material and components used do not have an identified thermal aging mechanism (as compared to Appendix C of IE Bulletin 79-01B) that could affect the performance of these transmitters during reactor operation.

Until Lot 4 Barton testing has been completed, the radiation aging has been addressed adequately by the Lot 2 testing program. Barton Lot 2 WCAP-9885 is sufficient for qualification data of Lot 4 Barton's. This is possible due to the similarity of the transmitters. In addition, upon completion of the Lot 4 tests, which include aging, Westinghouse will provide the WCAP qualifying these transmitters.

The documentation review for aging is ongoing. Interim operation is justified based on the fact that aging is a long term parameter and should not adversely affect equipment operability until the question is more fully resolved. In addition to the material evaluation being conducted, Indian Point 2 will establish an ongoing program to review the surveillance and maintenance records of the plant in order to

identify equipment degradation which may be age related. A maintenance program will be established which, in conjunction with the surveillance program and materials study results, will lead to the establishment of a replacement schedule for equipment that is qualified for less than the life after plant.

Final Resolution

These units have been replaced with Barton Lot 4 Model 764 transmitters. The replacement date was May 1981.

FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION	OUTSTAND.
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.	METHOD	ITEMS
SYSTEM: High Head Flow	OPERATING TIME	5 min.	Trip 5 min. Post DBE 4 mos.		Note 3	Simultaneous Test	N/A
I.D. NO.: FT-924 COMPONENT: Transmitter	TEMPERATURE (°F)	287	380	1	Note 3	Simultaneous Test	N/A
MANUFACTURER: Barton	PRESSURE (PSIG)	40	89.7	1	Note 3	Simultaneous Test	N/A
MODEL NO.: 764 (Lot 4)	RELATIVE HUMIDITY (%)	100	100	1	Note 3	Simultaneous Test	N/A
FUNCTION: High Head Flow	CHEMICAL SPRAY	Note 1	1.4 wt. boric acid + 0.17 wt. of NaOH	1	Note 3	Simultaneous Test	N/A
ACCURACY: (% OF SPAN) SPEC: DEMON: Note 4	RADIATION (rads)	$52 \times 10^7$ Note 2	$5 \times 10^7$	2	Note 3	Sequential Test	N/A
SERVICE: High Head Flow	AGING (yrs)	40	40 Note 3	N/A	Note 3	Sequential Test	N/A
LOCATION: Inside Containment	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A	N/A
ABOVE FLOOD LEVEL: YES X NO							

NOTES:

- 2000 PPM boric acid spray with 40% NaOH to result in 10.0 ph.
- Radiation dose is base on the transmitter located outside the crane wall.
- Equipment committed for maintenance.
- Accuracy requirements: +10% for 0 to 5 min.  
5 min. to 4 mos. +25%  
Accuracy demonstrated: max. error 0-5 min. +5%, -17%  
5 min. to 4 mos. +19%

REFERENCES:

- FSAR section 14.3
- IE Bulletin 79-01B, Attachment 4, section 4.1.2
- WCAP-9885 (lot 2)

FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION	OUTSTAND.
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.	METHOD	ITEMS
SYSTEM: High Head Flow	OPERATING TIME	5 min.	Trip 5 min. Post DBE 4 mos.		Note 3	Simultaneous Test	N/A
I.D. NO.: FT-925 COMPONENT: Transmitter	TEMPERATURE (°F)	287	380	1	Note 3	Simultaneous Test	N/A
MANUFACTURER: Barton	PRESSURE (PSIG)	40	89.7	1	Note 3	Simultaneous Test	N/A
MODEL NO.: 764 (Note 4)	RELATIVE HUMIDITY (%)	100	100	1	Note 3	Simultaneous Test	N/A
FUNCTION: High Head Flow	CHEMICAL SPRAY	Note 1	1.4 wt. boric acid + 0.17 wt. of NaOH	1	Note 3	Simultaneous Test	N/A
ACCURACY: (% OF SPAN) SPEC: Note 4 DEMON:	RADIATION (rads)	$.52 \times 10^7$ Note 2	$5 \times 10^7$	2	Note 3	Sequential Test	N/A
SERVICE: High Head Flow	AGING (yrs)	40	40 Note 3	N/A	Note 3	Sequential Test	N/A
LOCATION: Inside Containment	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A	N/A
ABOVE FLOOD LEVEL: YES X NO							

NOTES:

- 2000 PPM boric acid spray with 40% NaOH to result in 10.0 ph.
- Radiation dose is base on the transmitter located outside the crane wall.
- Equipment committed for maintenance.
- Accuracy requirements:  $+10\%$  for 0 to 5 min.  
 $+25\%$  5 min. to 4 mos.  
Accuracy demonstrated: max. error 0-5 min.  $+5\%$ ,  $-17\%$   
5 min. to 4 mos.  $+19\%$

REFERENCES:

- FSAR section 14.3
- IE Bulletin 79-01B, Attachment 4, section 4.1.2
- WCAP-9885 (Lot 2)

FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION	OUTSTAND.
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.	METHOD	ITEMS
SYSTEM: High Head Flow I.D. NO.: FT-926 COMPONENT: Transmitter MANUFACTURER: Barton MODEL NO.: 764 (Lot 4) FUNCTION: High Head Flow ACCURACY: (% OF SPAN) SPEC: Note 4 DEMON: Note 4 SERVICE: High Head Flow LOCATION: Inside Containment	OPERATING TIME	5 min.	Trip 5 min. Post DBE 4 mos.		Note 3	Simultaneous Test	N/A
	TEMPERATURE (°F)	287	380	1	Note 3	Simultaneous Test	N/A
	PRESSURE (PSIG)	40	89.7	1	Note 3	Simultaneous Test	N/A
	RELATIVE HUMIDITY (%)	100	100	1	Note 3	Simultaneous Test	N/A
	CHEMICAL SPRAY	Note 1	1.4 wt. boric acid + 0.17 wt. of NaOH	1	Note 3	Simultaneous Test	N/A
	RADIATION (rads)	$.52 \times 10^7$ Note 2	$5 \times 10^7$	2	Note 3	Sequential Test	N/A
	AGING (yrs)	40	40 Note 3	N/A	Note 3	Sequential Test	N/A
ABOVE FLOOD LEVEL: YES X NO	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A	N/A

NOTES:

- 2000 PPM boric acid spray with 40% NaOH to result in 10.0 pH.
- Radiation dose is base on the transmitter located outside the crane wall.
- Equipment committed for maintenance.
- Accuracy requirements: +10% for 0 to 5 min.  
5 min. to 4 mos. +25%  
Accuracy demonstrated: max. error 0-5 min. + 5%, -17%  
5 min. to 4 mos. +19%

REFERENCES:

- FSAR section 14.3
- IE Bulletin 79-01B, Attachment 4, section 4.1.2
- WCAP-9885 (lot 2)

Component:

TER Item #: 12  
Device: Transmitter Foxboro  
Model: 611GH K  
Function: RCS Pressure  
Location: In Containment

Deficiency:

QI, QM, A, CS, R

Interim Justification:

These units at Indian Point 2 have been replaced with Barton Lot 4 transmitters.

With the large range of experience and the amount of testing on this type of transmitter, it is known that the material and components used do not have an identified thermal aging mechanism (as compared to Appendix C of IE Bulletin 79-01B) that could affect the performance of these transmitters during reactor operation.

Until Lot 4 Barton testing has been completed, the radiation aging has been addressed adequately by the Lot 2 testing program. Barton Lot 2 WCAP-9885 is sufficient for qualification data of Lot 4 Barton's. This is possible due to the similarity of the transmitters. In addition, upon completion of the Lot 4 test, which includes aging, Westinghouse will provide the WCAP qualifying these transmitters.

The documentation review for aging is ongoing. Interim operation is justified based on the fact that aging is a long term parameter and should not adversely affect equipment operability until the question is more fully resolved. In addition to the material evaluation being conducted, Indian Point 2 will establish an ongoing program to review the surveillance and maintenance records of the plant in order to

identify equipment degradation which may be age related. A maintenance program will be established which, in conjunction with the surveillance program and materials study results, will lead to the establishment of a replacement schedule for equipment that is qualified for less than the life after plant.

Final Resolution

These units have been replaced with Barton Lot 4 Model 763 transmitters. The replacement date was May 1981.

FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION	OUTSTAND.
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.	METHOD	ITEMS
SYSTEM: RCS Pressure	OPERATING TIME	5 min.	Trip 5 min. Post DBE 4 mos.	-----	Note 3	Simultaneous Test	N/A
I.D. NO.: PT-402 COMPONENT: Transmitter	TEMPERATURE (°F)	287	380	1	Note 3	Simultaneous Test	N/A
MANUFACTURER: Barton	PRESSURE (PSIG)	40	89.7	1	Note 3	Simultaneous Test	N/A
MODEL NO.: 763 (Lot 4)	RELATIVE HUMIDITY (%)	100	100	1	Note 3	Simultaneous Test	N/A
FUNCTION: RCS Pressure	CHEMICAL SPRAY	Note 1	1.4 wt. boric acid + 0.17 wt. of NaOH	1	Note 3	Simultaneous Test	N/A
ACCURACY: (% OF SPAN) SPEC: Note 4 DEMON: Note 4	RADIATION (rads)	.52 X 10 <sup>7</sup> Note 2	5 X 10 <sup>7</sup>	2	Note 3	Sequential Test	N/A
SERVICE: RCS Pressure	AGING (yrs)	40	40 Note 3	N/A	Note 3	Sequential Test	N/A
LOCATION: Inside Containment	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A	N/A
ABOVE FLOOD LEVEL: YES X NO							

NOTES:

- 2000 PPM boric acid spray with 40% NaOH to result in 10.0 ph.
- Radiation dose is base on the transmitter located outside the crane wall.
- Equipment committed for maintenance.
- Accuracy requirements: +10% for 0 to 5 min.  
5 min. to 4 mos. +25%  
Accuracy demonstrated: max. error 0-5 min. + 5%, -17%  
5 min. to 4 mos. +10%

REFERENCES:

- FSAR section 14.3
- IE Bulletin 79-01B, Attachment 4, section 4.1.2
- WCAP-9885 (Lot 2)



FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION	OUTSTAND.
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.	METHOD	ITEMS
SYSTEM: RCS Pressure I.D. NO.: PT-403 COMPONENT: Transmitter MANUFACTURER: Barton MODEL NO.: 763 (Lot 4) FUNCTION: RCS Pressure ACCURACY: (% OF SPAN) SPEC: Note 4 DEMON: Note 4 SERVICE: RCS Pressure LOCATION: Inside Containment	OPERATING TIME	5 min.	Trip 5 min. Post DBE 4 mos.		Note 3	Simultaneous Test	N/A
	TEMPERATURE (°F)	287	380	1	Note 3	Simultaneous Test	N/A
	PRESSURE (PSIG)	40	89.7	1	Note 3	Simultaneous Test	N/A
	RELATIVE HUMIDITY (%)	100	100	1	Note 3	Simultaneous Test	N/A
	CHEMICAL SPRAY	Note 1	1.4 wt. boric acid + 0.17 wt. of NaOH	1	Note 3	Simultaneous Test	N/A
	RADIATION (rads)	$.52 \times 10^7$ Note 2	$5 \times 10^7$	2	Note 3	Sequential Test	N/A
	AGING (yrs)	40	40 Note 3	N/A	Note 3	Sequential Test	N/A
ABOVE FLOOD LEVEL: YES X NO	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A	N/A

NOTES:

- 2000 PPM boric acid spray with 40% NaOH to result in 10.0 ph.
- Radiation dose is base on the transmitter located outside the crane wall.
- Equipment committed for maintenance.
- Accuracy requirements: +10% for 0 to 5 min.  
5 min. to 4 mos. +25%  
Accuracy demonstrated: max. error 0-5 min. + 5%, -17%  
5 min. to 4 mos. +19%

REFERENCES:

- FSAR section 14.3
- IE Bulletin 79-01B, Attachment 4, section 4.1.2
- WCAP-9885 (Lot 2)

Component:

TER Item #: 14A

Device: Transmitter Foxboro

Model: 611GM

Function: Pressurizer Pressure

Deficiency:

QI, QM, A, CS, R

Interim Justification:

These units at Indian Point 2 have been replaced with Barton Lot 4 transmitters.

With the large range of experience and the amount of testing on this type of transmitter, it is known that the material and components used do not have an identified thermal aging mechanism (as compared to Appendix C of IE Bulletin 79-01B) that could affect the performance of these transmitters during reactor operation.

Until Lot 4 Barton testing has been completed, the radiation aging has been addressed adequately by the Lot 2 testing program. Barton Lot 2 WCAP-9885 is sufficient for qualification data of Lot 4 Barton's. This is possible due to the similarity of the transmitters. In addition, upon completion of the Lot 4 tests, which include aging, Westinghouse will provide the WCAP qualifying these transmitters.

The documentation review for aging is ongoing. Interim operation is justified based on the fact that aging is a long term parameter and should not adversely affect equipment operability until the question is more fully resolved. In addition to the material evaluation being conducted, Indian Point 2 will establish an ongoing program to review the surveillance and maintenance records of the plant in order to identify equipment degradation which may be age related. A maintenance program

will be established which, in conjunction with the surveillance program and materials study results, will lead to the establishment of a replacement schedule for equipment that is qualified for less than the life after plant.

Final Resolution

These units have been replaced with Barton Lot 4 Model 763 transmitters. The replacement date was May 1981.

FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION	OUTSTAND.
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.	METHOD	ITEMS
SYSTEM: Pressurizer Transmitter I.D. NO.: PT-455 COMPONENT: Transmitter MANUFACTURER: Barton MODEL NO.: 763 (Lot 4) FUNCTION: Pressurizer Transmitter ACCURACY: (% OF SPAN) SPEC: Note 4 DEMON: Note 4 SERVICE: Pressurizer Transmitter LOCATION: Inside Containment	OPERATING TIME	5 min.	Trip 5 min. Post DBE 4 mos.		Note 3	Simultaneous Test	N/A
	TEMPERATURE (°F)	287	380	1	Note 3	Simultaneous Test	N/A
	PRESSURE (PSIG)	40	89.7	1	Note 3	Simultaneous Test	N/A
	RELATIVE HUMIDITY (%)	100	100	1	Note 3	Simultaneous Test	N/A
	CHEMICAL SPRAY	Note 1	1.4 wt. boric acid + 0.17 wt. of NaOH	1	Note 3	Simultaneous Test	N/A
	RADIATION (rads)	.52 x 10 <sup>7</sup> Note 2	5 x 10 <sup>7</sup>	2	Note 3	Sequential Test	N/A
	AGING (yrs)	40	40 Note 3	N/A	Note 3	Sequential Test	N/A
ABOVE FLOOD LEVEL: YES X NO	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A	N/A

NOTES:

- 2000 PPM boric acid spray with 40% NaOH to result in 10.0 ph.
- Radiation dose is base on the transmitter located outside the crane wall.
- Equipment committed for maintenance.
- Accuracy requirements: +10% for 0 to 5 min.  
5 min. to 4 mos. +25%  
Accuracy demonstrated: max. error 0-5 min. + 5%, -17%  
5 min. to 4 mos. +19%

REFERENCES:

- FSAR section 14.3
- IE Bulletin 79-01B, Attachment 4, section 4.1.2
- WCAP-9885 (Lot 2)

FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION	OUTSTAND.
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.	METHOD	ITEMS
SYSTEM: Pressurizer Transmitter I.D. NO.: PT-456 COMPONENT: Transmitter	OPERATING TIME	5 min.	Trip 5 min. Post DBE 4 mos.		Note 3	Simultaneous Test	N/A
MANUFACTURER: Barton	TEMPERATURE (°F)	287	380	1	Note 3	Simultaneous Test	N/A
MODEL NO.: 763 (Lot 4)	PRESSURE (PSIG)	40	89.7	1	Note 3	Simultaneous Test	N/A
FUNCTION: Pressurizer Transmitter	RELATIVE HUMIDITY (%)	100	100	1	Note 3	Simultaneous Test	N/A
ACCURACY: (% OF SPAN) SPEC: Note 4 DEMON: Note 4	CHEMICAL SPRAY	Note 1	1.4 wt. boric acid + 0.17 wt. of NaOH	1	Note 3	Simultaneous Test	N/A
SERVICE: Pressurizer Transmitter	RADIATION (rads)	.52 X 10 <sup>7</sup> Note 2	5 X 10 <sup>7</sup>	2	Note 3	Sequential Test	N/A
LOCATION: Inside Containment	AGING (yrs)	40	40 Note 3	N/A	Note 3	Sequential Test	N/A
ABOVE FLOOD LEVEL: YES X NO	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A	N/A

NOTES:

- 2000 PPM boric acid spray with 40% NaOH to result in 10.0 ph.
- Radiation dose is base on the transmitter located outside the crane wall.
- Equipment committed for maintenance.
- Accuracy requirements: +10% for 0 to 5 min.  
5 min. to 4 mos. +25%  
Accuracy demonstrated: max. error 0-5 min. + 5%, -17%  
5 min. to 4 mos. +19%

REFERENCES:

- FSAR section 14.3
- IE Bulletin 79-01B, Attachment 4, section 4.1.2
- WCAP-9885 (Lot 2)

FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION	OUTSTAND.
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.	METHOD	ITEMS
SYSTEM: Pressurizer Transmitter I.D. NO.: PT-457 COMPONENT: Transmitter  MANUFACTURER: Barton  MODEL NO.: 763 (Lot 4)  FUNCTION: Pressurizer Transmitter  ACCURACY: (% OF SPAN) SPEC: Note 4 DEMON:  SERVICE: Pressurizer Transmitter  LOCATION: Inside Containment  ABOVE FLOOD LEVEL: YES X NO	OPERATING TIME	5 min.	Trip 5 min. Post DBE 4 mos.		Note 3	Simultaneous Test	N/A
	TEMPERATURE (°F)	287	380	1	Note 3	Simultaneous Test	N/A
	PRESSURE (PSIG)	40	89.7	1	Note 3	Simultaneous Test	N/A
	RELATIVE HUMIDITY (%)	100	100	1	Note 3	Simultaneous Test	N/A
	CHEMICAL SPRAY	Note 1	1.4 wt. boric acid + 0.17 wt. of NaOH	1	Note 3	Simultaneous Test	N/A
	RADIATION (rads)	.52 X 10 <sup>7</sup> Note 2	5 X 10 <sup>7</sup>	2	Note 3	Sequential Test	N/A
	AGING (yrs)	40	40 Note 3	N/A	Note 3	Sequential Test	N/A
	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A	N/A

NOTES:

- 2000 PPM boric acid spray with 40% NaOH to result in 10.0 ph.
- Radiation dose is base on the transmitter located outside the crane wall.
- Equipment committed for maintenance.
- Accuracy requirements:
  - ±10% for 0 to 5 min.
  - 5 min. to 4 mos. +25%
 Accuracy demonstrated:
  - max. error 0-5 min. + 5%, -17%
  - 5 min. to 4 mos. +19%

REFERENCES:

- FSAR section 14.3
- IE Bulletin 79-01B, Attachment 4, section 4.1.2
- WCAP-9885 (Lot 2)

FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION	OUTSTAND.
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.	METHOD	ITEMS
SYSTEM: Pressurizer Transmitter I.D. NO.: PT-474 COMPONENT: Transmitter MANUFACTURER: Barton MODEL NO.: 763 (Lot 4) FUNCTION: Pressurizer Transmitter ACCURACY: (% OF SPAN) SPEC: Note 4 DEMON: Note 4 SERVICE: Pressurizer Transmitter LOCATION: Inside Containment ABOVE FLOOD LEVEL: YES X NO	OPERATING TIME	5 min.	Trip 5 min. Post DBE 4 mos.	---	Note 3	Simultaneous Test	N/A
	TEMPERATURE (°F)	287	380	1	Note 3	Simultaneous Test	N/A
	PRESSURE (PSIG)	40	89.7	1	Note 3	Simultaneous Test	N/A
	RELATIVE HUMIDITY (%)	100	100	1	Note 3	Simultaneous Test	N/A
	CHEMICAL SPRAY	Note 1	1.4 wt. boric acid + 0.17 wt. of NaOH	1	Note 3	Simultaneous Test	N/A
	RADIATION (rads)	$.52 \times 10^7$ Note 2	$5 \times 10^7$	2	Note 3	Sequential Test	N/A
	AGING (yrs)	40	40 Note 3	N/A	Note 3	Sequential Test	N/A
	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A	N/A

NOTES:

- 2000 PPM boric acid spray with 40% NaOH to result in 10.0 ph.
- Radiation dose is base on the transmitter located outside the crane wall.
- Equipment committed for maintenance.
- Accuracy requirements: +10% for 0 to 5 min.  
5 min. to 4 mos. +25%  
Accuracy demonstrated: max. error 0-5 min. + 5%, -17%  
5 min. to 4 mos. +19%

REFERENCES:

- FSAR section 14.3
- IE Bulletin 79-01B, Attachment 4, section 4.1.2
- WCAP-9885 (Lot 2)

Component:

TER Item #: 14B

Device: Foxboro Transmitter

Model: 611GM-ASI

Function: Containment Pressure (PT-948A,B,C and 949A,B,C)

Location: Pipe Penetration Area

Deficiency:

QM, A, R, QI, CS

Interim Justification:

Radiation is the only environment that changes during a DBE for these transmitter locations. The transmitters have been satisfactorily tested per WCAP-7410L to a level which exceeds the service condition requirement of  $3.6 \times 10^6$  rads. Indian Point 2 has established that the same model amplifiers tested are installed in the plant.

The documentation review for aging is ongoing. Interim operation is justified based on the fact that aging is a long term parameter and should not adversely affect equipment operability until the question is more fully resolved. In addition to the material evaluation being conducted, Indian Point 2 will establish an ongoing program to review the surveillance and maintenance records of the plant in order to identify equipment degradation which may be age related. A maintenance program will be established which, in conjunction with the surveillance program and materials study results, will lead to the establishment of a replacement schedule for equipment that is qualified for less than the life of the plant. This replacement schedule will be developed and provided to the staff as it becomes available.

Final Resolution:

The additional information concerning the aging evaluation program will be forwarded to the staff as it becomes available.



FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION METHOD	OUTSTAND. ITEMS
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.		
SYSTEM: Containment Pressure I.D. NO.: PT-94 <b>8A</b> COMPONENT: Transmitter  MANUFACTURER: Foxboro  MODEL NO.: G11GM-ASI  FUNCTION: Containment Pressure Pipe Penetration Area  ACCURACY: (% OF SPAN) SPEC: +10% DEMON: -15%  SERVICE: Pressure Transmitter  LOCATION: Pipe Penetration Area  ABOVE FLOOD LEVEL: N/A YES NO	OPERATING TIME	30 days	N/A	---	--	N/A	N/A
	TEMPERATURE (°F)	104	N/A	1	--	N/A	N/A
	PRESSURE (PSIG)	0	N/A	1	--	N/A	N/A
	RELATIVE HUMIDITY (%)	60	N/A	1	--	N/A	N/A
	CHEMICAL SPRAY	N/A	N/A	1	N/A	N/A	N/A
	RADIATION (rads)	$3.6 \times 10^6$	$1.0 \times 10^7$	1	2	Separate Test	N/A
	AGING (yrs)	40	---	N/A	---	N/A	N/A
	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A	N/A

NOTES:

REFERENCES:

1. IE Bulletin 79-01B, Attachment 4, Section 4
2. Foxboro Report T2-1075

FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION	OUTSTAND.
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.	METHOD	ITEMS
SYSTEM: Containment Pressure I.D. NO.: PT-94 <b>8B</b> COMPONENT: Transmitter  MANUFACTURER: Foxboro  MODEL NO.: 11GM-ASI  FUNCTION: Containment Pressure Pipe Penetration Area  ACCURACY: (% OF SPAN) SPEC: +10% DEMON: -15%  SERVICE: Pressure Transmitter  LOCATION: Pipe Penetration Area  ABOVE FLOOD LEVEL: N/A YES NO	OPERATING TIME	30 days	N/A	---	--	N/A	N/A
	TEMPERATURE (°F)	104	N/A	1	---	N/A	N/A
	PRESSURE (PSIG)	0	N/A	1	--	N/A	N/A
	RELATIVE HUMIDITY (%)	60	N/A	1	--	N/A	N/A
	CHEMICAL SPRAY	N/A	N/A	1	N/A	N/A	N/A
	RADIATION (rads)	$3.6 \times 10^6$	$1.0 \times 10^7$	1	2	Separate Test	N/A
	AGING (yrs)	40	--	N/A	--	N/A	N/A
	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A	N/A

NOTES:

REFERENCES:

1. IE Bulletin 79-01B, Attachment 4, Section 4
2. Foxboro Report T2-1075

FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION	OUTSTAND.
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.	METHOD	ITEMS
SYSTEM: Containment Pressure I.D. NO.: PT-948C COMPONENT: Transmitter  MANUFACTURER: Foxboro  MODEL NO.: 511GM-ASI  FUNCTION: Containment Pressure Pipe Penetration Area  ACCURACY: (% OF SPAN) SPEC: +10% DEMON: -15%  SERVICE: Pressure Transmitter  LOCATION: Pipe Penetration Area  ABOVE FLOOD LEVEL: N/A YES NO	OPERATING TIME	30 days	N/A		--	N/A	N/A
	TEMPERATURE (°F)	104	N/A	1	--	N/A	N/A
	PRESSURE (PSIG)	0	N/A	1	--	N/A	N/A
	RELATIVE HUMIDITY (%)	60	N/A	1	--	N/A	N/A
	CHEMICAL SPRAY	N/A	N/A	1	N/A	N/A	N/A
	RADIATION (rads)	$3.6 \times 10^6$	$1.0 \times 10^7$	1	2	Separate Test	N/A
	AGING (yrs)	40	--	N/A	--	N/A	N/A
	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A	N/A

NOTES:

REFERENCES:

- IE Bulletin 79-01B, Attachment 4, Section 4
- Foxboro Report T2-1075

FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION	OUTSTAND.
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.	METHOD	ITEMS
SYSTEM: Containment Pressure I.D. NO.: PT-94 <b>9A</b> COMPONENT: Transmitter  MANUFACTURER: Foxboro  MODEL NO.: 611GM-ASI  FUNCTION: Containment Pressure Pipe Penetration Area  ACCURACY: (% OF SPAN) SPEC: +10% DEMON: -15%  SERVICE: Pressure Transmitter  LOCATION: Pipe Penetration Area  ABOVE FLOOD LEVEL: N/A YES NO	OPERATING TIME	30 days	N/A	—	--	N/A	N/A
	TEMPERATURE (°F)	104	N/A	1	--	N/A	N/A
	PRESSURE (PSIG)	0	N/A	1	--	N/A	N/A
	RELATIVE HUMIDITY (%)	60	N/A	1	--	N/A	N/A
	CHEMICAL SPRAY	N/A	N/A	1	N/A	N/A	N/A
	RADIATION (rads)	$3.6 \times 10^6$	$1.0 \times 10^7$	1	2	Separate Test	N/A
	AGING (yrs)	40	--	N/A	--	N/A	N/A
	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A	N/A

NOTES:

REFERENCES:

1. IE Bulletin 79-01B, Attachment 4, Section 4
2. Foxboro Report T2-1075

FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION METHOD	OUTSTAND. ITEMS
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.		
SYSTEM: Containment Pressure I.D. NO.: PT-94 <b>9B</b> COMPONENT: Transmitter  MANUFACTURER: Foxboro  MODEL NO.: 611GM-ASI  FUNCTION: Containment Pressure Pipe Penetration Area  ACCURACY: (% OF SPAN) SPEC: +10% DEMON: -15%  SERVICE: Pressure Transmitter  LOCATION: Pipe Penetration Area  ABOVE FLOOD LEVEL: N/A YES NO	OPERATING TIME	30 days	N/A	---	--	N/A	N/A
	TEMPERATURE (°F)	104	N/A	1	--	N/A	N/A
	PRESSURE (PSIG)	0	N/A	1	--	N/A	N/A
	RELATIVE HUMIDITY (%)	60	N/A	1	--	N/A	N/A
	CHEMICAL SPRAY	N/A	N/A	1	N/A	N/A	N/A
	RADIATION (rads)	$3.6 \times 10^6$	$1.0 \times 10^7$	1	2	Separate Test	N/A
	AGING (yrs)	40	--	N/A	--	N/A	N/A
	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A	N/A

NOTES:

REFERENCES:

1. IE Bulletin 79-01B, Attachment 4, Section 4
2. Foxboro Report T2-1075

FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION	OUTSTAND.
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.	METHOD	ITEMS
SYSTEM: Containment Pressure I.D. NO.: PT-94 <b>9c</b> COMPONENT: Transmitter  MANUFACTURER: Foxboro  MODEL NO.: 611GM-ASI  FUNCTION: Containment Pressure Pipe Penetration Area  ACCURACY: (% OF SPAN) SPEC: +10% DEMON: -15%  SERVICE: Pressure Transmitter  LOCATION: Pipe Penetration Area  ABOVE FLOOD LEVEL: N/A YES      NO	OPERATING TIME	30 days	N/A		--	N/A	N/A
	TEMPERATURE (°F)	104	N/A	1	--	N/A	N/A
	PRESSURE (PSIG)	0	N/A	1	--	N/A	N/A
	RELATIVE HUMIDITY (%)	60	N/A	1	--	N/A	N/A
	CHEMICAL SPRAY	N/A	N/A	1	--	N/A	N/A
	RADIATION (rads)	$3.6 \times 10^6$	$1.0 \times 10^7$	1	2	Separate Test	N/A
	AGING (yrs)	40	--	N/A	--	N/A	N/A
	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A	N/A

NOTES:

REFERENCES:

1. IE Bulletin 79-01B, Attachment 4, Section 4
2. Foxboro Report T2-1075

Component:

TER Item #: 15B and 15C

Device: Foxboro Transmitter

Model: 611GM & 611 GM-OSI

Function: SI Pump Suction and Discharge Pressure (PT-922, 923 and 947)

Location: Safety Injection Room

Deficiency:

QM, A, R, QI

Interim Justification:

Radiation is the only environment that changes during a DBE for these transmitter locations. The transmitters have been satisfactorily tested per WCAP-7410L to a level which exceeds the service condition requirement of  $3.6 \times 10^6$  rads. Indian Point 2 has established that the same model amplifiers tested are installed in the plant.

The documentation review for aging is ongoing. Interim operation is justified based on the fact that aging is a long term parameter and should not adversely affect equipment operability until the question is more fully resolved. In addition to the material evaluation being conducted, Indian Point 2 will establish an ongoing program to review the surveillance and maintenance records of the plant in order to identify equipment degradation which may be age related. A maintenance program will be established which, in conjunction with the surveillance program and materials study results, will lead to the establishment of a replacement schedule for equipment that is qualified for less than the life of the plant. This replacement schedule will be developed and provided to the staff as required.

Final Resolution:

The additional information concerning the aging evaluation program will be forwarded to the Staff as it becomes available.

FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION METHOD	OUTSTAND. ITEMS
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.		
SYSTEM: Safety Injection Pump Suction I.D. NO.: PI-947 COMPONENT: Transmitter MANUFACTURER: Foxboro MODEL NO.: 611GM FUNCTION: SI Pump Suction ACCURACY: (% OF SPAN) SPEC: +10% DEMON: -15% SERVICE: Pressure Transmitter LOCATION: Safety Injection Pump Room ABOVE FLOOD LEVEL: N/A YES NO	OPERATING TIME	30 Days	N/A	—	--	N/A	N/A
	TEMPERATURE (°F)	104	N/A	1	--	N/A	N/A
	PRESSURE (PSIG)	0	N/A	1	--	N/A	N/A
	RELATIVE HUMIDITY (%)	60	N/A	1	--	N/A	N/A
	CHEMICAL SPRAY	N/A	N/A	1	--	N/A	N/A
	RADIATION (rads)	$3.6 \times 10^6$	$1.0 \times 10^7$	1	2	Separate Test	N/A
	AGING (yrs)	40	--	N/A	--	N/A	N/A
	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A	N/A

NOTES:

REFERENCES:

1. IE Bulletin 79-01B, Attachment 4, Section 4.3.
2. Foxboro Report T2-1075



FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION	OUTSTAND.
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.	METHOD	ITEMS
SYSTEM: Safety Injection Discharge Pressure I.D. NO.: PT-922 COMPONENT: Transmitter  MANUFACTURER: Foxboro  MODEL NO.: GLIGM DSI  FUNCTION: Safety Injection Discharge Pressure  ACCURACY: (% OF SPAN) SPEC: +10% DEMON: -15%  SERVICE: Pressure Transmitter  LOCATION: Safety Injection Pump Room  ABOVE FLOOD LEVEL: N/A YES NO	OPERATING TIME	30 Days	N/A	---	--	N/A	N/A
	TEMPERATURE (°F)	104	N/A	1	--	N/A	N/A
	PRESSURE (PSIG)	0	N/A	1	--	N/A	N/A
	RELATIVE HUMIDITY (%)	60	N/A	1	--	N/A	N/A
	CHEMICAL SPRAY	N/A	N/A	1	N/A	N/A	N/A
	RADIATION (rads)	$3.6 \times 10^6$	$1.0 \times 10^7$	1	2	Separate test	N/A
	AGING (yrs)	40	--	N/A	--	N/A	N/A
	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A	N/A

NOTES:

REFERENCES:

1. IE Bulletin 79-01B, Attachment 4, Section 4.3.
2. Foxboro Report T2-1075

FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION	OUTSTAND.
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.	METHOD	ITEMS
SYSTEM: Safety Injection Discharge Pressure I.D. NO.: PT-923 COMPONENT: Transmitter  MANUFACTURER: Foxboro  MODEL NO.: 611GM DSI  FUNCTION: Safety Injection Discharge Pressure  ACCURACY: (% OF SPAN) SPEC: +10% DEMON: -15%  SERVICE: Pressure Transmitter  LOCATION: Safety Injection Pump Room  ABOVE FLOOD LEVEL: N/A  YES NO	OPERATING TIME	30 Days	N/A	---	--	N/A	N/A
	TEMPERATURE (°F) note	104	N/A	1	--	N/A	N/A
	PRESSURE (PSIG) note	0	N/A	1	--	N/A	N/A
	RELATIVE HUMIDITY (%)	60	N/A	1	--	N/A	N/A
	CHEMICAL SPRAY	N/A	N/A	1	N/A	N/A	N/A
	RADIATION (rads)	$3.6 \times 10^6$	$1.0 \times 10^7$	1	--	Separate Test	N/A
	AGING (yrs)	40	--	N/A	--	N/A	N/A
	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A	N/A

NOTES:

REFERENCES:

1. IE Bulletin 79-01B, Attachment 4, Section 4.3.
2. Foxboro Report T2-1075

Component:

TER Item #: 10 & 13  
Device: Foxboro Transmitter  
Model: 613HM-H & 613HM  
Function: Pressurizer Level (LT-459, 460, 461)  
RHR Flow (FT-946A-D, FT-640)  
Location: Inside Containment

Deficiency:

QI, QM, A, CS, R

Interim Justification:

N/A

Final Resolution:

These units at Indian Point 2 have been replaced with Barton Lot 4 transmitters.

With the large range of experience and the amount of testing on this type of transmitter, it is known that the material and components used do not have an identified thermal aging mechanism (as compared to Appendix C of IE Bulletin 79-01B) that could affect the performance of these transmitters during reactor operation.

Until Lot 4 Barton testing has been completed, the radiation aging has been addressed adequately by the Lot 2 testing program. Barton Lot 2 WCAP-9885 is sufficient for qualification data of Lot 4 Barton's. This is possible due to the similarity of the transmitters. In addition, upon completion of the Lot 4 tests, which include aging, Westinghouse will provide the WCAP qualifying these transmitters.

The documentation review for aging is on going. Interim operation is justified based on the fact that aging is a long term parameter and should not adversely affect equipment operability until the question is more fully resolved. In addition to the material evaluation being conducted, Indian Point 2 will establish an ongoing program to review the surveillance and maintenance records of the plant in order to identify equipment degradation which may be age related. A maintenance program will be established which, in conjunction with the surveillance program and materials study results, will lead to the establishment of a replacement schedule for equipment that is qualified for less than the life after plant.

These units were replaced with Barton Lot 4 Model 764 transmitters. The replacement date was May 1981.

These devices were misclassified as Appendix A items. They should have been listed under Appendix B of the SER.

FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION	OUTSTAND.
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.	METHOD	ITEMS
SYSTEM: Pressurizer Level  I.D. NO.: LT-459 COMPONENT: Level Transmitter  MANUFACTURER: Barton  MODEL NO.: 764(Lot 4)  FUNCTION: Pressurizer Level  ACCURACY: (% OF SPAN) SPEC: Note 4 DEMON:  SERVICE: Pressurizer Level  LOCATION: Inside Containment  ABOVE FLOOD LEVEL: YES <input checked="" type="checkbox"/> NO	OPERATING TIME	5 min.	Trip 5 Min. Post DBE - 4 mos.	--	3	Simultaneous Test	N/A
	TEMPERATURE (°F) note	287	380	1.	3	Simultaneous Test	N/A
	PRESSURE (PSIG) note	40.6	89.7	1	3	Simultaneous Test	N/A
	RELATIVE HUMIDITY (%)	100	100	1	3	Simultaneous Test	N/A
	CHEMICAL SPRAY	Note 1	1.4 Wt. Boric Acid +0.17 wt. of NaOH	1	3	Simultaneous Test	N/A
	RADIATION (rads)	.52x10 <sup>7</sup> Note 2	5x10 <sup>7</sup>	2	3	Sequential Test	N/A
	AGING (yrs)	40	40 Note 3	N/A	3	Sequential Test	N/A
	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A	N/A

NOTES:

- 2000 PPM boric acid spray with 40% NaOH to result in 10.0 ph.
- Radiation dose is based on the transmitter located outside the crane wall.
- Equipment committed for maintenance.
- Accuracy requirements: + 10% for 0 to 5 min.  
5 min. to 4 mos. + 25%  
Accuracy Demonstrated: Max. error 0-5 min. +5%, -17%  
5 min. to 4 mos. + 19%

REFERENCES:

- FSAR Section 14.3
- I.E. Bulletin 79-01B, Attachment 4, Section 4.1.2.
- WCAP-9885 (9885 (Lot 2)).

FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION	OUTSTAND.
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.	METHOD	ITEMS
SYSTEM: PRESSURIZER LEVEL  I.D. NO.: LT-460 COMPONENT: Level Transmitter  MANUFACTURER: Barton  MODEL NO.: 764(Lot 4)  FUNCTION: Pressurizer Level  ACCURACY: (% OF SPAN) SPEC: Note 4 DEMON:  SERVICE: Pressurizer Level  LOCATION: Inside Containment	OPERATING TIME	5 min.	Trip 5 Min. Post DBE - 4 mos.	--	3	Simultaneous Test	N/A
	TEMPERATURE (°F) note	287	380	1	3	Simultaneous Test	N/A
	PRESSURE (PSIG) note	40.6	89.7	1	3	Simultaneous Test	N/A
	RELATIVE HUMIDITY (%)	100	100	1	3	Simultaneous Test	N/A
	CHEMICAL SPRAY	Note 1	1.4 Wt. Boric Acid + 0.17 wt. of NaOH	1	3	Simultaneous Test	N/A
	RADIATION (rads)	.52x10 <sup>7</sup> Note 2	5x10 <sup>7</sup>	2	3	Sequential Test	N/A
	AGING (yrs)	40	40 Note 3	N/A	3	Sequential Test	N/A
	ABOVE FLOOD LEVEL: YES <sup>x</sup> NO	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A

NOTES:

- 2000 PPM boric acid spray with 40% NaOH to result in 10.0 ph.
  - Radiation dose is based on the transmitter located outside the crane wall.
  - Equipment committed for maintenance.
  - Accuracy requirements: + 10% for 0 to 5 min.  
5 min. to 4 mos. + 25%
- Accuracy Demonstrated: Max. error 0-5 min. +5%, -17%  
5 min. to 4 mos. + 19%

REFERENCES:

- FSAR Section 14.3
- I.E. Bulletin 79-01B, Attachment 4, Section 4.1.2.
- WCAP-9885 (9885 (Lot 2)).

FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION	OUTSTAND.
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.	METHOD	ITEMS
SYSTEM: Pressurizer Level  I.D. NO.: LT-461 COMPONENT: Level Transmitter  MANUFACTURER: Barton  MODEL NO.: 764(Lot 4)  FUNCTION: Pressurizer Level  ACCURACY: (% OF SPAN) SPEC: Note 4 DEMON:  SERVICE: Pressurizer Level  LOCATION: Inside Containment  ABOVE FLOOD LEVEL: YES X NO	OPERATING TIME	5 min.	Trip 5 Min. Post DBE - 4 mos.	--	3	Simultaneous Test	N/A
	TEMPERATURE (°F) note	287	380	1	3	Simultaneous Test	N/A
	PRESSURE (PSIG) note	40.6	89.7	1	3	Simultaneous Test	N/A
	RELATIVE HUMIDITY (%)	100	100	1	3	Simultaneous Test	N/A
	CHEMICAL SPRAY	Note 1	1.4 Wt. Boric Acid +0.17 wt. of NaOH	1	3	Simultaneous Test	N/A
	RADIATION (rads)	.52x10 <sup>7</sup> Note 2	5x10 <sup>7</sup>	2	3	Sequential Test	N/A
	AGING (yrs)	40	40 Note 3	N/A	3	Sequential Test	N/A
	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A	N/A

NOTES:

- 2000 PPM boric acid spray with 40% NaOH to result in 10.0 ph.
- Radiation dose is based on the transmitter located outside the crane wall.
- Equipment committed for maintenance.
- Accuracy requirements:  $\pm 10\%$  for 0 to 5 min.  
5 min. to 4 mos.  $\pm 25\%$   
Accuracy Demonstrated: Max. error 0-5 min. +5%, -17%  
5 min. to 4 mos. + 19%

REFERENCES:

- FSAR Section 14.3
- I.E. Bulletin 79-01B, Attachment 4, Section 4.1.2.
- WCAP-9885 (9885 (Lot 2)).

FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION	OUTSTAND.
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.	METHOD	ITEMS
SYSTEM: RHR FLOW	OPERATING TIME	5 min.	Trip 5 Min. Post DBE - 4 mos.	--	3	Simultaneous Test	N/A
I.D. NO.: FT-946A COMPONENT: Flow Transmitter	TEMPERATURE (°F) note	287	380	1	3	Simultaneous Test	N/A
MANUFACTURER: Barton	PRESSURE (PSIG) note	40.6	89.7	1	3	Simultaneous Test	N/A
MODEL NO.: 764(Lot 4)	RELATIVE HUMIDITY (%)	100	100	1	3	Simultaneous Test	N/A
FUNCTION: RHR Flow	CHEMICAL SPRAY	Note 1	1.4 Wt. Boric Acid +0.17 wt. of NaOH	1	3	Simultaneous Test	N/A
ACCURACY: (% OF SPAN) SPEC: Note 4 DEMON:	RADIATION (rads)	.52x10 <sup>7</sup> Note 2	5x10 <sup>7</sup>	2	3	Sequential Test	N/A
SERVICE: RHR Flow	AGING (yrs)	40	40 Note 3	N/A	3	Sequential Test	N/A
LOCATION: Inside Containment	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A	N/A
ABOVE FLOOD LEVEL: YES X NO							

NOTES:

- 2000 PPM boric acid spray with 40% NaOH to result in 10.0 ph.
- Radiation dose is based on the transmitter located outside the crane wall.
- Equipment committed for maintenance.
- Accuracy requirements: + 10% for 0 to 5 min.  
5 min. to 4 mos. + 25%  
Accuracy Demonstrated: Max. error 0-5 min. +5%, -17%  
5 min. to 4 mos. + 19%

REFERENCES:

- FSAR Section 14.3
- I.E. Bulletin 79-01B, Attachment 4, Section 4.1.2.
- WCAP-9885 (9885 (Lot 2)).



FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION	OUTSTAND.
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.	METHOD	ITEMS
SYSTEM: RHR FLOW I.D. NO.: FT-946B COMPONENT: Flow Transmitter MANUFACTURER: Barton MODEL NO.: 764(Lot 4) FUNCTION: RHR Flow ACCURACY: (% OF SPAN) SPEC: Note 4 DEMON: SERVICE: RHR Flow LOCATION: Inside Containment ABOVE FLOOD LEVEL: YES X NO	OPERATING TIME	5 min.	Trip 5 Min. Post DBE - 4 mos.	--	3	Simultaneous Test	N/A
	TEMPERATURE (°F) note	287	380	1	3	Simultaneous Test	N/A
	PRESSURE (PSIG) note	40.6	89.7	1	3	Simultaneous Test	N/A
	RELATIVE HUMIDITY (%)	100	100	1	3	Simultaneous Test	N/A
	CHEMICAL SPRAY	Note 1	1.4 Wt. Boric Acid +0.17 wt. of NaOH	1	3	Simultaneous Test	N/A
	RADIATION (rads)	.52x10 <sup>7</sup> Note 2	5x10 <sup>7</sup>	2	3	Sequential Test	N/A
	AGING (yrs)	40	40 Note 3	N/A	3	Sequential Test	N/A
	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A	N/A

NOTES:

- 2000 PPM boric acid spray with 40% NaOH to result in 10.0 ph.
- Radiation dose is based on the transmitter located outside the crane wall.
- Equipment committed for maintenance.
- Accuracy requirements:  $\pm 10\%$  for 0 to 5 min.  
5 min. to 4 mos.  $\pm 25\%$

Accuracy Demonstrated: Max. error 0-5 min. +5%, -17%  
5 min. to 4 mos. + 19%

REFERENCES:

- FSAR Section 14.3
- I.E. Bulletin 79-01B, Attachment 4, Section 4.1.2.
- WCAP-9885 (9885 (Lot 2)).

FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION	OUTSTAND.
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.	METHOD	ITEMS
SYSTEM: RHR FLOW  I.D. NO.: FT-946 C COMPONENT: Flow Transmitter  MANUFACTURER: Barton  MODEL NO.: 764(Lot 4)  FUNCTION: RHR Flow  ACCURACY: (% OF SPAN) SPEC: Note 4 DEMON:  SERVICE: RHR Flow  LOCATION: Inside Containment  ABOVE FLOOD LEVEL: YES X NO	OPERATING TIME	5 min.	Trip 5 Min. Post DBE - 4 mos.	--	3	Simultaneous Test	N/A
	TEMPERATURE (°F) note	287	380	1	3	Simultaneous Test	N/A
	PRESSURE (PSIG) note	40.6	89.7	1	3	Simultaneous Test	N/A
	RELATIVE HUMIDITY (%)	100	100	1	3	Simultaneous Test	N/A
	CHEMICAL SPRAY	Note 1	1.4 Wt. Boric Acid +0.17 wt. of NaOH	1	3	Simultaneous Test	N/A
	RADIATION (rads)	.52x10 <sup>7</sup> Note 2	5x10 <sup>7</sup>	2	3	Sequential Test	N/A
	AGING (yrs)	40	40 Note 3	N/A	3	Sequential Test	N/A
	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A	N/A

NOTES:

- 2000 PPM boric acid spray with 40% NaOH to result in 10.0 ph.
- Radiation dose is based on the transmitter located outside the crane wall.
- Equipment committed for maintenance.
- Accuracy requirements:  $\pm 10\%$  for 0 to 5 min.  
5 min. to 4 mos.  $\pm 25\%$   
Accuracy Demonstrated: Max. error 0-5 min. +5%, -17%  
5 min. to 4 mos. + 19%

REFERENCES:

- FSAR Section 14.3
- I.E. Bulletin 79-01B, Attachment 4, Section 4.1.2.
- WCAP-9885 (9885 Lot 2).

FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION	OUTSTAND.
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.	METHOD	ITEMS
SYSTEM: RHR FLOW	OPERATING TIME	5 min.	Trip: 5 Min. Post DBE - 4 mos.	--	3	Simultaneous Test	N/A
I.D. NO.: FT-946D COMPONENT: Flow Transmitter	TEMPERATURE (°F) note	287	380	1	3	Simultaneous Test	N/A
MANUFACTURER: Barton	PRESSURE (PSIG) note	40.6	89.7	1	3	Simultaneous Test	N/A
MODEL NO.: 764(Lot 4)	RELATIVE HUMIDITY (%)	100	100	1	3	Simultaneous Test	N/A
FUNCTION: RHR Flow	CHEMICAL SPRAY	Note 1	1.4 Wt. Boric Acid +0.17 wt. of NaOH	1	3	Simultaneous Test	N/A
ACCURACY: (% OF SPAN) SPEC: Note 4 DEMON:	RADIATION (rads)	.52x10 <sup>7</sup> Note 2	5x10 <sup>7</sup>	2	3	Sequential Test	N/A
SERVICE: RHR Flow	AGING (yrs)	40	40 Note 3	N/A	3	Sequential Test	N/A
LOCATION: Inside Containment	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A	N/A
ABOVE FLOOD LEVEL: YES <input checked="" type="checkbox"/> NO							

NOTES:

- 2000 PPM boric acid spray with 40% NaOH to result in 10.0 ph.
- Radiation dose is based on the transmitter located outside the crane wall.
- Equipment committed for maintenance.
- Accuracy requirements:  $\pm 10\%$  for 0 to 5 min.  
5 min. to 4 mos.  $\pm 25\%$   
Accuracy Demonstrated: Max. error 0-5 min.  $+5\%$ ,  $-17\%$   
5 min. to 4 mos.  $+ 19\%$

REFERENCES:

- FSAR Section 14.3
- I.E. Bulletin 79-01B, Attachment 4, Section 4.1.2.
- WCAP-9885 (9885 (Lot 2)).

Component:

TER Item #: 18 - Model 8320  
19 - Model 8300  
21 - Model 8314  
22A,B,C - Model 8316  
23 - Model 8300  
24A,B - Model 8210  
25 - Model 8300  
26 - Model 8320

Device: ASCO Solenoid Valves

Function: Actuates 49 separate valves

Location: Pipe Penetrations Area (21, 22B, 22C, 25)

Auxiliary Pump Room (19, 23, 24A, 24B)

Ventilation Purge Valve (22A) Inside Containment

Containment Pressure Relief Valve (18) Inside Containment

Condensate Storage Tank Valve (26)

Deficiency:

QI

Interim Justification:

The information provided in the NS-CE-755 (Potential Mode of Failure Identified for Solenoid Valves) concerning these valves provides assurance through analysis that the ASCO solenoids will perform their safety function without occurrence of a common failure mode.

The documentation review for aging is ongoing. Interim operation is justified based on the fact that aging is a long term parameter and should not adversely affect equipment operability until the question is more fully resolved or the units replaced. In addition to the material evaluation being conducted, Indian Point 2 will establish an ongoing program to review the surveillance and maintenance records of the plant in order to identify equipment degradation which may be age related. A maintenance program will be established which, in conjunction with the

surveillance program and materials study results, will lead to the establishment of a replacement schedule for equipment that is qualified for less than the life of the plant.

Final Resolution:

Indian Point 2 is in the process of procuring replacement solenoids qualified to the latest criteria. Replacement units will be ordered prior to the end of 1981. Replacement will be completed as soon as possible after receipt of qualified units during an outage of sufficient duration.

In Item #18 has been replaced with a qualified NP type Ascó solenoid.

FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION	OUTSTAND.
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.	METHOD	ITEMS
SYSTEM: Containment Ventilation I.D. NO.: PCV-1190 COMPONENT: Solenoid Valve  MANUFACTURER: ASCO  MODEL NO.: NP-8320A175E  FUNCTION: Containment Pressure Relief Valve ACCURACY: N/A (% OF SPAN) SPEC: DEMON:  SERVICE: Pressure Relief LOCATION: Inside Containment  ABOVE FLOOD LEVEL: YES X NO	OPERATING TIME	30 Days	30 Days	--	3	Type Test Simultaneous	N/A
	TEMPERATURE (°F)	287	340	1	3	Type Test Simultaneous	N/A
	PRESSURE (PSIG)	40.6	70	1	3	Type Test Simultaneous	N/A
	RELATIVE HUMIDITY (%)	100	100	1	3	Type Test Simultaneous	N/A
	CHEMICAL SPRAY	Note 1	Note 2	1	3	Type Test Simultaneous	N/A
	RADIATION (rads)	$1.54 \times 10^8$	$2 \times 10^8$	2	3	Type Test Sequential	N/A
	AGING (yrs)	40	Note 3	N/A	3	Type Test Sequential	--
	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A	N/A

NOTES:

- 2000 PPM boric acid spray with 40% NaOH to result in 10.0ph.
- 3000 ppm boric acid buffered with NaOH to ph of 10.0
- 4.5 years designed life at 140°F.

REFERENCES:

- FSAR Section 14.3
- IE Bulletin 79-01B, Attachment 4, Section 4.1.2
- Asco Test Report AQS-21678/TR.

FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION	OUTSTAND.
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.	METHOD	ITEMS
SYSTEM: Auxiliary Feedwater I.D. NO.: COMPONENT: Solenoid Valve MANUFACTURER: ASCO MODEL NO.: 8300 FUNCTION: City Water Suction Control Valve ACCURACY: N/A (% OF SPAN) SPEC: DEMON: SERVICE: Auxiliary Feedwater Suction Control LOCATION: Auxiliary Pump Room ABOVE FLOOD LEVEL: N/A YES NO	OPERATING TIME	30 Days	5 Hrs.	--	2	Analysis	Note 1
	TEMPERATURE (°F)	135	350	1	2	Analysis	N/A
	PRESSURE (PSIG)	0	N/A	1	2	N/A	N/A
	RELATIVE HUMIDITY (%)	100	100	1	2	Analysis	N/A
	CHEMICAL SPRAY	N/A	N/A	1	N/A	N/A	N/A
	RADIATION (rads)	N/A	N/A	1	N/A	N/A	N/A
	AGING (yrs)	40	--	N/A	--	--	N/A
	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A	N/A

NOTES:

- Unrestricted time analysis based on  $1 \times 10^6$ .

REFERENCES:

- Analysis of high energy lines in letter to Trosten to Giambusso of 5/14/73.
- NS-CE-755.

FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION	OUTSTAND.
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.	METHOD	ITEMS
SYSTEM: Containment Sump I.D. NO.: COMPONENT: SOV Operator MANUFACTURER: ASCO MODEL NO.: 8314 FUNCTION: Containment Sump Pump Discharge Valves ACCURACY: N/A (% OF SPAN) SPEC: DEMON: SERVICE: Isolation Valves LOCATION: Pipe Penetration Area ABOVE FLOOD LEVEL: N/A YES           NO	OPERATING TIME	30 Days	10 Days	--	--	N/A	N/A
	TEMPERATURE (°F)	104 Note 1	N/A	1	--	N/A	N/A
	PRESSURE (PSIG)	0 Note 1	N/A	1	--	N/A	N/A
	RELATIVE HUMIDITY (%)	60 Note 1	N/A	1	--	N/A	N/A
	CHEMICAL SPRAY	N/A	N/A	1	N/A	N/A	N/A
	RADIATION (rads)	$3.6 \times 10^6$	$1 \times 10^6$	1	--	--	--
	AGING (yrs)	40	--	N/A	--	--	--
	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A	N/A

NOTES:

1. Normal operating conditions

REFERENCES:

1. IE Bulletin 79-01B, Attachment 4, Section 4
2. NS-CE-755 or 8/15/75



FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION	OUTSTAND.
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.	METHOD	ITEMS
SYSTEM: Containment Ventilation I.D. NO.: FCV-1170 COMPONENT: Solenoid Valve  MANUFACTURER: ASCO  MODEL NO.: 8316  FUNCTION: Purge Valve  ACCURACY: N/A (% OF SPAN) SPEC: DEMON:  SERVICE: Containment Ventilation Purge Valve LOCATION: Inside Containment  ABOVE FLOOD LEVEL: YES X NO	OPERATING TIME	30 Days	1 HR.	---	--	Analysis	N/A
	TEMPERATURE (°F)	287	350	1	3	Analysis	N/A
	PRESSURE (PSIG)	40 .6	--	1	--	---	--
	RELATIVE HUMIDITY (%)	100	100	1	3	Analysis	N/A
	CHEMICAL SPRAY	Note 1	Note 2	1	3	Analysis	N/A
	RADIATION (rads)	$1.54 \times 10^8$	$1.0 \times 10^6$	2	3	Analysis	N/A
	AGING (yrs)	40	--	N/A	--	---	--
	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A	N/A

NOTES:

- 2000 PPM boric acid spray with 40% NaOH to result in 10.0 ph
- 1.2% Boric Acid.

REFERENCES:

- FSAR section 14.3
- IE Bulletin 79-01B, Attachment 4, Section 4.1.2
- NS-CE-755.

FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION	OUTSTAND.
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.	METHOD	ITEMS
SYSTEM: Containment Ventilation I.D. NO.: FCV-1172 COMPONENT: Solenoid Valve  MANUFACTURER: ASCO  MODEL NO.: 8316  FUNCTION: Purge Valve  ACCURACY: N/A (% OF SPAN) SPEC: DEMON:  SERVICE: Containment Ventilation Purge Valve LOCATION: Inside Containment  ABOVE FLOOD LEVEL: YES X NO	OPERATING TIME	30 Days	1 HR.	---	--	Analysis	N/A
	TEMPERATURE (°F)	287	350	1	3	Analysis	N/A
	PRESSURE (PSIG)	40.6	--	1	--	--	--
	RELATIVE HUMIDITY (%)	100	100	1	3	Analysis	N/A
	CHEMICAL SPRAY	Note 1	Note 2	1	3	Analysis	N/A
	RADIATION (rads)	$1.54 \times 10^8$	$1.0 \times 10^6$	2	3	Analysis	N/A
	AGING (yrs)	40	--	N/A	--	--	--
	SUBMERGENCE	N/A	--	N/A	--	N/A	N/A

NOTES:

- 2000 PPM boric acid spray with 40% NaOH to result in 10.0 ph
- 1.2% Boric Acid

REFERENCES:

- FSAR section 14.3
- IE Bulletin 79-01B, Attachment 4, Section 4.1.2
- NS-CE-755

FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION	OUTSTAND.
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.	METHOD	ITEMS
SYSTEM: Containment Sump I.D. NO.: COMPONENT: SOV Operator MANUFACTURER: ASCO MODEL NO.: 8316 FUNCTION: Containment Sump Pump Discharge Valves ACCURACY: N/A (% OF SPAN) SPEC: DEMON: SERVICE: Isolation Valves LOCATION: Pipe Penetration Area ABOVE FLOOD LEVEL: N/A YES <input checked="" type="checkbox"/> NO	OPERATING TIME	30 Days	10 Days	---	--	N/A	NA
	TEMPERATURE (°F)	104 Note 1	N/A	1	---	N/A	N/A
	PRESSURE (PSIG)	0 Note 1	N/A	1	--	N/A	N/A
	RELATIVE HUMIDITY (%)	60 Note 1	N/A	1	--	N/A	N/A
	CHEMICAL SPRAY	N/A	N/A	1	N/A	N/A	N/A
	RADIATION (rads)	$3.6 \times 10^6$	$1 \times 10^6$	1	--	--	--
	AGING (yrs)	40	--	N/A	--	--	--
	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A	N/A

NOTES:

1. Normal operating conditions

REFERENCES:

1. IE Bulletin 79-01B, Attachment 4, Section 4  
2. NS-CE-755 or 8/15/75

FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION METHOD	OUTSTAND. ITEMS
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.		
SYSTEM: Auxiliary Feedwater I.D. NO.: PCV-1310B COMPONENT: Solenoid Valve  MANUFACTURER: ASCO  MODEL NO.: 8316  FUNCTION: Steam supply to turbine drive auxiliary feed pump  ACCURACY: N/A (% OF SPAN) SPEC: DEMON:  SERVICE: Isolation Valve  LOCATION: Steam/Feedline Penetration Area  ABOVE FLOOD LEVEL: YES NO	OPERATING TIME	30 Min.	N/A	---	---	N/A	Note 2
	TEMPERATURE (°F)	213	N/A	1	---	N/A	N/A
	PRESSURE (PSIG)	.42	N/A	1	---	N/A	N/A
	RELATIVE HUMIDITY (%)	60 Note 1	N/A	1	---	N/A	N/A
	CHEMICAL SPRAY	N/A	N/A	1	N/A	N/A	N/A
	RADIATION (rads)	N/A	---	1	---	---	---
	AGING (yrs)	40	---	N/A	---	---	---
	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A	N/A

NOTES:

1. Normal operating conditions.
2. Unrestricted time analysis based on  $1 \times 10^6$ .

REFERENCES:

1. Analysis of high energy lines in letter Trosten to Giambusso 5/14/73.

FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION	OUTSTAND.
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.	METHOD	ITEMS
SYSTEM: Auxiliary Feedwater I.D. NO.: PCV-1310A COMPONENT: Solenoid Valve  MANUFACTURER: ASCO  MODEL NO.: 8316  FUNCTION: Steam supply to turbine drive auxiliary feed pump  ACCURACY: N/A (% OF SPAN) SPEC: DEMON:  SERVICE: Isolation Valve  LOCATION: Steam/Feedline Penetration Area  ABOVE FLOOD LEVEL: YES      NO	OPERATING TIME	30 Min.	N/A	---	--	N/A	Note 2
	TEMPERATURE (°F)	213	N/A	1	--	N/A	N/A
	PRESSURE (PSIG)	.42	N/A	1	--	N/A	N/A
	RELATIVE HUMIDITY (%)	60 Note 1	N/A	1	--	N/A	N/A
	CHEMICAL SPRAY	N/A	N/A	1	N/A	N/A	N/A
	RADIATION (rads)	N/A	--	1	--	--	--
	AGING (yrs)	40	--	N/A	--	--	--
	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A	N/A

## NOTES:

1. Normal operating conditions.
2. Unrestricted time analysis based on  $1 \times 10^6$ .

## REFERENCES:

1. Analysis of high energy lines in letter Trosten to Giambusso 5/14/73.

FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION	OUTSTAND.
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.	METHOD	ITEMS
SYSTEM: Auxiliary Feedwater I.D. NO.: COMPONENT: Solenoid Valve MANUFACTURER: ASCO MODEL NO.: 8300 FUNCTION: Steam supply to turbine driven auxiliary feed pump ACCURACY: N/A (% OF SPAN) SPEC: DEMON: SERVICE: Isolation Valve LOCATION: Steam & Feedline Penetration Area ABOVE FLOOD LEVEL: N/A YES NO	OPERATING TIME	30 Min.	5 Hrs.	--	2	Analysis	N/A
	TEMPERATURE (°F)	213	350	1	2	Analysis	N/A
	PRESSURE (PSIG)	.42	N/A	1	--	N/A	N/A
	RELATIVE HUMIDITY (%)	100	100	1	2	Analysis	N/A
	CHEMICAL SPRAY	N/A	N/A	1	N/A	N/A	N/A
	RADIATION (rads)	N/A	N/A	1	N/A	N/A	N/A
	AGING (yrs)	40	--	N/A	--	--	N/A
	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A	N/A

## NOTES:

- 2000 PPM boric acid spray with 40% NaOH to result in 10.0 ph.

## REFERENCES:

- Analysis of high energy lines in letter Trosten to Giambusso 5/14/73
- NS-CE-755

FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION METHOD	OUTSTAND. ITEMS
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.		
SYSTEM: Auxiliary Feedwater I.D. NO.: PVC-447L COMPONENT: Solenoid Valve MANUFACTURER: ASCO MODEL NO.: 8210 FUNCTION: Actuates low flow FW regulator valve ACCURACY: N/A (% OF SPAN) SPEC: DEMON: SERVICE: Recirculation flow trip valves LOCATION: Steam & Feedline Penetration Area ABOVE FLOOD LEVEL: N/A YES NO	OPERATING TIME	30 Min.	5 Hrs.	---	2	Analysis	N/A
	TEMPERATURE (°F)	213	350	1	2	Analysis	N/A
	PRESSURE (PSIG)	.42	N/A	1	2	N/A	N/A
	RELATIVE HUMIDITY (%)	100	100	1	2	Analysis	N/A
	CHEMICAL SPRAY	N/A	N/A	1	2	N/A	N/A
	RADIATION (rads)	N/A	N/A	1	N/A	N/A	N/A
	AGING (yrs)	40	--	N/A	--	--	N/A
	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A	N/A

NOTES:

REFERENCES:

1. Analysis of high energy lines in letter Trosten to Giambussò 5/14/73.
2. NS-CE-755.

FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION	OUTSTAND.
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.	METHOD	ITEMS
SYSTEM: Auxiliary Feedwater I.D. NO.: PCV-1189 COMPONENT: Solenoid Valve MANUFACTURER: ASCO MODEL NO.: 8210 FUNCTION: Actuates city water suction control valve ACCURACY: N/A (% OF SPAN) SPEC: DEMON: SERVICE: Recirculation flow trip valves LOCATION: Steam & Feedline Penetration Area ABOVE FLOOD LEVEL: N/A YES NO	OPERATING TIME	30 Min.	5 Hrs.	--	2	Analysis	N/A
	TEMPERATURE (°F)	213	350	1	2	Analysis	N/A
	PRESSURE (PSIG)	.42	N/A	1	2	N/A	N/A
	RELATIVE HUMIDITY (%)	100	100	1	2	Analysis	N/A
	CHEMICAL SPRAY	N/A	N/A	1	2	N/A	N/A
	RADIATION (rads)	N/A	N/A	1	N/A	N/A	N/A
	AGING (yrs)	40	--	N/A	--	--	
	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A	N/A

NOTES:

REFERENCES:

1. Analysis of high energy lines in letter Trosten to Giambusso 5/14/73
2. NS-CE-755.



24A

FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION	OUTSTAND.
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.	METHOD	ITEMS
SYSTEM: Auxiliary Feedwater I.D. NO.: PVC-1188 COMPONENT: SOLENOID VALVE MANUFACTURER: ASCO MODEL NO.: 8210 FUNCTION: Actuates city water suction control valve ACCURACY: N/A (% OF SPAN) SPEC: DEMON: SERVICE: Recirculation flow trip valves LOCATION: Steam & Feedline Penetration Area ABOVE FLOOD LEVEL: N/A YES NO	OPERATING TIME	30 Min.	5 Hrs.	---	2	Analysis	N/A
	TEMPERATURE (°F)	213	350	1	2	Analysis	N/A
	PRESSURE (PSIG)	.42	N/A	1	--	N/A	N/A
	RELATIVE HUMIDITY (%)	100	100	1	2	Analysis	N/A
	CHEMICAL SPRAY	N/A	N/A	1	N/A	N/A	N/A
	RADIATION (rads)	N/A	N/A	1	N/A	N/A	N/A
	AGING (yrs)	40	--	N/A	--	--	N/A
	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A	N/A

NOTES:

REFERENCES:

1. Analysis of high energy lines in letter Trosten to Giambusso 5/14/73.
2. NS-CE-755 of 8/15/75.

FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION	OUTSTAND. ITEMS
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.	METHOD	
SYSTEM: Auxiliary Feedwater I.D. NO.: PVC-1187 COMPONENT: Solenoid Valve  MANUFACTURER: ASCO  MODEL NO.: 8210  FUNCTION: Actuates city water suction control valve  ACCURACY: N/A (% OF SPAN) SPEC: DEMON:  SERVICE: Recirculation flow trip valves  LOCATION: Steam & Feedline Penetration Area	OPERATING TIME	30 Min.	5 Hrs.	—	2	Analysis	N/A
	TEMPERATURE (°F)	213	350	1	2	Analysis	N/A
	PRESSURE (PSIG)	.42	N/A	1	--	N/A	N/A
	RELATIVE HUMIDITY (%)	100	100	1	2	Analysis	N/A
	CHEMICAL SPRAY	N/A	N/A	1	N/A	N/A	N/A
	RADIATION (rads)	N/A	N/A	1	N/A	N/A	N/A
	AGING (yrs)	40	--	N/A	--	--	N/A
	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A	N/A
ABOVE FLOOD LEVEL: N/A YES NO							

NOTES:

REFERENCES:

1. Analysis of high energy lines in letter Trosten to Giambusso 5/14/73.
2. NS-CE-755 of 8/15/75

24A

FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION METHOD	OUTSTAND. ITEMS
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.		
SYSTEM: Auxiliary Feedwater I.D. NO.: FCV-1123 COMPONENT: Solenoid Valve MANUFACTURER: ASCO MODEL NO.: 8210 FUNCTION: Actuates AFP recirculation flow trip valves ACCURACY: N/A (% OF SPAN) SPEC: DEMON: SERVICE: Recirculation flow trip valves LOCATION: Steam & Feedline Penetration Area ABOVE FLOOD LEVEL: N/A YES           NO	OPERATING TIME	30 Min.	5 Hrs.	---	2	Analysis	N/A
	TEMPERATURE (°F)	213	350	1	2	Analysis	N/A
	PRESSURE (PSIG)	.42	N/A	1	--	N/A	N/A
	RELATIVE HUMIDITY (%)	100	100	1	2	Analysis	N/A
	CHEMICAL SPRAY	N/A	N/A	1	N/A	N/A	N/A
	RADIATION (rads)	N/A	N/A	1	N/A	N/A	N/A
	AGING (yrs)	40	--	N/A	--	--	N/A
	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A	N/A

## NOTES:

- 2000 PPM boric acid spray with 40% NaOH to result in 10.0 ph.

## REFERENCES:

- Analysis of high energy lines in letter Trosten to Giambusso 5/14/73.
- NS-CE-755

FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION	OUTSTAND.
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.	METHOD	ITEMS
SYSTEM: Auxiliary Feedwater I.D. NO.: FCV-1121 COMPONENT: Solenoid Valve MANUFACTURER: ASCO MODEL NO.: 8210 FUNCTION: Actuates AFP recirculation flow trip valves ACCURACY: N/A (% OF SPAN) SPEC: DEMON: SERVICE: Recirculation flow trip valves LOCATION: Steam & Feedline Penetration Area ABOVE FLOOD LEVEL: N/A YES NO	OPERATING TIME	30 Min.	5 Hrs.	--	2	Analysis	N/A
	TEMPERATURE (°F)	213	350	1	2	Analysis	N/A
	PRESSURE (PSIG)	.42	N/A	1	--	N/A	N/A
	RELATIVE HUMIDITY (%)	100	100	1	2	Analysis	N/A
	CHEMICAL SPRAY	N/A	N/A	1	N/A	N/A	N/A
	RADIATION (rads)	N/A	N/A	1	N/A	N/A	N/A
	AGING (yrs)	40	--	N/A	--	--	N/A
	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A	N/A

## NOTES:

- 2000 PPM boric acid spray with 40% NaOH to result in 10.0 ph.

## REFERENCES:

- Analysis of high energy lines in letter Trosten to Giambusso 5/14/73.
- NS-CE-755

FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION	OUTSTAND.
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.	METHOD	ITEMS
SYSTEM: Auxiliary Feedwater I.D. NO.: PVC-427L COMPONENT: Solenoid Valve  MANUFACTURER: ASCO  MODEL NO.: 8210  FUNCTION: Actuates low flow FW regulator valve  ACCURACY: N/A (% OF SPAN) SPEC: DEMON:  SERVICE: Recirculation flow trip valves  LOCATION: Steam & Feedline - Penetration Area  ABOVE FLOOD LEVEL: N/A YES NO	OPERATING TIME	30 Min.	5 Hrs.	--	2	Analysis	N/A
	TEMPERATURE (°F)	213	350	1	2	Analysis	N/A
	PRESSURE (PSIG)	.42	N/A	1	2	N/A	N/A
	RELATIVE HUMIDITY (%)	100	100	1	2	Analysis	N/A
	CHEMICAL SPRAY	N/A	N/A	1	2	N/A	N/A
	RADIATION (rads)	N/A	N/A	1	N/A	N/A	N/A
	AGING (yrs)	40	--	N/A	--	--	N/A
	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A	N/A

NOTES:

REFERENCES:

1. Analysis of high energy lines in letter Trosten to Giambusso 5/14/73
2. NS-CE-755

FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION	OUTSTAND.
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.	METHOD	ITEMS
SYSTEM: Auxiliary Feedwater I.D. NO.: PVC-437L COMPONENT: Solenoid Valve MANUFACTURER: ASCO MODEL NO.: 8210 FUNCTION: Actuates low flow FW regulator valve ACCURACY: N/A (% OF SPAN) SPEC: DEMON: SERVICE: Recirculation flow trip valves LOCATION: Steam & Feedline Penetration Area ABOVE FLOOD LEVEL: N/A YES NO	OPERATING TIME	30 Min.	5 Hrs.	--	2	Analysis	N/A
	TEMPERATURE (°F)	213	350	1	2	Analysis	N/A
	PRESSURE (PSIG)	.42	N/A	1	2	N/A	N/A
	RELATIVE HUMIDITY (%)	100	100	1	2	Analysis	N/A
	CHEMICAL SPRAY	N/A	N/A	1	2	N/A	N/A
	RADIATION (rads)	N/A	N/A	1	N/A	N/A	N/A
	AGING (yrs)	40	--	N/A	--	--	N/A
	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A	N/A

NOTES:

REFERENCES:

1. Analysis of high energy lines in letter Trosten to Giambusso 5/14/73.
2. NS-CE-755.

FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION	OUTSTAND.
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.	METHOD	ITEMS
SYSTEM: Auxiliary Feedwater I.D. NO.: PVC-417L COMPONENT: Solenoid Valve MANUFACTURER: ASCO MODEL NO.: 8210 FUNCTION: Actuates low flow FW regulator valve ACCURACY: N/A (% OF SPAN) SPEC: DEMON: SERVICE: Recirculation flow trip valves LOCATION: Steam & Feedline Penetration Area ABOVE FLOOD LEVEL: N/A YES       NO	OPERATING TIME	30 Min.	5 Hrs.	---	2	Analysis	N/A
	TEMPERATURE (°F)	213	350	1	2	Analysis	N/A
	PRESSURE (PSIG)	.42	N/A	1	2	N/A	N/A
	RELATIVE HUMIDITY (%)	100	100	1	2	Analysis	N/A
	CHEMICAL SPRAY	N/A	N/A	1	2	N/A	N/A
	RADIATION (rads)	N/A	N/A	1	N/A	N/A	N/A
	AGING (yrs)	40	--	N/A	--	--	N/A
	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A	N/A

NOTES:

REFERENCES:

1. Analysis of high energy lines in letter Trosten to Giambusso 5/14/73.
2. NS-CE-755

FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION METHOD	OUTSTAND. ITEMS
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.		
SYSTEM: Auxiliary Feedwater I.D. NO.: PCV-1139 COMPONENT: Solenoid Valve  MANUFACTURER: ASCO  MODEL NO.: 8210  FUNCTION: Actuates AFW pump steam pressure control valve  ACCURACY: N/A (% OF SPAN) SPEC: DEMON:  SERVICE: Steam pressure control  LOCATION: Auxiliary pump room  ABOVE FLOOD LEVEL: N/A YES NO	OPERATING TIME	30 Days	5 Hrs.	--	2	Analysis	N/A
	TEMPERATURE (°F)	135	350	1	2	Analysis	N/A
	PRESSURE (PSIG)	0	N/A	1	2	N/A	N/A
	RELATIVE HUMIDITY (%)	100	100	1	2	Analysis	N/A
	CHEMICAL SPRAY	N/A	N/A	1	2	N/A	N/A
	RADIATION (rads)	N/A	N/A	1	N/A	N/A	N/A
	AGING (yrs)	40	--	N/A	--	--	N/A
	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A	N/A

NOTES:

REFERENCES:

1. Analysis of high energy lines in letter Trosten to Giambussò of 5/14/73.
2. NS-CE-755.



FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION	OUTSTAND.
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.	METHOD	ITEMS
SYSTEM: Containment sump I.D. NO.: COMPONENT: SOV Operator MANUFACTURER: ASCO MODEL NO.: 8300 FUNCTION: Containment sump pump discharge valves ACCURACY: N/A (% OF SPAN) SPEC: DEMON: SERVICE: Isolation valves LOCATION: Pipe Penetration Area ABOVE FLOOD LEVEL: N/A YES           NO	OPERATING TIME	30 Days	10 Days	---	--	N/A	N/A
	TEMPERATURE (°F)	104 Note 1	N/A	1	--	N/A	N/A
	PRESSURE (PSIG)	0 Note 1	N/A	1	--	N/A	N/A
	RELATIVE HUMIDITY (%)	60 Note 1	N/A	1	--	N/A	N/A
	CHEMICAL SPRAY	N/A	N/A	1	N/A	N/A	N/A
	RADIATION (rads)	$3.6 \times 10^6$	$1 \times 10^6$	1	--	--	--
	AGING (yrs)	40	--	N/A	--	--	--
	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A	N/A

NOTES:

REFERENCES:

1. Normal operating conditions

1. IE Bulletin 79-01B, Attachment 4, Section 4.3.1.2

FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION	OUTSTAND.
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.	METHOD	ITEMS
SYSTEM: Auxiliary Feedwater I.D. NO.: LCV-1158 COMPONENT: Solenoid Valve MANUFACTURER: ASCO MODEL NO.: 8320 FUNCTION: Actuates condensate storage tank valve ACCURACY: N/A (% OF SPAN) SPEC: DEMON: SERVICE: Recirculation flow trip valves LOCATION: Auxiliary Pump Room ABOVE FLOOD LEVEL: N/A YES NO	OPERATING TIME	30 Min.	5 Hrs.	--	2	Analysis	N/A
	TEMPERATURE (°F)	135	350	1	2	Analysis	N/A
	PRESSURE (PSIG)	0	N/A	1	2	N/A	N/A
	RELATIVE HUMIDITY (%)	100	100	1	2	Analysis	N/A
	CHEMICAL SPRAY	N/A	N/A	1	2	N/A	N/A
	RADIATION (rads)	N/A	N/A	1	N/A	N/A	N/A
	AGING (yrs)	40	--	N/A	--	--	N/A
	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A	N/A

NOTES:

REFERENCES:

1. Analysis of high energy lines in letter to Giambusso of 5/14/73.
2. NS-CE-755.

Component:

TER Item #: 20A and B  
Device: Laurence Solenoid Valve  
Model: 500 and 1200  
Function: Actuates Main Steam Isolation Valves  
Location: Steam and Feedline Penetrations Area

Deficiency:

QI

Interim Justification:

Failure of the MSIVs to close following a high energy steam line rupture would result in multiple steam generator blowdown. Generic analysis has shown that multiple steamline blowdown results in a higher return to power following the rupture. However, the peaking factors are less severe than those resulting from only one steamline rupture. The effects on the core were similar to those presented in the SAR.

If the MSIVs fail in the closed position or operate normally following a high energy steam line rupture outside containment, the blowdown would be limited to only one steam generator blowdown. Multiple steam generator blowdown is precluded by the steamline check valves for a rupture upstream of the MSIVs. For a rupture downstream of the MSIVs, closure of MSIVs due to failure or automatic isolation would terminate the rupture blowdown.

Final Resolution:

Indian Point 2 is in the process of evaluating qualified solenoid valves and a replacement schedule will be established upon completion of this evaluation.

FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION	OUTSTAND.
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.	METHOD	ITEMS
SYSTEM: Main Steam I.D. NO.: COMPONENT: Solenoid MANUFACTURER: Lawrence MODEL NO.: 500 FUNCTION: Actuates Main Steam Isolation Valves ACCURACY: N/A (% OF SPAN) SPEC: DEMON: SERVICE: Isolation Valves LOCATION: Steam/Feedline Penetration Area ABOVE FLOOD LEVEL: N/A YES NO	OPERATING TIME	5 min.	Note 1	—	--	--	--
	TEMPERATURE (°F)	213	Note 1	1	--	--	--
	PRESSURE (PSIG)	.42	Note 1	1	--	--	--
	RELATIVE HUMIDITY (%)	100	Note 1	1	--	--	--
	CHEMICAL SPRAY	N/A	N/A	1	N/A	N/A	N/A
	RADIATION (rads)	N/A	N/A	1	N/A	N/A	N/A
	AGING (yrs)	40	Note 1	N/A	--	--	--
	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A	N/A

NOTES:

- Equipment Qualification to latest standards has not been performed.

REFERENCES:

- Analysis of high energy lines in letter Trosten to Giambusso 5-14.

FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION	OUTSTAND.
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.	METHOD	ITEMS
SYSTEM: Main Steam I.D. NO.: COMPONENT: Solenoid MANUFACTURER: Lawrence MODEL NO.: 1200 FUNCTION: Actuates Main Steam Isolation Valves ACCURACY: N/A (% OF SPAN) SPEC: DEMON: SERVICE: Isolation Valves LOCATION: Steam/Feedline Penetration Area	OPERATING TIME	5 min.	Note 1	---	--	--	--
	TEMPERATURE (°F)	213	Note 1	1	--	--	--
	PRESSURE (PSIG)	.42	Note 1	1	--	--	--
	RELATIVE HUMIDITY (%)	100	Note 1	1	--	--	--
	CHEMICAL SPRAY	N/A	N/A	1	N/A	N/A	N/A
	RADIATION (rads)	N/A	N/A	1	N/A	N/A	N/A
	AGING (yrs)	40	Note 1	N/A	--	--	--
	ABOVE FLOOD LEVEL: N/A YES NO	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A

NOTES:

- Equipment Qualification to latest standards has not been performed.

REFERENCES:

- Analysis of high energy lines in letter Trosten to Giambusso 5-14.

Component:

TER Item #: 27

Device: Laurence Solenoid Valve

Model: 629BC85PS

Function: Actuates H<sub>2</sub> Recombiner Isolation Valves

Location: Pipe Penetration Area

Deficiency:

QI, A, T

Interim Justification:

N/A

Final Resolution:

These valves have been replaced with qualified Valcor valves.

FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION METHOD	OUTSTAND. ITEMS
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.		
SYSTEM: Hydrogen Recombiner I.D. NO.: IV-2A COMPONENT: Solenoid Valve  MANUFACTURER: Valcor  MODEL NO.: V5-6200  FUNCTION: Hydrogen Recombiner Isolation Valve  ACCURACY: N/A (% OF SPAN) SPEC: DEMON:  SERVICE: Isolation Valve  LOCATION: Pipe Penetration Area  ABOVE FLOOD LEVEL: N/A YES NO	OPERATING TIME	30 Days	30 Days	--	2	N/A	N/A
	TEMPERATURE (°F)	104 Note 1	346	1	2	N/A	N/A
	PRESSURE (PSIG)	0 Note 1	113	1	2	N/A	N/A
	RELATIVE HUMIDITY (%)	60 Note 1	100	1	2	N/A	N/A
	CHEMICAL SPRAY	N/A	N/A	1	2	N/A	N/A
	RADIATION (rads)	$3.6 \times 10^6$	$2 \times 10^8$	1	2	N/A	N/A
	AGING (yrs)	40	40	N/A	2	--	
	SUBMERGENCE	N/A	--	N/A	N/A	N/A	N/A

NOTES:

1. Normal operating conditions.

REFERENCES:

- IE Bulletin 79-01B, Attachment 4, Section 4.3.
- Valcor report QR-52600-5940-2

FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION	OUTSTAND.
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.	METHOD	ITEMS
SYSTEM: Hydrogen Recombiner I.D. NO.: IV-3A COMPONENT: Solenoid Valve MANUFACTURER: Valcor MODEL NO.: V5-6200 FUNCTION: Hydrogen Recombiner Isolation Valve ACCURACY: N/A (% OF SPAN) SPEC: DEMON: SERVICE: Isolation Valve LOCATION: Pipe Penetration Area ABOVE FLOOD LEVEL: N/A YES NO	OPERATING TIME	30 Days	30 Days	--	2	N/A	N/A
	TEMPERATURE (°F)	104 Note 1	346	1	2	N/A	N/A
	PRESSURE (PSIG)	0 Note 1	113	1	2	N/A	N/A
	RELATIVE HUMIDITY (%)	60 Note 1	100	1	2	N/A	N/A
	CHEMICAL SPRAY	N/A	N/A	1	2	N/A	N/A-
	RADIATION (rads)	$3.6 \times 10^6$	$2 \times 10^8$	1	2	N/A	N/A
	AGING (yrs)	40	40	N/A	2	---	--
	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A	N/A

NOTES:

1. Normal operating conditions.

REFERENCES:

1. IE Bulletin 79-01B, Attachment 4, Section 4.3.
2. Valcor report QR-52600-5940-2.



FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION	OUTSTAND.
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.	METHOD	ITEMS
SYSTEM: Hydrogen Recombiner I.D. NO.: IV-5A COMPONENT: Solenoid Valve  MANUFACTURER: Valcor  MODEL NO.: V5-6200  FUNCTION: Hydrogen Recombiner Isolation Valve  ACCURACY: N/A (% OF SPAN) SPEC: DEMON:  SERVICE: Isolation Valve  LOCATION: Pipe Penetration Area  ABOVE FLOOD LEVEL: N/A YES NO	OPERATING TIME	30 Days	30 Days	--	2	N/A	N/A
	TEMPERATURE (°F)	104 Note 1	346	1	2	N/A	N/A
	PRESSURE (PSIG)	0 Note 1	113	1	2	N/A	N/A
	RELATIVE HUMIDITY (%)	60 Note 1	100	1	2	N/A	N/A
	CHEMICAL SPRAY	N/A	N/A	1	2	N/A	N/A
	RADIATION (rads)	$3.6 \times 10^6$	$2 \times 10^8$	1	2	N/A	N/A
	AGING (yrs)	40	40	N/A	2	--	--
	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A	N/A

NOTES:

1. Normal operating conditions.

REFERENCES:

1. IE Bulletin 79-01B, Attachment 4, Section 4.3.
2. Valcor report QR-52600-5940-2.

FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION METHOD	OUTSTAND. ITEMS
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.		
SYSTEM: Hydrogen Recombiner I.D. NO.: IV-2B COMPONENT: Solenoid Valve MANUFACTURER: Valcor MODEL NO.: V5-6200 FUNCTION: Hydrogen Recombiner Isolation Valve ACCURACY: N/A (% OF SPAN) SPEC: DEMON: SERVICE: Isolation Valve LOCATION: Pipe Penetration Area ABOVE FLOOD LEVEL: N/A YES NO	OPERATING TIME	30 Days	30 Days	--	2	N/A	N/A
	TEMPERATURE (°F)	104 Note 1	346	1	2	N/A	N/A
	PRESSURE (PSIG)	0 Note 1	113	1	2	N/A	N/A
	RELATIVE HUMIDITY (%)	60 Note 1	100	1	2	N/A	N/A
	CHEMICAL SPRAY	N/A	N/A	1	2	N/A	N/A
	RADIATION (rads)	$3.6 \times 10^6$	$2 \times 10^8$	1	2	N/A	N/A
	AGING (yrs)	40	40	N/A	2	--	--
	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A	N/A

NOTES:

1. Normal operating conditions.

REFERENCES:

1. IE Bulletin 79-01B, Attachment 4, Section 4.3.
2. Valcor report QR-52600-5940-2.

FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION METHOD	OUTSTAND. ITEMS
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.		
SYSTEM: Hydrogen Recombiner I.D. NO.: IV-3B COMPONENT: Solenoid Valve MANUFACTURER: Valcor MODEL NO.: V5-6200 FUNCTION: Hydrogen Recombiner Isolation Valve ACCURACY: N/A (% OF SPAN) SPEC: DEMON: SERVICE: Isolation Valve LOCATION: Pipe Penetration Area ABOVE FLOOD LEVEL: N/A YES NO	OPERATING TIME	30 Days		--	2	N/A	N/A
	TEMPERATURE (°F)	104 Note 1	346	1	2	N/A	N/A
	PRESSURE (PSIG)	0 Note 1	113	1	2	N/A	N/A
	RELATIVE HUMIDITY (%)	60 Note 1	100	1	2	N/A	N/A
	CHEMICAL SPRAY	N/A	N/A	1	2	N/A	N/A
	RADIATION (rads)	$3.6 \times 10^6$	$2 \times 10^8$	1	2	N/A	N/A
	AGING (yrs)	40	40	N/A	2	---	--
	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A	N/A

NOTES:

1. Normal operating conditions.

REFERENCES:

1. IE Bulletin 79-01B, Attachment 4, Section 4.3.
2. Valcor report QR-52600-5940-2.

FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION METHOD	OUTSTAND. ITEMS
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.		
SYSTEM: Hydrogen Recombiner I.D. NO.: IV-5B COMPONENT: Solenoid Valve MANUFACTURER: Valcor MODEL NO.: V5-6200 FUNCTION: Hydrogen Recombiner Isolation Valve ACCURACY: N/A (% OF SPAN) SPEC: DEMON: SERVICE: Isolation Valve LOCATION: Pipe Penetration Area ABOVE FLOOD LEVEL: N/A YES NO	OPERATING TIME	30 Days		--	2	N/A	N/A
	TEMPERATURE (°F)	104 Note 1	346	1	2	N/A	N/A
	PRESSURE (PSIG)	0 Note 1	113	1	2	N/A	N/A
	RELATIVE HUMIDITY (%)	60 Note 1	100	1	2	N/A	N/A
	CHEMICAL SPRAY	N/A	N/A	1	2	N/A	N/A
	RADIATION (rads)	$3.6 \times 10^6$	$2 \times 10^8$	1	2	N/A	N/A
	AGING (yrs)	40	40	N/A	2	--	--
	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A	N/A

NOTES:

1. Normal operating conditions.

REFERENCES:

1. IE Bulletin 79-01B, Attachment 4, Section 4.3.
2. Valcor report QR-52600-5940-2

Component:

TER Item #: 28A; 30; 31A,B&C; 32A&B; 29A,B; 33

Device: Position Switches

28A NAMCO EA-180

30 NAMCO SL3

31A,B,C NAMCO D2400X

32A Micro Switch EXD-AR

32B Micro Switch Exhar-3

29A,B Micro Switch BZE62RN

33 Micro Swtich OPD-AR 6923

Location: Various

Deficiency:

QI, A, T, P, S

Interim Justification:

N/A

Final Resolution:

Indian Point 2 has verified that these switches provide position indication only and that the operator does not require this information to perform a safety function.

Component:

TER Item #: 34A  
Device: Auxiliary Feedwater Pump Drive  
Manufacturer: Westinghouse Motor 509 US Frame  
Location: Auxiliary Pump Room

Deficiency:

QI

Interim Justification:

Indian Point 2 has established that these motors are several feet away from any potential pipe break and would not be subjected to direct impingement during the short period of time required to isolate the break.

The Auxiliary Pump Room is protected by a temperature switch which actuates at 135°F to isolate the steam to the auxiliary feed pump. Once this switch actuates the conditions in the room should quickly return to normal in case of an accident. The calculations performed showing 0.9 psig and a saturation temperature of 215°F assume that the temperature switch fails to operate and that the leak remains unisolated.

Even though this temperature switch is presently unqualified, it is felt that in the interim, its operation can be relied upon due to the low actuation temperature setpoint of 135°F. Assuming that this switch does operate in the event of a steam leak, the room conditions should not greatly exceed the 135°F setpoint.

Final Resolution:

The temperature switch relied upon in this accident will be qualified, replaced or modified to ensure its operation prior to June 30, 1982.

The licensee is also evaluating the effect on 1E equipment of the temperature excursion expected in this area as a result of a steam line break. Additional action will be taken by the licensee based on the results of this study. It is anticipated that the results will confirm the belief that the rupture will be isolated by the temperature switches before the critical components of the 1E devices become elevated to temperatures that will affect their operability.

FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION	OUTSTAND.
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.	METHOD	ITEMS
SYSTEM: Auxiliary	OPERATING TIME	----	--	---	--	N/A	N/A
I.D. NO.: COMPONENT: Motor	TEMPERATURE (°F)	135	Note 1	1	N/A	N/A	N/A
MANUFACTURER: Westinghouse	PRESSURE (PSIG)	0	N/A	1	2	N/A	N/A
MODEL NO.: 509 US Frame	RELATIVE HUMIDITY (%)	100	100	1	N/A	N/A	N/A
FUNCTION: Auxiliary Feed Pump Drive	CHEMICAL SPRAY	N/A	N/A	1	2	N/A	N/A
ACCURACY: N/A (% OF SPAN) SPEC: DEMON:	RADIATION (rads)	N/A	$2 \times 10^8$	1	2	Type Test & Analysis	N/A
SERVICE: Feed Pump Motor	AGING (yrs)	40	40 Yrs.	N/A	2	Type Test & Analysis	N/A
LOCATION: Auxiliary Pump Room	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A	N/A
ABOVE FLOOD LEVEL: N/A YES NO							

NOTES:

1. A short excursion above ambient will not degrade the insulation as qualified in WCAP 8754.

REFERENCES:

1. Analysis of high energy lines in letter Trosten to Giambusso of 4-14-73.
2. Westinghouse Report WCAP-8754



Component:

TER Item #: 37A  
Device: Transducer  
Manufacturer: Foxboro  
Model: 69TA1  
Location: Auxiliary Pump Room

Deficiency:

QI

Interim Justification:

Indian Point 2 has established that this transducer is several feet away from any potential pipe break and would not be subjected to direct impingement during the short period of time required to isolate the break.

The Auxiliary Pump Room is protected by a temperature switch which actuates at 1350F to isolate the steam to the auxiliary feed pump. Once this switch actuates the conditions in the room should quickly return to normal in case of an accident. The calculations performed showing 0.9 psig and a saturation temperature of 2150F assume that the temperature switch fails to operate and that the leak remains unisolated.

Even though this temperature switch is presently unqualified, it is felt that in the interim, its operation can be relied upon due to the low actuation temperature setpoint of 1350F. Assuming that this switch does operate in the event of a steam leak, the room conditions should not greatly exceed the 1350F setpoint.

Final Resolution:

The temperature switch relied upon in this accident will be qualified, replaced or modified to ensure its operation prior to June 30, 1982.

The licensee is also evaluating the effect on 1E equipment of the temperature excursion expected in this area as a result of a steam line break. Additional action will be taken by the licensee based on the results of this study. It is anticipated that the results will confirm the belief that the rupture will be isolated by the temperature switches before the critical components of the 1E devices become elevated to temperatures that will affect their operability.

37A  
 FACILITY: Indian Point 2  
 DOCKET:

SYSTEM COMPONENT EVALUATION  
 WORK SHEET

ENCLOSURE  
 79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION	OUTSTAND.
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.	METHOD	ITEMS
SYSTEM:	OPERATING TIME	30 days	N/A	--	--	N/A	N/A
I.D. NO.: COMPONENT: Transducer	TEMPERATURE (°F)	135	N/A	1	--	N/A	N/A
MANUFACTURER: Foxboro	PRESSURE (PSIG)	0	N/A	1	--	N/A	N/A
MODEL NO.: 69TA1	RELATIVE HUMIDITY (%)	100	Note 1	1	--	N/A	N/A
FUNCTION:	CHEMICAL SPRAY	N/A	N/A	1	--	N/A	N/A
ACCURACY: (% OF SPAN) SPEC: DEMON:	RADIATION (rads)	N/A	N/A	1	--	N/A	N/A
SERVICE:	AGING (yrs)	40	--	N/A	--	--	--
LOCATION: Auxiliary Pump Room	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A	N/A
ABOVE FLOOD LEVEL: YES NO							

NOTES:

1. A short excursion above ambient is considered to have a negligible effect.

REFERENCES:

1. Analysis of high energy lines in letter Trosten to Giambusso of 5-14-73.

Component:

TER Item #: 38  
Device: Terminal Blocks  
Manufacturer: Westinghouse  
Model: 542247  
Location: Inside Containment

Deficiency:

QM, A

Interim Justification:

Existing data on the wood-flour-reinforced phonolic material used for these terminal blocks does not indicate any degradation in electrical properties due to thermal aging or a radiation dose less than 20 M rads gamma. To reduce the probability of conductance between terminals during a HELB the terminal blocks will be periodically cleaned. At this time the blocks will be inspected for possible aging degradation. The steam test (FIRL# F-C4911-1) indicates that satisfactory performance may be expected for protected terminal blocks. Resilient washers will be installed under the blocks to preclude any cracking of the block while mounting or connecting to the block. The above information provides sufficient justification for continued usage of these terminal blocks.

Final Resolution

The resolution of the deficiencies associated with these terminal blocks is ongoing. Appropriate action will be taken once these deficiencies are resolved. The resilient washers will be installed, and an inspection and evaluation of the necessity for cleaning will be made at the same time.

FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION METHOD	OUTSTAND. ITEMS
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.		
SYSTEM: Various	OPERATING TIME	30 days	24 HR. Note 3	---	3	Type Test Sequential	N/A
I.D. NO.: COMPONENT: Terminal Blocks	TEMPERATURE (°F)	287	285	1	3	Type Test Sequential	N/A
MANUFACTURER: Westinghouse	PRESSURE (PSIG)	40	40	1	3	Type Test Sequential	N/A
MODEL NO.: 542247(805432)	RELATIVE HUMIDITY (%)	100	100	1	3	Type Test Sequential	N/A
FUNCTION: Electrical Connections	CHEMICAL SPRAY	Note 1	--	1	--	--	Note 2
ACCURACY: N/A (% OF SPAN) SPEC: DEMON:	RADIATION (rads)	1.4x10 <sup>7</sup>	--	2	3	--	Note 4
SERVICE: Electrical Connections	AGING (yrs)	40	--	N/A	N/A	N/A	Note 4
LOCATION: Inside Containment	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A	N/A
ABOVE FLOOD LEVEL: YES X NO							

NOTES:

- 2000 PPM boric acid spray with 40% NaOH to result in 10.0 ph.
- Chemical spray not part of test.
- Successful test conducted at maximum conditions, equivalent to 16 days using Arrhenius Techniques with 0.5 ev and 160°F ambient.
- See interim justification

REFERENCES:

- FSAR Section 14.3.
- IE Bulletin 79-01B, Attachment 4, Section 4.1.2.
- Franklin Report F-C4911-1

Component:

TER Item #: 39:

Device: Containment Penetrations

Model: Crouse-Hinds/Westinghouse

Function: Electrical Cable Penetrations

Location: Inside Containment

Deficiency:

Interim Justification:

Interim operation is justified based on the fact that qualification testing done in report PEN-TR-81-37 is applicable to the ceramic bushing sealed type penetrations used in Indian Point 2. Testing as specified and performed under Crouse-Hinds Report of 3/30/67 on canister samples indicate satisfactory electrical and leak tight performance during LOCA temperature and pressure conditions. The documentation review for aging is ongoing. Interim operation is justified based on the fact that aging is a long term parameter and should not adversely affect equipment operability until the question is more fully resolved. In addition to the material evaluation being conducted, Indian Point 2 will establish an ongoing program to review the surveillance and maintenance records of the plant in order to identify equipment degradation which may be age related.

Final Resolution:

Original penetration qualification was addressed in previous responses to IE Bulletin 77-06 dated December 2, 1977 and January 30, 1978. Additional penetration information was included in the October 31, 1980 and January 5, 1981 supplements to the Indian Point 2 equipment qualification report.

It is felt by Indian Point 2 that the above referenced information is adequate to demonstrate qualification for these penetrations.

In addition, Franklin Research Center (FRC) has found the Crouse-Hinds Electrical Cable Penetrations in the Ginna Plant to be environmentally qualified. Con Edison makes reference to the Rochester Gas & Electric Company references on penetrations listed in the FRC Technical Evaluation Report for the Ginna Plant, particularly Reference 2-59, "Aging Effects on Crouse-Hinds Penetration Materials" (30 Oct 80). These references are already in the possession of FRC. Con Edison has reviewed the environmental qualification parameters for the Ginna Plant and found them to envelope Indian Point Unit No. 2 (in containment).

FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION	OUTSTAND.
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.	METHOD	ITEMS
SYSTEM: Containment Penetrations I.D. NO.: COMPONENT: Electrical Penetrations MANUFACTURER: Westinghouse MODEL NO.: WX31864 FUNCTION: Containment Seal at Electrical Penetration ACCURACY: N/A (% OF SPAN) SPEC: DEMON: SERVICE: Electrical/Control Cable Penetrations LOCATION: Inside/Outside Containment ABOVE FLOOD LEVEL: YES X NO	OPERATING TIME	30 days	21 Days	--	3,4	Type Test Simultaneous	Note 2
	TEMPERATURE (°F)	287	340	1	3,4	Type Test Simultaneous	N/A
	PRESSURE (PSIG)	40	56	1	3,4	Type Test Simultaneous	N/A
	RELATIVE HUMIDITY (%)	100	100	1	3,4	Type Test Simultaneous	N/A
	CHEMICAL SPRAY	Note 1	none	1	none	N/A	N/A
	RADIATION (rads)	$.6 \times 10^8$	$1.25 \times 10^8$	2	3,4	Type Test Simultaneous	N/A
	AGING (yrs)	40	40	N/A	3,4	Type Test Simultaneous	N/A
	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A	N/A

NOTES:

- 2000 PPM boric acid spray with 40% NaOH to result in 10.0 ph.
- Total qualification time based on test reported in Ref. 3 and using a conservative activation energy of  $0.5 \text{ eV}$  in the Arrhenius equation to extrapolate from the required envelope of 287°F for one hour and 160°F for the remainder of the period.

REFERENCES:

- FSAR Section 14.3.
- IE Bulletin 79-01B, Attachment 4, Section 4.1.2.
- Westinghouse Report PEN-TR-81-37.
- Westinghouse Report PEN-RLK-3-16-01 and Addendum to PEN-RLK-3-16-01.



FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION	OUTSTAND.
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.	METHOD	ITEMS
SYSTEM: Containment Penetration	OPERATING TIME	30 days	Note 3	--	3, 4	Type Test Simultaneous	Note 3
I.D. NO.: COMPONENT: Electrical Penetration	TEMPERATURE (°F) note 2	287	320	1	3, 4	Type Test Simultaneous	N/A
MANUFACTURER: Crouse Hinds	PRESSURE (PSIG) note 2	40.6	90	1	3, 4	Type Test Simultaneous	N/A
MODEL NO.:	RELATIVE HUMIDITY (%)	100	100	1	3, 4	Type Test Simultaneous	N/A
FUNCTION: Containment Seal at Electrical Penetration	CHEMICAL SPRAY	Note 1	--	1	3, 4	Type Test Simultaneous	Note 2
ACCURACY: N/A (% OF SPAN) SPEC: DEMON:	RADIATION (rads)	.6 x 10 <sup>8</sup>	--	2	3, 4	--	Note 2
SERVICE: Electrical/Control Cable Penetration	AGING (yrs)	40	--	N/A	3, 4	--	Note 2
LOCATION: Inside/Outside Containment	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A	N/A
ABOVE FLOOD LEVEL: YES NO							

NOTES:

- 1, 2000 PPM boric acid spray with 40% NaOH to result in 10.0 ph.
2. Pressure retaining are inorganic materials.
3. Leakage test for 100 minutes.
4. Chemical spray not part of leakage test.

REFERENCES:

1. FSAR Section 14.3.
2. IE Bulletin 79-0115, Attachment 4, Section 4.1.2.
3. Westinghouse Report PEN-TR-81-44.
4. IP2 letter to NRC Cahill to Varga May 9, 1980, Ref. 7.

Component:

TER Item #: 40C  
Device: Cable/Splice  
Manufacturer: GE/Ray Chem  
Model: NA  
Location: In Containment

Deficiency:

QI, A, R

Interim Justification:

Samples of cable were removed from Indian Point 2 and were tested under different programs run by both Westinghouse and the different cable manufacturers. This justification summarizes these tests as well as establishes traceability for manufacturers versus test.

During all of the tests only one failure was reported. This was described in the Westinghouse test report in WCAP-7410L Volume 2 of 2. This failure resulted from apparent steam impingement on the cable splice. Since steam impingement is not a failure on field mounted cables, this failure was not considered relevant.

The test conditions are as follows:

Note: all tests are summarized

1. HELB (WCAP-7410L)

Steam and Chemical Environment

Pressure = 80 psig

Temperature = 300°F

Time = 200 hours, 68 hours at a steam pressure higher than  
containment design pressure

1.5 weight percent boric acid with NaOH added to yield a pH of 9.25.

2. Radiation and Steam (WCAP-7410L)

Gamma -  $2.8 \times 10^7$  Rads followed by exposure to a steam environment of 85 psig for 2(two) - 30 minute cycles.

3. Aging, Steam and Radiation (WCAP-7410L)

40 year equivalent followed by 4 hours of steam at 287°F and 60 psig followed by irradiation exposure to  $2 \times 10^8$  Rads.

4. Radiation and steam (Franklin Institute Report #F-C2442-02)4.

Gamma  $2.5 \times 10^7$  Rads  
328°F, 85 psig

5. Submergence (Phelps-Dodge R&D Report #10519)

Submerged in simulated river water for 2 weeks.  
IR tests -  $4 \times 10^6$  megohms.  
DC withstand test - 18 KVdc for 15 minutes and 6 KVdc for 5 minutes

6. Radiation and HELB (Franklin Institute Report #F-C2781)

100 MRAD gamma radiation followed by steam and chemical environment

Pressure = 50 psig  
Temperature = 298°F  
Time = 7 days (12 hours at a steam pressure and temperature)

7. Steam and Chemical Spray (Raychem Thermofit Report 71100 Rev. 1)

(250°F, 21 psig, 0.2% Boric Acid Spray for 24 hours).

NOTE: Tests 1 through 4 apply to Kerite cables  
Tests 1 through 5 apply to GE cables  
Test 6 applies to Lewis cables  
Tests 1 through 7 apply to Raychem splices

The above test data provides sufficient justification for interim operation since no absolute failures occurred as a result of anticipated environmental conditions.

Final Resolution:

The tests reported in WCAP-7410L demonstrate the capability of this cable/splice combination to survive accident conditions in an aged condition. Radiation tests exceeding the requirement were also performed before and after high energy line break test simulations. The successful submergence test was performed on an 8 - 10 year old cable removed from the site for this purpose.

FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION	OUTSTAND.
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.	METHOD	ITEMS
SYSTEM: Electrical I.D. NO.: COMPONENT: Cable/Splice MANUFACTURER: GE /Raychem MODEL NO.: Note 4 FUNCTION: ACCURACY: (% OF SPAN) SPEC: DEMON: SERVICE: LOCATION: Inside Containment	OPERATING TIME	30 days	70 days Note 2	—	3	Seperate Test	N/A
	TEMPERATURE (°F)	287	300	1	3	Simultaneous Test	N/A
	PRESSURE (PSIG)	40	80	1	3	Simultaneous Test	N/A
	RELATIVE HUMIDITY (%)	100	100	1	3	Simultaneous Test	N/A
	CHEMICAL SPRAY	Note 1	Note 3	1	3	Simultaneous Test	N/A
	RADIATION (rads)	$1.2 \times 10^8$	$2 \times 10^8$	2	3	Seperate Test	NA
	AGING (yrs)	40	40 yrs	N/A	3	Seperate Test	N/A
	SUBMERGENCE	assumed	Ref 4	N/A	4	none	N/A

NOTES:

- 2000 PPM boric acid spray with NaOH to result in 10.0 ph.
- Based on test reported in WCAP-7410L of 486 hrs. at 214F (steam) and using 0.5 ev and an ambient of 160F in the Arrhenius equation.
- 1.5 percent of boric acid (by weight) in water and adding sodium hydroxide to buffer the ph to a value of 9.25.
- Submergence test performed as GE cables and Raychem splices.
- 600 V Power & Control multi-conductor #12 Kerite Insulation w/pair braid zinc tape kerite jacket

REFERENCES:

- FSAR Section 14.3.
- IE Bulletin 79-01B, Attachment 4, Section 4.1
- WCAP-7410L
- Phelps-Dodge R&D report #10519.

Component:

TER Item #: 42B  
Device: Hydrogen Recombiners  
Model: Flame Type  
Function: Remove Hydrogen from Containment Environment  
Location: Inside Containment

Deficiency:

QI, QM, A

Interim Justification:

Continued operation of the H<sub>2</sub> Recombiner is justified by the following test:

1) WCAP-7410L Vol. 2

A) Ignitor Excitor

The unit performed satisfactorily after three separate radiation exposures totalling  $3.23 \times 10^8$  rads gamma demonstrating a one year post accident capability with margin. Following these tests the unit was exposed to a steam environment (285°F, 55 psig) for two hours followed by 22 hours at 220°F and 20 psig and three weeks at 155°F and slightly above atmospheric pressure with satisfactory performance.

B) Blower Motor

A 2 HP 3 PH 230/460V motor with class H insulation constructed in the same manner as the actual 15 HP motor was subjected to the following tests:

1) Radiation -  $2 \times 10^8$  rads gamma

- 2) Thermal Aging - aged at 240°C for 120 hours which is equivalent to seven years of continuous operation at 150°C assuming a 100°C rise per half life. This test included a 3KV surge and a 220V no-load operation for two hours.
- 3) Steam tests - the motor was subjected to the same environment as the excitor with satisfactory performance.

2) WCAP-9001

A) Ignitor and thermocouple

These components do not contain any organic materials and will not be affected by the environment.

B) Wiring

Both the ignition lead and the thermocouple are completely housed in a pressure tight system with the connections field brazed.

3) WCAP-7301L

This test demonstrates the proper operation of the recombiner from 55% to 175% of the design basis with a one gallon per minute water mist being introduced into the combustor section.

Final Resolution:

The information contained in the above reports demonstrates that the Hydrogen Recombiner can be expected to be available and perform satisfactorily for one year post accident with the possible exception of the Barksdale Flow Switch. Qualification data will be established for this switch or a qualified replacement will be provided.

FACILITY: Indian Point 2  
 DOCKET:

SYSTEM COMPONENT EVALUATION  
 WORK SHEET

ENCLOSURE  
 79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION	OUTSTAND.
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.	METHOD	ITEMS
SYSTEM: Hydrogen Recombiner	OPERATING TIME	30 days	Note 2	--	--	--	--
I.D. NO.: COMPONENT: Thermocouple	TEMPERATURE (°F)	287	Note 2	1	--	--	--
MANUFACTURER: Westinghouse	PRESSURE (PSIG)	40.6	Note 2	1	--	--	--
MODEL NO.: A-2092	RELATIVE HUMIDITY (%)	100	Note 2	1	--	--	--
FUNCTION: Hydrogen Recombiner Exhaust Temp. Indication	CHEMICAL SPRAY	Note 1	Note 2	1	--	--	--
ACCURACY: N/A (% OF SPAN) SPEC: DEMON:	RADIATION (rads)	1.54 x 10 <sup>8</sup>	Note 2	2	--	--	--
SERVICE: Exhaust Temperature Indication	AGING (yrs)	40	Note 2	N/A	--	--	--
LOCATION: Inside Containment	SUBMERGENCE	N/A	Note 2	N/A	--	--	--
ABOVE FLOOD LEVEL: YES X NO							

NOTES:

- 2000 PPM boric acid spray with 40% NaOH to result in 10.0 ph.
- Thermocouple contains no organic materials and will not be effected by the environment per drawing A-2092.

REFERENCES:

- FSAR Section 14.3.
- IE Bulletin 79-01B, Attachment 4, Section 4.1.2.



FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION METHOD	OUTSTAND. ITEMS
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.		
SYSTEM: Hydrogen Recombiner I.D. NO.: COMPONENT: Fan Blower Motor MANUFACTURER: Westinghouse MODEL NO.: FUNCTION: Air Handling for Hydrogen Recombiner ACCURACY: N/A (% OF SPAN) SPEC: DEMON: SERVICE: Hydrogen Control in Containment Air LOCATION: In Containment ABOVE FLOOD LEVEL: YES X NO	OPERATING TIME	30 days	2 hours 1 year	1	3	Type Test Sequential	N/A
	TEMPERATURE (°F)	287	220 155	1	3	Type Test Sequential	N/A
	PRESSURE (PSIG)	40 .6	55 5	1	3	Type Test Sequential	N/A
	RELATIVE HUMIDITY (%)	100	100	1	3	Type Test Sequential	N/A
	CHEMICAL SPRAY	Note 1	Note 2	1	3	Type Test Sequential	N/A
	RADIATION (rads)	$1.54 \times 10^8$	$2 \times 10^8$	2	3	Type Test Separate	N/A
	AGING (yrs)	40	40 Note 3	N/A	3	Type Test Sequential	N/A
	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A	N/A

NOTES:

- 2000 PPM boric acid spray with 40% NaOH to result in 10.0 ph.
- 1.5% Boric acid spray with NaOH to result in 9.25 ph.
- 40 Yr. life based on occasional use of H<sub>2</sub> recombinder and testing which indicates satisfactory operation for a continuous duty of 7 yrs.

REFERENCES:

- FSAR Section 14.3.
- IE Bulletin 79-01B, Attachment 4, Section 4.1.2.
- Westinghouse Report WCAP-7410L

FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION	OUTSTAND.
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.	METHOD	ITEMS
SYSTEM: Hydrogen Recombiner	OPERATING TIME	30 Days	Note 2	--	--	--	--
I.D. NO.: COMPONENT: Flow Switch	TEMPERATURE (°F)	287	Note 2	1	--	--	--
MANUFACTURER: Barksdale	PRESSURE (PSIG)	40.6	Note 2	1	--	--	--
MODEL NO.:	RELATIVE HUMIDITY (%)	100	Note 2	1	--	--	--
FUNCTION: Air Handling for Hydrogen Recombiner	CHEMICAL SPRAY	NOTE 1	Note 2	1	--	--	--
ACCURACY: N/A (% OF SPAN) SPEC: DEMON:	RADIATION (rads)	1.54x 10 <sup>8</sup>	Note 2	2	--	--	--
SERVICE: Hydrogen Control in Containment	AGING (yrs)	40	Note 2	N/A	--	--	--
LOCATION: Inside Containment	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A	N/A
ABOVE FLOOD LEVEL: YES X NO							

NOTES:

- 2000 PPM boric acid spray with 40% NAOH to result in 10.0 ph.
- Equipment qualification to latest standards has not been performed.

REFERENCES:

- FSAR Section 14.3.
- IE Bulletin 79-01B, Attachment 4, Section 4.1.2.

FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION	OUTSTAND.
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.	METHOD	ITEMS
SYSTEM: Hydrogen Recombiner	OPERATING TIME	30 days	2 hours / 3 wks	—	3	Type Test Sequential	N/A
I.D. NO.: COMPONENT: Ignitor Excitor	TEMPERATURE (°F)	287	285	1	3	Type Test Sequential	N/A
MANUFACTURER: Westinghouse	PRESSURE (PSIG)	40.6	55	1	3	Type Test Sequential	N/A
MODEL NO.: GLA43737	RELATIVE HUMIDITY (%)	100	100	1	3	Type Test Sequential	N/A
FUNCTION: Ignition of Burner in Hydrogen Recombiner	CHEMICAL SPRAY	Note 1	---	1	---	---	---
ACCURACY: N/A (% OF SPAN) SPEC: DEMON:	RADIATION (rads)	$1.54 \times 10^8$	$3.23 \times 10^8$	2	3	Type Test Separate	N/A
SERVICE: Hydrogen Control in Containment Air	AGING (yrs)	40	40 Note 2	N/A	3	Type Test Separate	N/A
LOCATION: Inside Containment	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A	N/A
ABOVE FLOOD LEVEL: YES X NO							

NOTES:

1. 2000 PPM boric acid spray with 40% NaOH to result in 10.0 ph.

2. 40 yr. life obtained through maintenance program.

REFERENCES:

1. FSAR Section 14.3.
2. IE Bulletin 79-01B, Attachment 4, Section 4.1.2.
3. Westinghouse Report WCAP-7410L.

Component:

TER Item #:

Device: Temperature Switch

Manufacturer: United Electric Control

Model: Type D-5 MOD 74

Location: Auxiliary Pump Room.

Deficiency:

This unqualified device is relied upon to isolate steam to the Auxiliary Pump Room in case of a steam leak.

Interim Justification:

This device is set to actuate at a low temperature of 135°F and should actuate before extremely harsh conditions develop in this area.

Final Resolution:

This device will be replaced, qualified, or modified to ensure its operation prior to June 30, 1982.

FACILITY: Indian Point 2  
DOCKET:

SYSTEM COMPONENT EVALUATION  
WORK SHEET

ENCLOSURE  
79-01B

EQUIPMENT DESCRIPTION	ENVIRONMENT			DOC. REF.		QUALIFICATION	OUTSTAND.
	PARAMETER	SPECIFICATION	QUALIFICATION	SPEC.	QUAL.	METHOD	ITEMS
SYSTEM: Auxiliary Feedwater	OPERATING TIME	30 Days	Note 1	--	--	--	--
I.D. NO.: COMPONENT: Temperature Switch	TEMPERATURE (°F)	135	Note 1	1	--	--	--
MANUFACTURER: United Electric Controls	PRESSURE (PSIG)	0	Note 1	1	--	--	--
MODEL NO.: Type D-5 MOD 74	RELATIVE HUMIDITY (%)	100	Note 1	1	--	--	--
FUNCTION: Aux Feedpump Turbine Isolation	CHEMICAL SPRAY	N/A	Note 1	1	--	--	--
ACCURACY: (% OF SPAN) SPEC: N/A DEMON:	RADIATION (rads)	N/A	Note 1	1	--	--	--
SERVICE: Temp. Sensor	AGING (yrs)	40	Note 1		--	--	--
LOCATION: Auxiliary Pump Room	SUBMERGENCE	N/A	N/A	N/A	N/A	N/A	N/A
ABOVE FLOOD LEVEL: N/A YES NO							

NOTES:

- Equipment qualification to latest standards has not been performed.

REFERENCES:

- Analysis of high energy lines in letter Tosten to Giambusso 5/14/73.

## APPENDIX C

The documentation review for aging is ongoing. Interim operation is justified based on the fact that aging is a long term parameter and should not adversely affect equipment operability until the question is more fully resolved. In addition to the material evaluation being conducted, Indian Point 2 will establish an ongoing program to review the surveillance and maintenance records of the plant in order to identify equipment degradation which may be age related. A maintenance program will be established which, in conjunction with the surveillance program and materials study results, will lead to the establishment of a replacement schedule for equipment that is qualified for less than the life of the plant. This replacement schedule will be developed and provided to the staff as soon as it becomes available.

ATTACHMENT 2

Environmental Qualification

Cold Shut-Down Report

Consolidated Edison Company of New York, Inc.  
Indian Point Unit No. 2  
Docket No. 50-247  
Facility Operating License No. DPR-26  
September, 1981

WESTINGHOUSE SUPPLIED ELECTRICAL EQUIPMENT TO BE USED FOR COLD SHUTDOWN

EQUIPMENT	LOCATION	MANUFACTURER TYPE/MODEL	ABNORMAL/ ACCIDENT PARAMETER	EXTREMES QUALIFIED	OPERABILITY REQUIRED	QUALIFIED LIFE	METHOD	QUAL. REF.
<u>TRANSMITTERS</u>								
Containment Pressure Transmitter	Outside Containment	Barton 752 Lot 3	Temperature Pressure Rel. Humidity Radiation Chemistry	130°F Atmos. 95% < 10 <sup>4</sup> R(γ) None	Continuous	5 yrs	Seq. Test	ESE-2
Sump Level Transmitter	Inside Containment	Barton 764 Lot 4	Temperature Pressure Rel. Humidity Radiation Chemistry	420°F 57 psig 100% 5x10 <sup>7</sup> R(γ)+9x10 <sup>8</sup> R(β) 2500 ppm H <sub>3</sub> BO <sub>3</sub> - NaOH to 10.7 pH	Post DBE 4 months	10 yrs	Seq. Test	ESE-3
Boric Acid Tank Level	Outside Containment	Barton 752 Lot 3	Temperature Pressure Rel. Humidity Radiation Chemistry	130°F Atmos. 95% < 10 <sup>4</sup> R(γ) None	Continuous	5 yrs	Seq. Test	ESE-4



WESTINGHOUSE SUPPLIED ELECTRICAL EQUIPMENT TO BE USED FOR COLD SHUTDOWN

EQUIPMENT	LOCATION	MANUFACTURER TYPE/MODEL	ABNORMAL/ ACCIDENT PARAMETER	EXTREMES QUALIFIED	OPERABILITY REQUIRED	QUALIFIED LIFE	METHOD	QUAL. REF.
<u>TRANSMITTERS</u>								
Steam Line Pressure Transmitter	Outside Containment	Barton 753 Lot 3	Temperature Pressure Rel. Humidity Radiation Chemistry	130°F 57 psig 95% 5x10 <sup>7</sup> R(γ) None	Continuous	5 yrs	Seq. Test	ESE-4
Steam Gener- ator Level Transmitter	Containment Bldg/Outside Missile Shield	Barton 764 Lot 4	Temperature Pressure Rel. Humidity Radiation Chemistry	420°F 57 psig 100% 5x10 <sup>7</sup> R(γ) 9x10 <sup>8</sup> R(β) 2500 ppm H <sub>3</sub> BO <sub>3</sub> - NaOH to 10.7 pH	Trip < 5 min	10 yrs	Seq. Test	ESE-3
Pressurizer Level Transmitter	Containment Bldg/Outside Missile Shield	Barton 764 Lot 4	Temperature Pressure Rel. Humidity Radiation Chemistry	420°F 57 psig 100% 5x10 <sup>7</sup> R(γ)+9x10 <sup>8</sup> R(β) 2500 ppm H <sub>3</sub> BO <sub>3</sub> - NaOH to 10.7 pH	Post DBE 4 months	10 yrs	Seq. Test	ESE-3
Pressurizer Pressure Transmitter	Containment Bldg/Outside Missile Shield	Barton 763 Lot 4	Temperature Pressure Rel. Humidity Radiation Chemistry	420°F 57 psig 100% 5x10 <sup>7</sup> R(γ)+9x10 <sup>8</sup> R(β) 2500 ppm H <sub>3</sub> BO <sub>3</sub> - NaOH to 10.7 pH	Trip 5 min	10 yrs	Seq. Test	ESE-1

WESTINGHOUSE SUPPLIED ELECTRICAL EQUIPMENT TO BE USED FOR COLD SHUTDOWN

EQUIPMENT	LOCATION	MANUFACTURER TYPE/MODEL	ABNORMAL/ ACCIDENT PARAMETER	EXTREMES QUALIFIED	OPERABILITY REQUIRED	QUALIFIED LIFE	METHOD	QUAL. REF.
<u>VALVES</u>								
Safety Injection Suction Isolation Valves MOV-887A,B	SI. Out. Containment	Limiterorque SMB-00 B-Insulation	Temperature Pressure Rel. Humidity Radiation Chemistry	50 - 120°F Atmos. 95% 2x10 <sup>8</sup> R(γ) None	30 days (Qualified)		Separate	(1) (5)
High Head Recirc. valves MOV-888A&B	PP Out. Containment	Limiterorque SMB-00 B-Insulation	Temperature Pressure Rel. Humidity Radiation Chemistry	50 - 120°F Atmos. 95% 2x10 <sup>8</sup> R(γ) None	30 days (Qualified)		Separate	(1) (5)
Refueling Water Storage Tank Disch. Valve MOV-1810	SI Out. Containment	Limiterorque SMB-00 B-Insulation	Temperature Pressure Rel. Humidity Radiation Chemistry	50 - 120°F Atmos. 95% 2x10 <sup>8</sup> R(γ) None	30 days (Qualified)		Separate	(1) (5)
Residual Heat Isolation Valve MOV-774	PP Out. Containment	Limiterorque SMB-1 B-Insulation	Temperature Pressure Rel. Humidity Radiation Chemistry	50 - 120°F Atmos. 95% 2x10 <sup>8</sup> R(γ) None	30 days (Qualified)		Separate	(1) (5)

WESTINGHOUSE SUPPLIED ELECTRICAL EQUIPMENT TO BE USED FOR COLD SHUTDOWN

EQUIPMENT	LOCATION	MANUFACTURER TYPE/MODEL	ABNORMAL/ ACCIDENT PARAMETER	EXTREMES QUALIFIED	OPERABILITY REQUIRED	QUALIFIED LIFE	METHOD	QUAL. REF.
<u>VALVES</u>								
High Head Injection Valve MOV- 856 A to F	Inside Containment	Limatorque SMB-00	Temperature Pressure Rel. Humidity Radiation Chemistry	300°F 70 psig 100% $2 \times 10^8$ R(γ) 2500 ppm H <sub>3</sub> BO <sub>3</sub> NaOH to 10.7 pH	30 days		Sequential	(1) (2) (3) (4)
Charcoal Filter Dousing Valves MOV- 880 A to H J to K	Inside Containment	Limatorque SMB-00	Temperature Pressure Rel. Humidity Radiation Chemistry	300°F 70 psig 100% $2 \times 10^8$ R(γ) 2500 ppm H <sub>3</sub> BO <sub>3</sub> NaOH to 10.7 pH	30 days		Sequential	(1) (2) (3) (4)
Recirculation Pump Discharge Valves MOV- 1802 A & B	Inside Containment	Limatorque SMB-00	Temperature Pressure Rel. Humidity Radiation Chemistry	300°F 70 psig 100% $2 \times 10^8$ R(γ) 2500 ppm H <sub>3</sub> BO <sub>3</sub> NaOH to 10.7 pH	30 days		Sequential	(1) (2) (3) (4)

WESTINGHOUSE SUPPLIED ELECTRICAL EQUIPMENT TO BE USED FOR COLD SHUTDOWN

EQUIPMENT	LOCATION	MANUFACTURER TYPE/MODEL	ABNORMAL/ ACCIDENT PARAMETER	EXTREMES QUALIFIED	OPERABILITY REQUIRED	QUALIFIED LIFE	METHOD	QUAL. REF.
<u>VALVES</u>								
Safety Injection System Mini-Flow Iso. Valves MOV-842 & 843	SI Outside Containment	Limiterque SMB-00 B-Insulation	Temperature Pressure Rel. Humidity Radiation Chemistry	50 - 120°F Atmos. 95% 2x10 <sup>8</sup> R(Y) None	30 days (Qualified)		Separate	(1) (5)
High Head Safety Injection Discharge Valves MOV-851 A & B	SI Outside Containment	Limiterque SMB-00 B-Insulation	Temperature Pressure Rel. Humidity Radiation Chemistry	50 - 120°F Atmos. 95% 2x10 <sup>8</sup> R(Y) None	30 days (Qualified)		Separate	(1) (5)
Residual Heat Exchanger Isolation Valves MOV-745 A & B	Inside Containment	Limiterque SMB-00 H-Insulation	Temperature Pressure Rel. Humidity Radiation Chemistry	300°F 70 psig 100% 2x10 <sup>8</sup> R(Y) Yes	30 days (Qualified)		Sequential	(1) (2) (3) (4)
Residual Heat Exchanger Isolation Valves MOV-746 & 747	Inside Containment	Limiterque SMB-2 H-Insulation	Temperature Pressure Rel. Humidity Radiation Chemistry	300°F 70 psig 100% 2x10 <sup>8</sup> R(Y) Yes	30 days (Qualified)		Sequential	(1) (2) (3) (4)

WESTINGHOUSE SUPPLIED ELECTRICAL EQUIPMENT TO BE USED FOR COLD SHUTDOWN

EQUIPMENT	LOCATION	MANUFACTURER TYPE/MODEL	ABNORMAL/ ACCIDENT PARAMETER	EXTREMES QUALIFIED	OPERABILITY REQUIRED	QUALIFIED LIFE	METHOD	QUAL. REF.
<u>VALVES</u>								
Residual Heat Exchanger Cooling Water Supply Valves MOV-822 A&B	Inside Containment	Limitorque SMB-00 B-Insulation	Temperature Pressure Rel. Humidity Radiation Chemistry	286°F 60 psig 100% 2x10 <sup>8</sup> R(Y) (Qualified) Yes	< 8 hrs.		Separate	(1) (5)
Reactor Coolant Pump Cooling Water Supply Valves MOV-797,769, 784,786,FCV- 625 & 789	PP Outside Containment	Limitorque SMB-00 B-Insulation	Temperature Pressure Rel. Humidity Radiation Chemistry	50 - 120°F Atmos. 95% 2x10 <sup>8</sup> R(Y) (Qualified) No	30 days		Separate	(1) (5)

REFERENCES

- (1) Westinghouse Electric Corp. WCAP 7410-L, Volume I & II, Topical Report: Environmental Testing of Engineered Safety Features Related Equipment, J. Locante, December, 1970.
- (2) Limitorque Corporation, Nuclear Power Station Qualification Type Test report. Limitorque valve actuators for PWR service project #600456, W. Sykes, December, 1975.
- (3) Westinghouse Electric Corp., letter NS-CE-692 from C. Eicheldinger to D.B. Vassalo, July 10, 1975.
- (4) Westinghouse Electric Corp., letter NS-CE-756 from C. Eicheldinger to D.B. Vassalo, August 15, 1975.
- (5) Limitorque Corporation, Qualification Type Test Report. Limitorque valve actuators for Class 1E service outside Primary Containment B0003.