

2009 KEWAUNEE POWER STATION

RETAKE EXAMINATION

ADMINISTRATIVE FILES

Facility: <u>Kewaunee Retake Exam</u>		Date of Examination: <u>8/6/2009</u>
Developed by: Written - Facility <input type="checkbox"/> NRC <input type="checkbox"/> // Operating - Facility <input checked="" type="checkbox"/> NRC <input type="checkbox"/>		
Target Date*	Task Description (Reference)	Chief Examiner's Initials
-180	1. Examination administration date confirmed (C.1.a; C.2.a and b)	RKW
-120	2. NRC examiners and facility contact assigned (C.1.d; C.2.e)	RKW
-120	3. Facility contact briefed on security and other requirements (C.2.c)	RKW
-120	4. Corporate notification letter sent (C.2.d)	RKW
[-90]	[5. Reference material due (C.1.e; C.3.c; Attachment 3)]	RKW
{-75}	6. Integrated examination outline(s) due, including Forms ES-201-2, ES-201-3, ES-301-1, ES-301-2, ES-301-5, ES-D-1's, ES-401-1/2, ES-401-3, and ES-401-4, as applicable (C.1.e and f; C.3.d)	RKW
{-70}	{7. Examination outline(s) reviewed by NRC and feedback provided to facility licensee (C.2.h; C.3.e)}	RKW
{-45}	8. Proposed examinations (including written, walk-through JPMs, and scenarios, as applicable), supporting documentation (including Forms ES-301-3, ES-301-4, ES-301-5, ES-301-6, and ES-401-6, and any Form ES-201-3 updates), and reference materials due (C.1.e, f, g and h; C.3.d)	RKW
-30	9. Preliminary license applications (NRC Form 398's) due (C.1.i; C.2.g; ES-202)	RKW
-14	10. Final license applications due and Form ES-201-4 prepared (C.1.i; C.2.i; ES-202)	RKW
-14	11. Examination approved by NRC supervisor for facility licensee review (C.2.h; C.3.f)	RKW
-14	12. Examinations reviewed with facility licensee (C.1.j; C.2.f and h; C.3.g)	RKW
-7	13. Written examinations and operating tests approved by NRC supervisor (C.2.i; C.3.h)	RKW
-7	14. Final applications reviewed; 1 or 2 (if >10) applications audited to confirm qualifications / eligibility; and examination approval and waiver letters sent (C.2.i; Attachment 5; ES-202, C.2.e; ES-204)	RKW
-7	15. Proctoring/written exam administration guidelines reviewed with facility licensee (C.3.k)	N/A
-7	16. Approved scenarios, job performance measures, and questions distributed to NRC examiners (C.3.i)	RKW
<p>* Target dates are generally based on facility-prepared examinations and are keyed to the examination date identified in the corporate notification letter. They are for planning purposes and may be adjusted on a case-by-case basis in coordination with the facility licensee. [Applies only] {Does not apply} to examinations prepared by the NRC.</p>		

1. Pre-Examination

I acknowledge that I have acquired specialized knowledge about the NRC licensing examinations scheduled for the week(s) of 08/03/2009 as of the date of my signature. I agree that I will not knowingly divulge any information about these examinations to any persons who have not been authorized by the NRC chief examiner. I understand that I am not to instruct, evaluate, or provide performance feedback to those applicants scheduled to be administered these licensing examinations from this date until completion of examination administration, except as specifically noted below and authorized by the NRC (e.g., acting as a simulator booth operator or communicator is acceptable if the individual does not select the training content or provide direct or indirect feedback). Furthermore, I am aware of the physical security measures and requirements (as documented in the facility licensee's procedures) and understand that violation of the conditions of this agreement may result in cancellation of the examinations and/or an enforcement action against me or the facility licensee. I will immediately report to facility management or the NRC chief examiner any indications or suggestions that examination security may have been compromised.

2. Post-Examination

To the best of my knowledge, I did not divulge to any unauthorized persons any information concerning the NRC licensing examinations administered during the week(s) of 08/03/2009. From the date that I entered into this security agreement until the completion of examination administration, I did not instruct, evaluate, or provide performance feedback to those applicants who were administered these licensing examinations, except as specifically noted below and authorized by the NRC.


	PRINTED NAME	JOB TITLE / RESPONSIBILITY	SIGNATURE (1)	DATE	SIGNATURE (2)	DATE NOTE
01.	Andrew Fahrenkrug	Exam Author	<i>[Signature]</i>	6/22/09	<i>[Signature]</i>	8/6/09
02.	Stephen Johnson	Exam Author	<i>[Signature]</i>	6/23/09	<i>[Signature]</i>	8/6/09
03.	David Schoeder	IT Support	<i>[Signature]</i>	6/23/09	<i>[Signature]</i>	8/11/09
04.	KAY Stangel	Admin Assistant	<i>[Signature]</i>	6/23/09	<i>[Signature]</i>	8/6/09
05*	DAVID SHIELDS	CHEMISTRY INSTRUCTOR	<i>[Signature]</i>	6-24-2009	<i>[Signature]</i>	8-10-2009
06.	Ethan Troplow	Facility Representative	<i>[Signature]</i>	6-30-09	<i>[Signature]</i>	8-10-09
07.	TERRY A EVANS	EXAM PROJECT MANAGER	<i>[Signature]</i>	6/23/09	<i>[Signature]</i>	8/11/09
08.	Jim PETERSON	EP SPECIALIST	<i>[Signature]</i>	6/23/09	<i>[Signature]</i>	8-11-09
09.	Charlotte Kleiman	Sim Support	<i>[Signature]</i>	6/30/09	<i>[Signature]</i>	8-11-09
10.	Craig Byall	Sim Support	<i>[Signature]</i>	6-30-09	<i>[Signature]</i>	8-11-09
11.	Mark Langer	Unit Supervisor	<i>[Signature]</i>	6-30-09	<i>[Signature]</i>	8/14/09
12.	MARK GOOLSBY	SHIFT MANAGER/FACILITY REP.	<i>[Signature]</i>	7-7-09	<i>[Signature]</i>	8/14/09
13.	Joe Stedola	US/SIA	<i>[Signature]</i>	7/7/09	<i>[Signature]</i>	8/11/09
14.	JIM ROZELL	Facility sim support	<i>[Signature]</i>	7-7-09	<i>[Signature]</i>	8/11/09
15.	TOM ARNETTE	UNIT SUPERVISOR	<i>[Signature]</i>	7/27/09	<i>[Signature]</i>	8/6/09

NOTES:

* NO BADGE ISSUED FOR SECURITY REASONS

Operating Test Comments (Kewaunee Retake Exam – 8/2009)

1. The licensee replaced Administrative JPM A.5 due to a potential exam security issue that was identified and later corrected by the licensee.
2. At onsite validation, JPM A.2, pg 9 of 11, Overtime Schedule, the last column was changed from "Today" to "Proposed Today." This change would prevent the applicant from believing that the shift was actually worked.
3. JPM A.4, Radiological Discharge Permit, Attachments A, B and C, "Tritium Concentration" value was changed from 0.6519 E-2 to 0.3951E-2 to ensure the diluted Tritium Concentration value would not exceed the Guideline of "less than 5.0 E-6uci/ml." The examiner was concerned that had the diluted Tritium Concentration value exceeded this guideline, that the applicant may halt the discharge altogether, even though discharges are allowed to exceed the guideline.



Raymond Keith Walton
Chief Examiner

The licensee did not submit any post-exam comments.

Raymond Keith Walton