




ASSISTANT SECRETARY OF DEFENSE
WASHINGTON, D. C. 20301

HEALTH AND ENVIRONMENT



17 SEP 1970

Mr. Harold L. Price
Director of Regulation
Atomic Energy Commission
Washington, D. C. 20545

Regulatory

File Cy.

Dear Mr. Price:

50-247

We have reviewed the Environmental Statement from the Consolidated Edison Company of New York, Inc. for the Indian Point Nuclear Generating Station Unit 2 as requested by your letter of August 17, 1970.


The following comments are provided:

1. Insufficient information is presented within the Statement regarding the environmental monitoring program. Sampling frequency should also be included as well as an indication of whether sampling frequency will be increased with the initial operation of Unit No. 2 at the Indian Point Site.

2. Reference is made to page 23 concerning the air pollution potential of two package boilers. The amount of products released is termed "insignificant", but no baseline for this statement is given. Estimated emission due to these boilers would be a valuable addition to the report. Elsewhere in the report, in regard to sanitary waste, it is stated that both the New York State Department of Health and the Westchester County Department of Health had been consulted and that the design and operation had been approved. The same assurance should be provided regarding the subject of air pollution.

Sincerely,

Louis M. Rousselot
Louis M. Rousselot, M.D., F.A.C.S.



8111100905 700917
PDR ADCK 05000247
D PDR

d
2996
~~2983~~



ASSISTANT SECRETARY OF DEFENSE
WASHINGTON, D. C. 20301

HEALTH AND
ENVIRONMENT

17 SEP 1970

Mr. Harold L. Price
Director of Regulation
Atomic Energy Commission
Washington, D. C. 20545

Dear Mr. Price:

We have reviewed the Environmental Statement from the Consolidated Edison Company of New York, Inc. for the Indian Point Nuclear Generating Station Unit 2 as requested by your letter of August 17, 1970.

The following comments are provided:

1. Insufficient information is presented within the Statement regarding the environmental monitoring program. Sampling frequency should also be included as well as an indication of whether sampling frequency will be increased with the initial operation of Unit No. 2 at the Indian Point Site.

2. Reference is made to page 23 concerning the air pollution potential of two package boilers. The amount of products released is termed "insignificant", but no baseline for this statement is given. Estimated emission due to these boilers would be a valuable addition to the report. Elsewhere in the report, in regard to sanitary waste, it is stated that both the New York State Department of Health and the Westchester County Department of Health had been consulted and that the design and operation had been approved. The same assurance should be provided regarding the subject of air pollution.

Sincerely,

A handwritten signature in cursive script that reads "Louis M. Rousselot".

Louis M. Rousselot, M.D., F.A.C.S.

2996
~~2988~~



1970 SEP 17 1970

[Faint, illegible text, possibly a header or introductory paragraph]

[Faint, illegible text, possibly a main body paragraph]

[Faint, illegible text, possibly a closing or signature area]

[Faint, illegible text, possibly a footer or additional notes]

FROM: Assistant Secretary of Defense
 Wash. D.C.
 Louis M. Rousselet, M.D.

TO: Price

CLASSIF: U POST OFFICE REG. NO:

DESCRIPTION: (Must Be Unclassified)
 Ltr providing comments on Con. Ed's.
 Enviro. Rpt for Indian Point Unit #2..

ENCLOSURES:

REMARKS:

DATE OF DOCUMENT: 9-17-70		DATE RECEIVED 9-17-70		NO. 2996
LTR. X	MEMO:	PORT:	OTHER:	
ORIG.: 1	CC:	OTHER:		
ACTION NECESSARY <input type="checkbox"/>	CONCURRENCE <input type="checkbox"/>	DATE ANSWERED:		
NO ACTION NECESSARY <input type="checkbox"/>	COMMENT <input type="checkbox"/>	BY:		
FILE CODE:	50-247 (ENVIRO. FILE)			
REFERRED TO	DATE	RECEIVED BY	DATE	
Muller	9-22			
W/4 cys for Action(w/Orig for MATS)(Orig to		be returned to 016)		
<u>DIST:</u>				
Reg File				
AEC PDR				
OGC(RM 506A)Shapar				
Compliance(2)				
Henderson				
Felton				
DiNunno				
Boyd				
DeYoung				
E.Price SLR				
N. Dube				
P.Howe(2)				
Morris/Schroeder			2996	wms

DO NOT REMOVE
 ACKNOWLEDGED