

SUPPLEMENTAL  
FILE COPY

JUL 1 1968

Docket No. 50-286

Consolidated Edison Company of New York, Inc.  
4 Irving Place  
New York, New York 10003

Attention: Mr. Donham Crawford  
Administrative Vice President

Gentlemen:

The following information is required for the completion of our review of your application for construction permit for Indian Point Nuclear Generating Unit No. 3. This matter was discussed in a telephone conversation between Mr. John Grob of Consolidated Edison and D. R. Muller of the Division of Reactor Licensing on June 12, 1968.

1. Please describe and analyze those features of the Indian Point Unit No. 3 protection instrument system which differ from those of the Diablo Canyon design. Include the instrumentation which initiates engineered safety feature, containment isolation, pressure reduction, and air cleaning systems.
2. The ACRS "Report on the Pacific Gas and Electric Company Nuclear Unit -- Diablo Canyon Site," dated December 20, 1967, expressed concern with respect to (a) control rod position indication, and (b) separation of certain control and safety functions. Please address these two items by describing and analyzing any design changes you may wish to accomplish, or by justifying your present position.

8111110208 680701  
PDR ADDCK 05000286  
A PDR

3. Provide an analysis of the flooding potential of the Indian Point site considering both maximum probable hurricane storm surges and flooding from excessive rainfall or dam failures upriver.
4. Considering maximum flooding elevations at the site, analyze the protection requirements of these various critical plant structures, systems, or components required for safe shutdown of the facility or for the operation of the consequence limiting engineered safety features following the occurrence of the design basis loss-of-coolant accident.

Please submit this additional information as a part of the next supplement to your PSAR or as a separate supplement.

Sincerely,

Peter A. Morris, Director  
Division of Reactor Licensing

cc: Arvin E. Upton, Esq.  
LeBoeuf, Lamb, Leiby & Macrae  
1821 Jefferson St., NW.  
Washington, D. C. 20036

Distribution:  
AEC Public Doc. Rm  
Formal Docket  
Suppl.  
DR Reading  
RL Reading  
RPB-1 Reading  
M. M. Mann  
F. Schroeder  
R. S. Boyd  
S. Levine (13)  
L. Kornblith, CO (3)  
D. R. Muller  
J. Murphy  
N. Blunt

*I agree! Unfortunately, this question is a direct quote of Voss' which was passed on to Con. Ed. This letter only confirms "our" questions.*

*PAM: I do not concur w/ question 2. suggest at the time...*

OFFICE ▶	RL:RPB-1	RL:RPB-1	RL:RT	RL:RP	RL	
SURNAME ▶	<i>MM</i> Murphy/eb x#7441	<i>for</i> Muller	<i>sk</i> Levine	<i>RB</i> Boyd	<i>M</i> Morris	
DATE ▶	6/26/68	6/26/68	6/26/68	6/27/68	7/1/68	