

Distribution:

AEC PD

Local PDR

Docket

PWR-1 Rdg

PWR-1 File

H. Specter

OGC

R. DeYoung

J. Lee

J. Kastner

S. Block

W. Kreeger

W. Eister

H. Denton

RO (3)

RP Rdg

Docket No. 50-286

JUN 11 1973

Consolidated Edison Company
of New York, Inc.

ATTN: Mr. William J. Cahill, Jr.
Vice President

4 Irving Place
New York, New York 10003

Gentlemen:

We have reviewed the Indian Point Nuclear Generating Unit No. 3 airborne gaseous and particulate monitoring system and have discussed this with your representatives on May 23, 1973. On the basis of our review we require that fixed gaseous and particulate monitors be installed in the radwaste area, the fuel handling and storage area, and the control room. These three additional continuous monitors are to be installed with readout provisions in the control room.

It will be necessary that you amend your FSAR to state clearly your position regarding these requirements. Our tentative review schedule is based on the assumption that your FSAR will be so amended by June 25, 1973. If you cannot meet this date, please inform us within seven (7) days after receipt of this letter so that we may revise our schedule.

Sincerely,

D. B. Vassallo, Chief
Pressurized Water Reactors
Branch No. 1
Directorate of Licensing

cc: See page 2

8111120717 730611
PDR ADOCK 05000286
A PDR

OFFICE	PWR-1	PWR-1				
SURNAME	HSpecter:ms	DVassallo				
DATE	6/8/73	6/8/73				

Consolidated Edison Company
of New York, Inc.

- 2 -

JUN 11 1973

cc: Arvin E. Upton, Esq.
Harry H. Voigt, Esq.
Eugene R. Fidell, Esq.
LeBoeuf, Lamb, Leiby & MacRae
1821 Jefferson Place, N. W.
Washington, D. C. 20036

J. Bruce MacDonald
Deputy Commissioner and Counsel
New York Department of Commerce
99 Washington Avenue
Albany, New York 12210

Angus Macbeth, Esq.
Natural Resources Defense
Council, Inc.
15 West 44th Street
New York, New York 10036

Nicholas A. Robinson, Esq.
Marshall, Bratter, Greene,
Allison & Tucker
430 Park Avenue
New York, New York 10022

OFFICE ▶						
SURNAME ▶						
DATE ▶						