

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

In the Matter of)
)
CONSOLIDATED EDISON COMPANY)
OF NEW YORK, INC. and) Docket No. 50-286
POWER AUTHORITY OF THE STATE)
OF NEW YORK)
(Indian Point Station,)
Unit No. 3))

APPLICATION FOR AMENDMENT TO
OPERATING LICENSE

Pursuant to Section 50.90 of the regulations of the Nuclear Regulatory Commission, Consolidated Edison Company of New York, Inc. ("Con Edison"), in its own right and as agent for Power Authority of the State of New York as coholder of Facility Operating License No. DPR-64, hereby applies for an amendment to the Indian Point Unit No. 3 Technical Specifications contained in Appendix A to that License.

Specifically, Con Edison requests changes to Section 3.10.2 and the corresponding Basis to reflect a revised fuel rod bowing model and its effect on departure from nucleate boiling. In addition certain editorial corrections are also requested, including changes to Section 2.3 to achieve a greater degree of conformity with the Standard Technical Specifications and to eliminate areas of possible ambiguity.

The proposed Technical Specification changes consist of the specific revisions set forth in Attachment A to this Application. A safety evaluation of the proposed changes is set forth in Attachment B to this Application. This evaluation demonstrates

8111060313 770420
PDR ADOCK 05000286
PDR
P

that the proposed changes do not represent a significant hazards consideration and will not cause any change in the types or increase in the amounts of effluents or any change in the authorized power level of the facility.

CONSOLIDATED EDISON COMPANY
OF NEW YORK, INC.

By: William J. Cahill, Jr.
William J. Cahill, Jr.
Vice President

Sworn to before me
this 20th day of April, 1977

James P. Brady
Notary Public
JAMES P. BRADY
Notary Public State of New York
No. 03-4622425
Qualified in Bronx County
Commission Expires March 30, 1978