

POWER AUTHORITY OF THE STATE OF NEW YORK

10 COLUMBUS CIRCLE NEW YORK, N. Y. 10019
(212) 397-6200

TRUSTEES
FREDERICK R. CLARK
CHAIRMAN
GEORGE L. INGALLS
VICE CHAIRMAN
RICHARD M. FLYNN
ROBERT I. MILLONZI
WILLIAM F. LUDDY



GEORGE T. BERRY
EXECUTIVE DIRECTOR
LEWIS R. BENNETT
GENERAL COUNSEL AND
ASSISTANT EXECUTIVE
DIRECTOR
JOSEPH R. SCHMIEDER
CHIEF ENGINEER
JOHN W. BOSTON
DIRECTOR OF
POWER OPERATIONS
THOMAS F. McCRANN, JR.
CONTROLLER

April 26, 1979
IPN-79-20

Director, Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Attention: Mr. Albert Schwencer, Chief
Operating Reactors Branch No. 1
Division of Operating Reactors

Subject: Indian Point 3 Nuclear Power Plant
Docket No. 50-286

Dear Sir:

Enclosed for filing are three (3) signed originals and nineteen (19) copies of a document entitled "Application for Amendment to Operating License", and attachments thereto.

This application seeks to amend Technical Specification 3.5.5, Table 3.5-1 and Table 3.5-3 on the coincident low pressurizer pressure/level safety injection actuation signal, of Appendix A to Facility Operating License DPR-64. These changes are intended to provide an engineered safeguards actuation signal on low pressurizer pressure regardless of pressurizer level.

The Authority has classified this application for amendment to the operating license as Class III, as it involves the single safety issue of the revised actuation signal logic. Enclosed is a check in the amount of \$4,000 as the filing fee, per 10 CFR Section 170.22, which the Authority pays under protest, pending a final determination of the legality of the fee schedule.

In support of this application, we are enclosing forty (40) copies of the Safety Evaluation corresponding to the proposed Technical Specification change.

Handwritten:
A001
5/3
w/check
\$ 4,000.00


7904300 320

U.S. Nuclear Regulatory
Commission

-2-

Your expeditious processing of this application will be
greatly appreciated.

Very truly yours,


Paul J. Early
Assistant Chief Engineer-
Projects

Attachments

cc: w/att.

Hon. George V. Begany
White Plains Library