

BEFORE THE UNITED STATES  
NUCLEAR REGULATORY COMMISSION

In the Matter of )  
 )  
POWER AUTHORITY OF THE )  
 )  
STATE OF NEW YORK )  
 )  
Indian Point 3 Nuclear Power Plant )  
 )  
 )

Docket No. 50-286

APPLICATION FOR AMENDMENT TO  
OPERATING LICENSE

Pursuant to Section 50.90 of the regulations of the Nuclear Regulatory Commission (NRC), the Power Authority of the State of New York, as holder of Facility Operating License No. DPR-64, hereby applies for an Amendment to the Technical Specifications contained in Appendix A of this license.

The proposed change to the Indian Point Unit 3 (IP3) Technical Specifications is necessary to allow the capsule T specimen cask to be moved in and out of the Spent Fuel Pit while irradiated fuel is stored therein in order to comply with the requirements of 10CFR50, Appendix G. The cask, tools and specimens are not expected to exceed 20,000 pounds in weight.

Proposed changes to the Technical Specifications are presented in Attachment I to this Application. The Safety Evaluation is included as Attachment II.

POWER AUTHORITY OF THE  
STATE OF NEW YORK

By George T. Berry  
George T. Berry  
General Manager and  
Chief Engineer

Subscribed and Sworn to before  
me this 23 day of May, 1978.

Helen J. McCormick

HELEN J. MCCORMICK  
Notary Public, State of New York  
No. 01MC 2607500  
Qualified in Kings County  
Term Expires March 30, 1979

811110925 780523  
PDR ADOCK 05000286  
P PDR