

ATTACHMENT I
PROPOSED TECHNICAL SPECIFICATION CHANGES
INDIAN POINT 3 NUCLEAR POWER PLANT

Power Authority of the State of New York
December 1977

811111046 780130
PDR ADDCK 05000286
P PDR

- B. If any of the specified limiting conditions for refueling are not met, refueling shall cease until the specified limits are met, and no operations which may increase the reactivity of the core shall be made.
- C. During fuel handling and storage operations, the following conditions shall be met.
1. Radiation levels in the spent fuel storage area shall be monitored continuously whenever there is irradiated fuel stored therein. If the monitor is inoperable, a portable monitor may be used.
 2. The spent fuel cask shall not be moved over any region of the spent fuel pit which contains irradiated fuel. Additionally, if the spent fuel pit contains irradiated fuel, the spent fuel cask shall not be moved over any region of the spent fuel pit unless the irradiated fuel stored therein has been in a subcritical condition for at least 90 days.
 3. During periods of spent fuel cask or fuel storage building cask crane movement over the spent fuel pit, or during periods of spent fuel movement in the spent fuel pit, when the pit contains irradiated fuel, the pit shall be filled with borated water at a concentration ≥ 1000 ppm.
 4. Whenever movement of irradiated fuel in the spent fuel pit is being made, the minimum water level in the area of movement shall be maintained 23 feet over the top of irradiated fuel assemblies seated in the storage rack.
 5. Hoists or cranes utilized in handling irradiated fuel shall be dead-load tested before fuel movement begins. The load assumed by the hoists or cranes for this test must be equal to or greater than the maximum load to be assumed by the hoists or cranes during the fuel handling operation. A thorough visual inspection of the hoists or cranes shall be made after the dead-load test and prior to fuel handling.

5.4 FUEL STORAGE

Applicability

Applies to the capacity and storage arrays of new and spent fuel.

Objective

To define those aspects of fuel storage relating to prevention of criticality in fuel storage areas.

Specification

1. The spent fuel pit structure is designed to withstand the anticipated earthquake loadings as a Class I structure. The spent fuel pit has a stainless steel liner to insure against loss of water.
2. The new and spent fuel storage racks are designed so that it is impossible to insert assemblies in other than an array of vertical fuel assemblies with the sufficient center-to-center distance between assemblies to assure $k_{eff} \leq 0.95$.
3. Whenever there is fuel in the pit (except in the initial core loading), the spent fuel storage pit is filled and borated to the concentration to match that used in the reactor cavity and refueling canal during refueling operations.
4. The enrichment of fuel stored in the spent fuel pit will be no more than 3.5 weight percent of U-235.