

File Service Water Dept

*Rec'd.
4/11/75
9:15
EPL*



PA Electric Company
a subsidiary of PECO Group
1431 Arch Street Philadelphia, Pa. 19102

Teletypier #4439
Discipline 11103

April 11, 1975
J.O. 9321-094

50-286

TO: Mr. T. L. Ertel
Wesco Corporation
Buchanan, MI

FROM: Mr. G. C. Bierr

SUBJECT: Indian Point Generating Station
Unit No. 3
Service Water System Tests

We have reviewed the procedure and recorded data in Section 6.12 of the Service Water Functional Test INT-IP-4.12.1, Addendum No. 1, and find that the procedure is in agreement with our preliminary program outline sent by our teletypier message T/C 04424 dated April 1, 1975 and that the results are in good agreement with our predicted results. We therefore conclude that the test has been properly conducted and that the Service Water System meets the functional requirements of the post-100% recirculation mode of operation.

G. C. Bierr
G. C. Bierr
Proj. Eng. Mgr.

CC:
EC Powell
EF Clark
PA Matters
CC Bierr
Teletypier File

8111180686 750411
PDR ADOCK 05000286
A PDR