



Consolidated Edison Company of New York, Inc.
4 Irving Place, New York, NY 10003

January 21, 1974

Re: Indian Point Unit No. 2
AEC Docket No. 50-247
Operating License DPR-26
A.O.-4-2-4

Mr. James P. O'Reilly, Director
Regulatory Operations, Region I
U. S. Atomic Energy Commission
631 Park Avenue
King of Prussia, Pennsylvania 19406

Dear Mr. O'Reilly,

In accordance with the requirements of Section 6.12.2a of the Technical Specifications of Facility Operating License No. DPR-26, the following report is submitted.

During the course of a routine plant inspection on January 21, 1974 a small leak was observed at the upstream orifice flange connection for flow transmitter 946D in the six inch residual heat removal system return line (Line No. 355) to No. 21 reactor coolant loop. At the time of this observation, the reactor was in the cold shutdown condition with the residual heat removal system in service and pressurized to about 400 psig.

The leak is at the base of the fillet weld attaching a 3/4" pipe nipple to the orifice flange and is on the pipe side of the weld. Preparations for repair of the leak are underway; however, before repairs are initiated, a dye penetrant inspection of the weld will be made to determine the nature and extent of the defect. In addition our Engineering Department is investigating the occurrence in an effort to determine the cause.

Mr. Anthony Pasano of your office was notified on January 21, 1974 of the circumstances relating to this occurrence.

Very truly yours,

Warren R. Cobean, Jr., Manager
Nuclear Power Generation

cc: Mr. John F. O'Leary

8111070110 740121
PDR ADOCK 05000286
S PDR

50-286

MEMO ROUTE SLIP Form AEC-93 (Rev. May 14, 1947) AECM 0240		See me about this.	For concurrence.	For action.
		Note and return.	For signature.	<input checked="" type="checkbox"/> For information.
TO (Name and unit) Chief, FS&EB RO:HQ (4) RO Files DR Central Files Directorate of	INITIALS	REMARKS CONSOLIDATED EDISON CO. INDIAN POINT 2 AO #4-2-4		
	DATE			
TO (Name and unit) Licensing (4) OGC	INITIALS	REMARKS The above abnormal occurrence is forwarded for information. Distribution will be made by this office to the PDR, Local PDR, NSIC, DTIE, and State Representatives.		
	DATE			
TO (Name and unit)	INITIALS	REMARKS		
	DATE			
FROM (Name and unit) E. J. Brunner Region I <i>E. J. Brunner</i>	REMARKS			
PHONE NO. 8-337-1246	DATE 1/29/74			

USE OTHER SIDE FOR ADDITIONAL REMARKS

GPO : 1971 O - 445-452