

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (1)

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 N Y I P S 3 2 0 0 - 0 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 _____ 5
7 8 9 14 15 25 26 30 57 CAT 58

CON'T
0 1 REPORT SOURCE L 6 0 5 0 0 0 2 8 6 7 0 3 3 1 7 8 8 0 4 3 0 7 8 9
7 8 60 61 68 69 74 75 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | During normal operation, process radiation monitor R-11 and associated
0 3 | monitor R-12 become inoperable due to a tripped sample pump. The hum-
0 4 | idity and condensate flow systems, as well as the instrumentation re-
0 5 | quired for a water inventory balance, were operable. The pump was re-
0 6 | stored to service within the required Tech. Spec. time limit.
0 7 | Similar events were reported in R.O. - 76-3-44(B),
0 8 | R.O. 76-24(B) and TEIR-77-3-4

0 9 SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP. SUBCODE VALVE SUBCODE
B B 11 E 12 A 13 M O T O R X 14 Z 15 Z 16
7 8 9 10 11 12 13 18 19 20

17 LER/RO REPORT NUMBER 7 8 EVENT YEAR 7 8 SEQUENTIAL REPORT NO. 0 0 7 OCCURRENCE CODE 0 3 REPORT TYPE L REVISION NO. 0

ACTION TAKEN E 18 Z 19 EFFECT ON PLANT Z 20 SHUTDOWN METHOD Z 21 HOURS 0 0 0 0 ATTACHMENT SUBMITTED N 23 NPRD-4 FORM SUB. N 24 PRIME COMP. SUPPLIER N 25 COMPONENT MANUFACTURER C 5 2 1 1 26

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | A Conde, model G Motor had tripped due to thermal
1 1 | overload. The thermal overload was adjusted.
1 2 |
1 3 |
1 4 |

1 5 FACILITY STATUS E 28 % POWER 0 9 1 29 OTHER STATUS NA 30 METHOD OF DISCOVERY A 31 DISCOVERY DESCRIPTION Operator Observation 32

1 6 ACTIVITY CONTENT Z 33 Z 34 AMOUNT OF ACTIVITY NA 35 LOCATION OF RELEASE NA 36

1 7 PERSONNEL EXPOSURES NUMBER 0 0 0 37 TYPE Z 38 DESCRIPTION NA 39

1 8 PERSONNEL INJURIES NUMBER 0 0 0 40 DESCRIPTION NA 41

1 9 LOSS OF OR DAMAGE TO FACILITY TYPE Z 42 DESCRIPTION NA 43

2 0 PUBLICITY ISSUED Z 44 DESCRIPTION NA 45

B111070139 780430
PDR ADOCK 05000286
S PDR

NAME OF PREPARER: Neil A. Passman

PHONE: 914-739-5177