

LICENSE EVENT REPORT

CONTROL BLOCK: 1 2 3 4 5 6 1

(PLEASE PRINT OR TYPE REQUIRED INFORMATION)

0 1 N Y I P S 3 2 0 0 - 0 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5  
7 8 9 14 15 25 26 30 57 CAT 58

CON'T  
0 1 REPORT SOURCE L 6 0 5 0 0 0 2 8 0 7 0 3 2 8 7 8 8 0 4 2 7 7 8 9  
7 8 60 61 68 69 74 75 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

0 2 While returning the Unit to service, an above background reading on the  
0 3 Plant Vent Monitor initiated an investigation which revealed a leak  
0 4 in No. 31 RHR pump. The pump was removed from service and maintenance  
0 5 force notified.  
0 6  
0 7  
0 8

0 9 SYSTEM CODE C F 11 CAUSE CODE E 12 CAUSE SUBCODE B 13 COMPONENT CODE P U M P X X 14 COMP. SUBCODE B 15 VALVE SUBCODE Z 16  
7 8 9 10 11 12 13 18 19 20  
17 LER/RO REPORT NUMBER 7 8 21 22 SEQUENTIAL REPORT NO. 0 0 6 24 26 OCCURRENCE CODE 0 3 28 29 REPORT TYPE L 30 31 REVISION NO. 0 32  
ACTION TAKEN A 18 FUTURE ACTION Z 19 33 34 EFFECT ON PLANT Z 20 35 SHUTDOWN METHOD Z 21 36 HOURS 0 0 0 22 37 40 ATTACHMENT SUBMITTED N 23 41 NPRD-4 FORM SUB. N 24 42 PRIME COMP. SUPPLIER N 25 43 COMPONENT MANUFACTURER I 0 7 5 26 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

1 0 A defective Ingersoll-Rand, Model No. 8x20w, No. 096761 gasket  
1 1 between the mechanical seal gland plate and pump casing was found  
1 2 to be leaking and was replaced. The pump was returned to service  
1 3 on 3/29/78.  
1 4

1 5 FACILITY STATUS C 28 9 10 % POWER 0 2 4 29 12 13 OTHER STATUS NA 30 METHOD OF DISCOVERY A 31 45 46 DISCOVERY DESCRIPTION Shift Supervisor Observation 32 44 47

1 6 ACTIVITY CONTENT G 33 9 10 RELEASED OF RELEASE N 34 11 AMOUNT OF ACTIVITY 12.68 curies total 35 44 LOCATION OF RELEASE Plant Vent to atmosphere 36 45 47

1 7 PERSONNEL EXPOSURES NUMBER 0 0 0 37 9 11 TYPE Z 38 12 DESCRIPTION NA 39 13

1 8 PERSONNEL INJURIES NUMBER 0 0 0 40 9 11 DESCRIPTION NA 41 12

1 9 LOSS OF OR DAMAGE TO FACILITY TYPE Z 42 9 10 DESCRIPTION NA 43

2 0 PUBLICITY ISSUED N 44 9 10 DESCRIPTION NA 45  
8111070144 780427  
PDR ADOCK 05000286  
S PDR

NAME OF PREPARER Neil A. Passman PHONE: 914-739-5177

CPO 917-926