

LICENSEE EVENT REPORT

R.O.-76-3-26(B)

CONTROL BLOCK:

--	--	--	--	--	--

[PLEASE PRINT ALL REQUIRED INFORMATION]

LICENSEE NAME						LICENSE NUMBER						LICENSE TYPE			EVENT TYPE								
01	N	Y	I	P	S	3	0	0	-	0	0	0	0	-	0	0	4	1	1	1	1	0	3
7	8	9	14	15	25	26	30	31	32														
CATEGORY		REPORT TYPE	REPORT SOURCE	DOCKET NUMBER				EVENT DATE			REPORT DATE												
01	CONT	L	L	0	5	0	-	0	2	8	6	0	7	2	2	7	6	0	8	2	0	7	6
7	8	57	58	59	60	61	68	69	74	75	80												

EVENT DESCRIPTION

02 | A review of load rejection test data indicated that the K5 constant in
03 | the overpower delta T setpoint equation might be less conservative than
04 | the Tech. Spec. value. Upon confirmation, using special test instru-
05 | mentation, an immediate shutdown was initiated. The K5 constant was
06 | then reset to a more conservative value than required by Tech. Specs.,

SYSTEM CGDE		CAUSE CODE		COMPONENT CODE				PRIME COMPONENT SUPPLIER		COMPONENT MANUFACTURER			VIOLATION		
07	I	A	F	I	N	S	T	R	U	N	F	1	8	0	N
7	8	9	10	11	12	17	43	44	47	48					

CAUSE DESCRIPTION

08 | Investigation of this event failed to reveal any specific cause. The
09 | K5 constant was reset to a conservative value for operation.

10 |

FACILITY STATUS		% POWER		OTHER STATUS		METHOD OF DISCOVERY		DISCOVERY DESCRIPTION				
11	B	0	8	3	NA	C	Evaluation of Load Rejection	Test Data				
7	8	9	10	12	13	44	45	46	80			

FORM OF ACTIVITY RELEASED		CONTENT OF RELEASE		AMOUNT OF ACTIVITY		LOCATION OF RELEASE			
12	Z	Z	NA	NA	NA				
7	8	9	10	11	44	45	80		

PERSONNEL EXPOSURES

NUMBER		TYPE		DESCRIPTION					
13	0	0	0	Z	NA				
7	8	9	11	12	13	80			

PERSONNEL INJURIES

NUMBER		DESCRIPTION						
14	0	0	0	NA				
7	8	9	11	12	80			

PROBABLE CONSEQUENCES

15 | NA

LOSS OR DAMAGE TO FACILITY

TYPE		DESCRIPTION				
16	Z	NA				
7	8	9	10	80		

PUBLICITY

17 | NA

ADDITIONAL FACTORS

18 | (Event Desc. Cont.) - verified, and the shutdown was halted.

19 | [R.O.-76-3-26(B)] **8111070492 760820**
PDR ADOCK 05000286
S PDR

NAME: Austin J. Decker II PHONE: 914-739-8823