

LICENSEE EVENT REPORT

(PLEASE PRINT ALL REQUIRED INFORMATION)

CONTROL BLOCK: 1 6

LICENSEE NAME 01 N Y I P S 3														LICENSE NUMBER 0 0 - 0 0 0 0 0 - 0 0										LICENSE TYPE 4 1 1 1 1				EVENT TYPE 0 3					
CATEGORY 01 CONT														REPORT TYPE L		REPORT SOURCE L		DOCKET NUMBER 0 5 0 - 0 2 8 6										EVENT DATE 0 5 0 5 7 6				REPORT DATE 0 6 0 3 7 6	

EVENT DESCRIPTION

02 While performing a trip test during a post-maintenance check of a reac-
 03 tor protection logic channel, Relay V-1, associated with containment
 04 ventilation isolation functioned only intermittently. The relay was ad-
 05 justed and operated correctly upon retesting. Examination of similar
 06 relays in the safeguards logic cabinet was conducted and none were found

SYSTEM CODE 07 I B				CAUSE CODE E		COMPONENT CODE R E L A Y X				PRIME COMPONENT SUPPLIER N		COMPONENT MANUFACTURER W 1 2 0				VIOLATION N	
-----------------------	--	--	--	-----------------	--	-------------------------------	--	--	--	-------------------------------	--	-----------------------------------	--	--	--	----------------	--

CAUSE DESCRIPTION

08 A Westinghouse Type MG-6 relay was found to be misaligned in that the
 09 pivot point for the operating contacts had shifted. This caused the
 10 relay to work intermittently.

FACILITY STATUS 11 B		% POWER 0 0 0		OTHER STATUS NA		METHOD OF DISCOVERY B		DISCOVERY DESCRIPTION Surveillance Testing	
FORM OF ACTIVITY RELEASED 12 Z		CONTENT OF RELEASE Z		AMOUNT OF ACTIVITY NA		LOCATION OF RELEASE NA			

PERSONNEL EXPOSURES

NUMBER 13 0 0 0		TYPE Z		DESCRIPTION NA	
--------------------	--	-----------	--	-------------------	--

PERSONNEL INJURIES

NUMBER 14 0 0 0		DESCRIPTION NA	
--------------------	--	-------------------	--

PROBABLE CONSEQUENCES

15 NA

LOSS OR DAMAGE TO FACILITY

TYPE 16 Z		DESCRIPTION NA	
--------------	--	-------------------	--

PUBLICITY

17 NA

ADDITIONAL FACTORS

18 (Event Desc. Cont.) - to require adjustment R.O.-76-3-9(B)].

19 8111070576 760603
PDR ADOCK 05000286
PDR

NAME: Austin J. Decker II PHONE: 914-739-8823