

# LICENSEE EVENT REPORT

(PLEASE PRINT ALL REQUIRED INFORMATION)

CONTROL BLOCK: 

--	--	--	--	--	--

LICENSEE NAME: 

01	N	Y	I	P	S	3
----	---	---	---	---	---	---

 LICENSE NUMBER: 

0	0	-	0	0	0	0	0	-	0	0
---	---	---	---	---	---	---	---	---	---	---

 LICENSE TYPE: 

4	1	1	1	1
---	---	---	---	---

 EVENT TYPE: 

0	3
---	---

REPORT TYPE: 

L
---

 REPORT SOURCE: 

L
---

 DOCKET NUMBER: 

0	5	0	-	0	2	8	6
---	---	---	---	---	---	---	---

 EVENT DATE: 

0	5	1	0	7	6
---	---	---	---	---	---

 REPORT DATE: 

0	6	0	3	7	6
---	---	---	---	---	---

### EVENT DESCRIPTION

02 During startup testing, a "Battery Charger Trouble" alarm annunciated in  
03 the control room. When it was determined that the battery charger had  
04 become inoperable, a controlled shutdown was initiated. Upon investiga-  
05 tion, it was discovered that the charger fan had tripped. An alternate  
06 means of cooling was provided, and the battery charger was returned to

SYSTEM CODE: 

E	C
---	---

 CAUSE CODE: 

E
---

 COMPONENT CODE: 

B	L	O	W	E	R
---	---	---	---	---	---

 PRIME COMPONENT SUPPLIER: 

N
---

 COMPONENT MANUFACTURER: 

W	1	2	0
---	---	---	---

 VIOLATION: 

N
---

### CAUSE DESCRIPTION

08 A Westinhouse 3 Phase AC Fan Motor, Type FS, 1/4 H.P., 1725 RPM, became  
09 inoperable when exposed wiring caused a fuse to blow. The inoperable fan  
10 in turn caused a negative pressure sensor to operate, tripping the AC  
breaker.

FACILITY STATUS: 

B
---

 % POWER: 

0	4	5
---	---	---

 OTHER STATUS: 

NA
----

 METHOD OF DISCOVERY: 

B
---

 DISCOVERY DESCRIPTION: 

Control Room Alarm
--------------------

FORM OF ACTIVITY RELEASED: 

Z
---

 CONTENT OF RELEASE: 

Z
---

 AMOUNT OF ACTIVITY: 

NA
----

 LOCATION OF RELEASE: 

NA
----

### PERSONNEL EXPOSURES

13 NUMBER: 

0	0	0
---	---	---

 TYPE: 

Z
---

 DESCRIPTION: 

NA
----

### PERSONNEL INJURIES

14 NUMBER: 

0	0	0
---	---	---

 DESCRIPTION: 

NA
----

### PROBABLE CONSEQUENCES

15 NA

### LOSS OR DAMAGE TO FACILITY

15 TYPE: 

Z
---

 DESCRIPTION: 

NA
----

### PUBLICITY

17 NA

### ADDITIONAL FACTORS

18 (Event Desc. Cont) serv... this point the shutdown was halted and  
19 the unit was returned to 45% power. [R.O.-76-3-10(B)].

8111070581 760603  
PDR ADOCK 05000286  
PDR