

POWER AUTHORITY OF THE STATE OF NEW YORK
INDIAN POINT NO. 3 NUCLEAR POWER PLANT

P. O. BOX 215 BUCHANAN, N. Y. 10511

TELEPHONE: 914-739-8200



June 21, 1978
IP-MEA-1997

Mr. Boyce H. Grier, Director
Office of Inspection and Enforcement
Region I
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, Pennsylvania 19406

Subject: Indian Point 3 Nuclear Power Plant
Docket No. 50-286

Dear Mr. Grier:

In response to I. E. Bulletin No. 78-06, a survey was conducted in an effort to locate Cutler-Hammer DC relays of the type in question. A review of WCAP 8673, "Multi-Frequency and Direction Seismic Testing of Relays" indicated the absence of any Cutler-Hammer relays during initial installation. A subsequent inspection of all safety related relay schemes assured us that no Cutler-Hammer replacement relays had been installed.

As it was determined that none of the Cutler-Hammer Type M, DC relays, Catalog No. D23MRD have been utilized at Indian Point 3 Nuclear Power Plant, it is our conclusion that the events ascribed in I. E. Bulletin No. 78-06 have no applicability at our facility and no further action is required.

Very truly yours,


J. P. Bayne
Resident Manager

MEA/rbb

cc: Office of Inspection and Enforcement
Division of Reactor Inspection Programs
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

cc: Mr. George T. Berry
General Manager and Chief Engineer
Power Authority of the State of New York
10 Columbus Circle
New York, New York 10019

8111090150 780621
PDR ADOCK 05000286
G PDR

Bope
R

POWER AUTHORITY OF THE STATE OF NEW YORK
INDIAN POINT NO. 3 NUCLEAR POWER PLANT

P. O. BOX 215 BUCHANAN, N. Y. 10511

TELEPHONE: 914-739-8200



June 21, 1978
IP-MEA-1997

Mr. Boyce H. Grier, Director
Office of Inspection and Enforcement
Region I
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, Pennsylvania 19406


Subject: Indian Point 3 Nuclear Power Plant
Docket No. 50-286

Dear Mr. Grier:

In response to I. E. Bulletin No. 78-06, a survey was conducted in an effort to locate Cutler-Hammer DC relays of the type in question. A review of WCAP 8673, "Multi-Frequency and Direction Seismic Testing of Relays" indicated the absence of any Cutler-Hammer relays during initial installation. A subsequent inspection of all safety related relay schemes assured us that no Cutler-Hammer replacement relays had been installed.

As it was determined that none of the Cutler-Hammer Type M, DC relays, Catalog No. D23MRD have been utilized at Indian Point 3 Nuclear Power Plant, it is our conclusion that the events ascribed in I. E. Bulletin No. 78-06 have no applicability at our facility and no further action is required.

Very truly yours,


J. P. Bayne
Resident Manager

MEA/rbb

cc: Office of Inspection and Enforcement
Division of Reactor Inspection Programs
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

cc: Mr. George T. Berry
General Manager and Chief Engineer
Power Authority of the State of New York
10 Columbus Circle
New York, New York 10019

