NRC FORM 366 (7-77) Update Report - Previous report date 6/4/78 U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: | | - | | | | | (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | N Y I P S 3 (2) | 0 0 - 0 0 0 0 - 0 0 (3) | 4 1 1 1 1 (4) | (5)
LICENSEE CODE — LICENSE NUMBER — LICENSE TYPE — CAT

CON'T
01 | REPORT SOURCE L (6) | 0 5 0 0 0 2 8 6 (7) | 0 5 0 6 7 8 (8) | 0 8 2 4 7 8 (9)
DOCKET NUMBER — EVENT DATE — REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 During normal operation, LP Steam Dump Valve
03 No. 3 failed to open fully
04 during its stroke testing during performance
05 of PT-M24. Sufficient valves were available
06 to operate at full power.
07
08

09 | SYSTEM CODE H B (11) | CAUSE CODE X (12) | CAUSE SUBCODE Z (13) | COMPONENT CODE V A L V E X (14) | COMP. SUBCODE F (15) | VALVE SUBCODE G (16)

(17) LER/RO REPORT NUMBER | EVENT YEAR 7 8 | — | SEQUENTIAL REPORT NO. 0 1 0 | / | OCCURRENCE CODE 0 3 | REPORT TYPE L | — | REVISION NO. 1

ACTION TAKEN Z (18) | FUTURE ACTION 0 (19) | EFFECT ON PLANT Z (20) | SHUTDOWN METHOD Z (21) | HOURS (22) 0 0 0 0 | ATTACHMENT SUBMITTED N (23) | NPRD-4 FORM SUB. Y (24) | PRIME COMP. SUPPLIER N (25) | COMPONENT MANUFACTURER F 1 3 0 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 A Fisher, Type 657-AC, Size 87 plug and cage was scored.
11 The scoring was removed and the valve was reinstalled and
12 satisfactorily tested.
13
14

15 | FACILITY STATUS E (28) | % POWER 0 9 1 (29) | OTHER STATUS (30) NA | METHOD OF DISCOVERY B (31) | DISCOVERY DESCRIPTION (32) Surveillance Test

16 | ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY (35) NA | LOCATION OF RELEASE (36) NA

17 | PERSONNEL EXPOSURES NUMBER 0 0 0 (37) | TYPE Z (38) | DESCRIPTION (39) NA

18 | PERSONNEL INJURIES NUMBER 0 0 0 (40) | DESCRIPTION (41) NA

19 | LOSS OF OR DAMAGE TO FACILITY (43) TYPE Z (42) | DESCRIPTION NA

20 | PUBLICITY ISSUED N (44) | DESCRIPTION (45) NA | NRC USE ONLY

8111090387 780824
PDR ADOCK 05000286
S PDR

NAME OF PREPARER Neil A. Passman PHONE: 914-739-8200 X250