NRC FORM 366
(7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | NYIPS3 (2) | 00-000-00 (3) | 41111 (4) | (5)
LICENSEE CODE — LICENSE NUMBER — LICENSE TYPE — CAT

CON'T
01 | REPORT SOURCE L (6) | 05000286 (7) | 072178 (8) | 082078 (9)
DOCKET NUMBER — EVENT DATE — REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 While shutdown for refueling, performance of Surveillance Test, 3PC-R10, showed
03 the low level alarm LC-920A for the Refueling Water Storage Tank to be set below
04 the required value specified in Technical Specification 3.3.A.3.K. Since the
05 plant was in the cold shutdown condition, this alarm was not required to be
06 operable at this time.
07
08

09 SYSTEM CODE WG (11) | CAUSE CODE E (12) | CAUSE SUBCODE E (13) | COMPONENT CODE INSTRU (14) | COMP. SUBCODE X (15) | VALVE SUBCODE Z (16)

(17) LER/RO REPORT NUMBER: EVENT YEAR 78 | — | SEQUENTIAL REPORT NO. 018 | / | OCCURRENCE CODE 03 | REPORT TYPE L | — | REVISION NO. 0

ACTION TAKEN E (18) | FUTURE ACTION Z (19) | EFFECT ON PLANT Z (20) | SHUTDOWN METHOD Z (21) | HOURS (22) 0000 | ATTACHMENT SUBMITTED Y (23) | NPRD-4 FORM SUB. N (24) | PRIME COMP. SUPPLIER N (25) | COMPONENT MANUFACTURER F180 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 The Foxboro Model 63U-AR=0 (special) alarm indication unit was found to be
11 outside the required tolerance and was reset to within allowable limits.
12 The apparant cause was due to instrument drift.
13
14

15 FACILITY STATUS H (28) | % POWER 000 (29) | OTHER STATUS (30) NA | METHOD OF DISCOVERY B (31) | DISCOVERY DESCRIPTION (32) Surveillance Test

16 ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY (35) NA | LOCATION OF RELEASE (36) NA

PERSONNEL EXPOSURES
17 NUMBER 000 (37) | TYPE Z (38) | DESCRIPTION (39) NA

PERSONNEL INJURIES
18 NUMBER 000 (40) | DESCRIPTION (41) NA

LOSS OF OR DAMAGE TO FACILITY (43)
19 TYPE Z (42) | DESCRIPTION NA

PUBLICITY
20 ISSUED N (44) | DESCRIPTION (45) NA

8111090417 780818
PDR ADOCK 05000286
S PDR

NRC USE ONLY

NAME OF PREPARER Neil A. Passman PHONE: 914 739-8200 x 250