

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | N Y I P S 3 | 2 | 0 0 - 0 0 0 0 0 - 0 0 | 3 | 4 1 1 1 1 | 4 | 5
7 8 9 14 15 25 26 30 57 CAT 58

CON'T
0 1 | L | 6 | 0 5 0 0 0 2 8 6 | 7 | 0 7 0 5 7 8 | 8 | 0 8 0 4 7 8 | 9
7 8 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | While shutdown for refueling, performance of Refueling Test,
0 3 | 3PC-R16, showed accumulator level transmitter, LT-934B to be
0 4 | outside the required tolerance.
0 5 |
0 6 |
0 7 |
0 8 |

0 9 | C J | 11 | E | 12 | E | 13 | I N S T R U | 14 | T | 15 | Z | 16
7 8 9 10 11 12 13 18 19 20

17 | LER/RO REPORT NUMBER | 7 8 | 21 22 | - | 23 | 0 1 5 | 24 26 | / | 27 | 0 3 | 28 29 | L | 30 | - | 31 | 0 | 32
EVENT YEAR SEQUENTIAL REPORT NO. OCCURRENCE CODE REPORT TYPE REVISION NC.

E | 18 | Z | 19 | Z | 20 | Z | 21 | 0 0 0 0 | 22 | N | 23 | N | 24 | N | 25 | R 3 6 9 | 26
33 34 35 36 37 40 41 42 43 44 47
ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NPRD-4 FORM SUB. PRIME COMP. SUPPLIER COMPONENT MANUFACTURER

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | A Rosemount, Model 1151 DP, level transmitter was found to be
1 1 | outside the required tolerance and was recalibrated.
1 2 |
1 3 |
1 4 |

1 5 | H | 28 | 0 0 0 | 29 | NA | 30 | B | 31 | Surveillance Test | 32
7 8 9 10 12 13 44 45 46 80
FACILITY STATUS % POWER OTHER STATUS METHOD OF DISCOVERY DISCOVERY DESCRIPTION

1 6 | Z | 33 | Z | 34 | NA | 35 | NA | 36
7 8 9 10 11 44 45 80
ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY LOCATION OF RELEASE

1 7 | 0 0 0 | 37 | Z | 38 | NA | 39
7 8 9 10 11 12 13 80
PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION

1 8 | 0 0 0 | 40 | NA | 41
7 8 9 10 11 12 80
PERSONNEL INJURIES NUMBER DESCRIPTION

1 9 | Z | 42 | NA | 43
7 8 9 10 11 12 80
LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION

2 0 | N | 44 | NA | 45 | 8111100047 780801 PDR ADOCK 05000286 S PDR | NRC USE ONLY
7 8 9 10 68 69 80
PUBLICITY ISSUED DESCRIPTION

NAME OF PREPARER: Neil A. Passman PHONE: 914-739-8200 X250