NRC FORM 3
(7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: (1)

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 NYIPS3 (2) 00000000-00 (3) 41111 (4) (5)
LICENSEE CODE — LICENSE NUMBER — LICENSE TYPE — CAT

CON'T
01 REPORT SOURCE - (6) 05000286 (7) 057788 (8) 060678 (9)
DOCKET NUMBER — EVENT DATE — REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 While performing the required surveillance testing of the Fuel Storage Building
03 charcoal absorbers, the results of the Methyl Iodine removal efficiency testing
04 revealed that the charcoal decontamination efficiency was less than the required
05 acceptance limit (>/=0.90) as stated in Section 4.5.A.6.C.1 of the Unit No. 3
06 Technical Specifications.
07
08

09 SYSTEM CODE: FB (11) CAUSE CODE: C (12) CAUSE SUBCODE: Z (13) COMPONENT CODE: FILTER (14) COMP. SUBCODE: Z (15) VALVE SUBCODE: Z (16)

(17) LER/RO REPORT NUMBER: EVENT YEAR 78 — SEQUENTIAL REPORT NO. 009 — OCCURRENCE CODE 03 — REPORT TYPE L — REVISION NO. 0

ACTION TAKEN: A (18) FUTURE ACTION: Z (19) EFFECT ON PLANT: Z (20) SHUTDOWN METHOD: Z (21) HOURS (22): 0000 ATTACHMENT SUBMITTED: N (23) NPRD-4 FORM SUB.: Y (24) PRIME COMP. SUPPLIER: A (25) COMPONENT MANUFACTURER: M335 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 Charcoal absorber degradation attributed to normal end of service life. All
11 charcoal absorber trays in the units were refilled with certified charcoal and
12 replaced. The surveillance test program effectively detects decreased efficiencies
13 of this nature.
14

15 FACILITY STATUS: E (28) % POWER: 090 (29) OTHER STATUS (30): METHOD OF DISCOVERY: B (31) DISCOVERY DESCRIPTION (32): Surveillance Testing

16 ACTIVITY RELEASED: Z (33) CONTENT OF RELEASE: Z (34) AMOUNT OF ACTIVITY (35): N/A LOCATION OF RELEASE (36): N/A

PERSONNEL EXPOSURES
17 NUMBER: 000 (37) TYPE: (38) DESCRIPTION (39): N/A

PERSONNEL INJURIES
18 NUMBER: 000 (40) DESCRIPTION (41): N/A

LOSS OF OR DAMAGE TO FACILITY
19 TYPE: Z (42) DESCRIPTION (43): N/A

PUBLICITY
20 ISSUED: N (44) DESCRIPTION (45): N/A

8111100136 780602
PDR ADOCK 05000286
S PDR

NRC USE ONLY

NAME OF PREPARER: Mark Tagliamonte PHONE: (914) 739-0502

GPO 917-935