NRC FORM 366 (7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

Line	Field	Value
01	Licensee Code (2)	NYIPS3
01	License Number (3)	00-00000-00
01	License Type (4)	41111
01	CAT (5)	
CON'T 01	Report Source (6)	L
01	Docket Number (7)	05000286
01	Event Date (8)	050678
01	Report Date (9)	060478

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 During normal operation, LP Steam Dump Valve

03 No. 3 failed to open fully

04 during its stroke testing during performance

05 of PT-M24. Sufficient valves available to

06 operate at full power.

07

08

Line 09	System Code (11)	Cause Code (12)	Cause Subcode (13)	Component Code (14)	Comp. Subcode (15)	Valve Subcode (16)
	HB	X	Z	VALVEX	F	G

LER/RO Report Number (17)	Event Year		Sequential Report No.		Occurrence Code	Report Type		Revision No.
	78	—	010	/	03	L	—	0

Action Taken (18)	Future Action (19)	Effect on Plant (20)	Shutdown Method (21)	Hours (22)	Attachment Submitted (23)	NPRD-4 Form Sub. (24)	Prime Comp. Supplier (25)	Component Manufacturer (26)
Z	0	Z	Z	0000	N	Y	N	F130

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 Repairs to be made during the next

11 refueling outage.

12

13

14

Line	Facility Status (28)	% Power (29)	Other Status (30)	Method of Discovery (31)	Discovery Description (32)
15	E	091	NA	B	Surveillance Test

Line	Activity Released (33)	Content of Release (34)	Amount of Activity (35)	Location of Release (36)
16	Z	Z	NA	NA

Line	Personnel Exposures Number (37)	Type (38)	Description (39)
17	000	Z	NA

Line	Personnel Injuries Number (40)	Description (41)
18	000	NA

Line	Loss of or Damage to Facility Type (42)	Description (43)
19	Z	NA

Line	Publicity Issued (44)	Description (45)	NRC Use Only
20	N	NA	

8111100157 780601
PDR ADOCK 05000286
S PDR

NAME OF PREPARER: Neil A. Passman

PHONE: 914-739-5177

GPO 917-926