

REGULATORY DOCKET FILE COPY

POWER AUTHORITY OF THE STATE OF NEW YORK
10 COLUMBUS CIRCLE NEW YORK, N. Y. 10019
(212) 397-6200

TRUSTEES
FREDERICK R. CLARK
CHAIRMAN
GEORGE L. INGALLS
VICE CHAIRMAN
RICHARD M. FLYNN
ROBERT I. MILLONZI
WILLIAM F. LUDDY



IPO-112
June 8, 1978

GEORGE T. BERRY
GENERAL MANAGER
AND CHIEF ENGINEER
LEWIS R. BENNETT
ASSISTANT GENERAL
MANAGER-GENERAL
COUNSEL
WILBUR L. GRONBERG
ASSISTANT GENERAL
MANAGER-ENGINEERING
JOHN W. BOSTON
DIRECTOR OF
POWER OPERATIONS
THOMAS F. MCCRANN, JR.
CONTROLLER

Director of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

Attention: Mr. Albert Schwencer, Chief
Operating Reactors Branch No. 1

Subject: Indian Point 3 Nuclear Power Plant
Docket No. 50-286



Dear Mr. Schwencer:

Please be advised that our Assistant Chief Engineer-
Projects, Mr. Paul J. Early, is authorized to sign correspon-
dence on behalf of the Power Authority of the State of
New York to the Nuclear Regulatory Commission.

Very truly yours,

George T. Berry
George T. Berry
General Manager

781650017

8111120357 780608
PDR ADOCK 05000286
H PDR

m006/s *
1/0

5 NUCLEAR REGULATORY COMMISSION
C DAILY ACCESSION LIST

05/10/78

PAGE 26
FILE LOCATION _____

8128-0123
LETTER
P+5P

TASK NBR:
FICHE NBR :
NOTARIZED: NO
LPDR: YES CLASS:

RECP AFFILIATION: N STATES PWR
ORG AFFILIATION: NRC

IG THAT THERE WERE NO ITEMS OF NON-COMPLIANCE CITED IN IE INSPEC. REPT.
1-282/78-03 & 50-306/78-04 CONDUCTED BY MESSRS. JANUSKA & JORGENSEN ON
/78. W/ATT INSPEC REPT

8124-0045
LETTER
IP

TASK NBR:
FICHE NBR :
NOTARIZED: NO
LPDR: YES CLASS:

RECP AFFILIATION: NRC
ORG AFFILIATION: N STATES PWR

URING LICENSEE EVENT REPT (RO 50-282/78-011) ON 04/22/78 CONCERNING DURING
OFFSET CALIBRATION AT ABOUT 90% PWR, AXIAL FLUX DIFFERENCE WAS ALLOWED
E THE PLUS - MINUS 5% TARGET BAND FOR ABOUT 14 HRS VS THE LIMIT OF 12 HRS
IN TECH SPEC.

78125-0054
LETTER
IP

TASK NBR:
FICHE NBR :
NOTARIZED: NO
LPDR: YES CLASS:

RECP AFFILIATION: NRC
ORG AFFILIATION: N STATES PWR

URING ENVIRON LICENSEE EVENT REPT (RO 50-282/78-03) ON 04/12/78 CONCERNING
ION OF SUBJECT FACILITY'S CIRCULATING WATER SYS IN THE PARTIAL RECYCLE
WITH DAILY AVERAGE BLOWDOWN FLOW WAS IN EXCESS OF 150 CFS.