

# REGULATORY DOCKET FILE COPY

POWER AUTHORITY OF THE STATE OF NEW YORK

10 COLUMBUS CIRCLE NEW YORK, N. Y. 10019

(212) 397-6200

## TRUSTEES

FREDERICK R. CLARK  
CHAIRMAN

GEORGE L. INGALLS  
VICE CHAIRMAN

RICHARD M. FLYNN

ROBERT I. MILLONZI

WILLIAM F. LUDDY



May 24, 1978  
IPO-106

GEORGE T. BERRY  
GENERAL MANAGER  
AND CHIEF ENGINEER

LEWIS R. BENNETT  
ASSISTANT GENERAL  
MANAGER-GENERAL  
COUNSEL

WILBUR L. GRONBERG  
ASSISTANT GENERAL  
MANAGER-ENGINEERING

JOHN W. BOSTON  
DIRECTOR OF  
POWER OPERATIONS

THOMAS F. MCCRANN, JR.  
CONTROLLER

Director of Nuclear Reactor Regulation  
U. S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Attention: Mr. A. Schwencer, Chief  
Operating Reactors Branch No. 1

Subject: Indian Point 3 Nuclear Power Plant  
Docket No. 50-286

Dear Mr. Schwencer:

Attached herewith is the "Indian Point 3 Cycle 2 Eighteen (18) Case FAC Reanalysis", in response to a request by NRC staff.

As noted in Supplement 1 to the Safety Evaluation Report regarding the proposed power increase to rated design power of the Indian Point 3 reactor, dated April 17, 1978, Section III, this attachment provides the results of a plant specific constant axial offset control analysis of eighteen (18) cases of load following which ensures that the Fq limit of 2.17 will not be exceeded in normal operation of the plant.

The reanalysis was based on a Cycle 1 power rating limited to 91%. Sufficient advantages in power distribution parameters; e.g., Fxy (Z), Axial offset; are available when a 91% power restriction is assumed for all of Cycle 1, so that Cycle 2 may be operated at 100% power with no restrictions except to limit the most positive axial flux difference pertinent to less than +10% at 100% power.

Since the validity of the analysis is predicated on restricting Indian Point 3 Cycle 1 to power operation at a below 91% of full rated power (3025 MWt), the Power Authority hereby makes that commitment.

1978 MAY 25 PM 12 14

RECEIVED DISTRIBUTION  
SERVICES UNIT


8111120372 780524  
PDR ADDOCK 05000286  
P PDR

781460088

A001/S \*  
11

This submittal is made in support of our "Application for Amendment to Operating License", dated April 7, 1978. Appropriate modifications to that application will be made in an upcoming submittal.

Very truly yours,

  
George T. Berry  
General Manager and  
Chief Engineer

Att:

cc: w/att.

George V. Begany  
White Plains Library