

POWER AUTHORITY OF THE STATE OF NEW YORK

10 COLUMBUS CIRCLE NEW YORK, N. Y. 10019

(212) 397-6200



July 23, 1979  
IPN-79-53

Director, Office of Nuclear Reactor Regulation  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Attention: Mr. Albert Schwencer, Chief  
Operating Reactors Branch No. 1  
Division of Operating Reactors


Subject: Indian Point 3 Nuclear Power Plant  
Docket No. 50-286  
I&E Bulletin 79-07 Status Report  
on Pipe Stress Reanalysis

**REGULATORY DOCKET FILE COPY**

Dear Sir:

Attached for your information is the weekly status report as of July 20, 1979 on United Engineers & Constructors piping reanalysis efforts for the critical lines committed under our letter of May 31, 1979.

Very truly yours,

  
Paul J. Early  
Assistant Chief Engineer-Projects

A001  
S/11

7907270 0218

Indian Point 3 Nuclear Power Plant  
 Pipe Stress Reanalysis  
Status of Work as of July 20, 1979

A. Piping

Total No. of Lines for Reanalysis	Total No. Reanalyzed	No. of Lines Within Allowables	No. of Lines Over Allowables
176	141	141	0

B. Piping Supports, Hangers, Snubbers & Nozzles

Total No. of Components to Reanalyze	Total No. Reanalyzed	No. of Components Within Original Design Loads and/ or Allowables	No. of Components Over Design Loads and/or Allowables
1462 (1)	483	483	0

Notes: (1) Estimated quantities