

POWER AUTHORITY OF THE STATE OF NEW YORK  
10 COLUMBUS CIRCLE NEW YORK, N. Y. 10019  
(212) 397-6200



**REGULATORY DOCKET FILE COPY**

August 8, 1979  
IPN-79-57

Director of Office of Nuclear Reactor Regulation  
United States Nuclear Regulatory Commission  
Washington, D. C. 20555


Attention: Mr. Albert Schwencer, Chief  
Operating Reactors Branch No. 1  
Division of Operating Reactors

Subject: Indian Point 3 Nuclear Power Plant  
Docket No. 50-286  
I&E Bulletin 79-07 Status Report  
on Pipe Stress Reanalysis

Dear Sir:

Attached for your information is the weekly status report as of August 3, 1979 on United Engineers and Constructors piping reanalysis efforts for the critical lines committed under our letter of May 31, 1979.

Very truly yours,

  
Paul J. Early  
Assistant Chief Engineer-  
Projects

Att.

*Acc  
S 1/1*

7908140564

Q

Indian Point 3 Nuclear Power Plant  
Pipe Stress Reanalysis  
Status of Work as of August 3, 1979

A. Piping

Total No. of Lines for Reanalysis	Total No. Reanalyzed	No. of Lines Within Allowables	No. of Lines Over Allowables
176	145	145	0

B. Piping Supports, Hangers, Snubbers & Nozzles

Total No. of Components to Reanalyze	Total No. Reanalyzed	No. of Components Within Original Design Loads and/ or Allowables	No. of Components Over Design Loads and/or Allowables
1462(1)	724	724	0

Notes: (1) Estimated quantities.