

POWER AUTHORITY OF THE STATE OF NEW YORK

10 COLUMBUS CIRCLE NEW YORK, N. Y. 10019

(212) 397-6200



REGULATORY DOCKET FILE COPY

August 15, 1979
IPN-79-59

Director of Office of Nuclear Reactor Regulation
United States Nuclear Regulatory Commission
Washington, D.C. 20555

Attention: Mr. Albert Schwencer, Chief
Operating Reactors Branch No. 1
Division of Operating Reactors

Subject: Indian Point 3 Nuclear Power Plant
Docket No. 50-286
I&E Bulletin 79-07 Status Report
On Pipe Stress Reanalysis

Dear Sir:

Attached for your information is the weekly status report as of August 10, 1979 on United Engineers and Constructors piping reanalysis efforts for the critical lines committed under our letter of May 31, 1979.

Very truly yours,



Paul J. Early
Assistant Chief Engineer-
Projects

Aug
5/11

7908230360

Indian Point 3 Nuclear Power Plant
 Pipe Stress Reanalysis
Status of Work as of August 10, 1979

A. Piping

Total No. of Lines for Reanalysis	Total No. Reanalyzed	No. of Lines Within Allowables	No. of Lines Over Allowables
176	147	147	0

B. Piping Supports, Hangers, Snubbers & Nozzles

Total No. of Components to Reanalyze	Total No. Reanalyzed	No. of Components Within Original Design Loads and/ or Allowables	No. of Components Over Design Loads and/or Allowables
1462 (1)	898	898	0

Notes: (1) Estimated quantities.