

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 NYIPSB 2 b 0 - 0 0 0 0 0 0 0 0 0 0 3 4 1 1 1 1 4 _____ 5
7 8 9 14 15 25 26 30 57 CAT 58

CON'T
01 REPORT SOURCE L 6 0 5 0 0 0 2 8 6 7 1 1 2 7 7 9 8 1 1 2 8 7 9 9
7 8 60 61 68 69 74 75 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10
02 WHILE SHUTDOWN FOR REFUELING, ANALYSIS OF PRESSURIZER SAFETY VALVE
03 SETTING TESTS INDICATED THAT THE SETPOINTS FOR VALVES PCV-464, PCV-466
04 AND PCV-468 WERE BELOW THE LIMITS OF 2485±25 PSIG (AS DEFINED IN
05 TECHNICAL SPECIFICATION 3.1.A.2.C), SHOWING VALUES OF 2450, 2375 AND
06 2410 PSIG RESPECTIVELY. IT SHOULD BE NOTED THAT THE SETTINGS WERE OUT OF
07 SPECIFICATION IN THE CONSERVATIVE DIRECTION. NO SIMILAR EVENTS HAVE BEEN
08 RECORDED TO DATE.

09 SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP. SUBCODE VALVE SUBCODE
C J 11 E 12 B 13 V A L V E X 14 F 15 B 16
9 10 11 12 13 18 19 20
17 LER/RO REPORT NUMBER EVENT YEAR SEQUENTIAL REPORT NO. OCCURRENCE CODE REPORT TYPE REVISION NO.
7 9 0 1 1 3 0 I 0
21 22 23 24 26 27 28 29 30 31 32
ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS 22 ATTACHMENT SUBMITTED NPRD-4 FORM SUB. PRIME COMP. SUPPLIER COMPONENT MANUFACTURER
E 18 Z 19 Z 20 Z 21 0 0 0 0 N 23 N 24 N 25 C 7 1 1 0 26
33 34 35 36 37 40 41 42 43 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27
10 CROSBY MODEL HB VALVES PCV-464, PCV-466 AND PCV-468 WERE RESET TO WITHIN
11 TECHNICAL SPECIFICATION REQUIREMENTS. THE PROBLEM WAS DETERMINED TO BE
12 CAUSED BY MECHANICAL VALVE DRIFT.

15 FACILITY STATUS % POWER OTHER STATUS 30 METHOD OF DISCOVERY DISCOVERY DESCRIPTION 32
H 28 0 0 0 29 NA B 31 SURVEILLANCE TEST
7 8 9 10 12 13 44 45 46 80

16 ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY 35 LOCATION OF RELEASE 36
Z 33 Z 34 NA NA
7 8 9 10 11 44 45 80

17 PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION 39
0 0 0 37 Z 38 NA
7 8 9 11 12 13 80

18 PERSONNEL INJURIES NUMBER DESCRIPTION 41
0 0 0 40 NA
7 8 9 11 12 80

19 LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION 43
Z 42 NA
7 8 9 11 12 80

20 ISSUED DESCRIPTION 45 PUBLICITY 45
N 44 NA
7 8 9 10 80

NAME OF PREPARER FLOYD W. GUMBLE PHONE: 914-739-8200, X217

7912040321